

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

Office Use Only
Well ID No. _____
Inspected by _____
Twp _____ Rge _____ Sec _____
1/4 _____ 1/4 _____ 1/4 _____
Lat: _____ Long: _____

1. WELL TAG NO. D 0035493
DRILLING PERMIT NO. 825782
Water Right or Injection Well No. _____

2. OWNER:
Name Len McCoy
Address 1457 Alameda
City Moscow State ID Zip 83843

3. LOCATION OF WELL by legal description:

You must provide address or Lot, Blk, Sub. or Directions to well.

Twp. 40 North ☒ or South ☐
Rge. 5 East ☐ or West ☒
Sec. 18 NE 1/4 SE 1/4 1/4
Gov't Lot _____
County Latah 10 acres 160 acres
Lat: _____ Long: _____
Address of Well Site Strat House Hill Hwy. 95
3-4 miles North of Moscow
(Give at least name of road or landmark)
Lt. _____ Blk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)
☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD:

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

Seal Material	From	To	Weight / Volume	Seal Placement Method
<u>Bentonite</u>	<u>0</u>	<u>75</u>	<u>500 lbs.</u>	<u>Dry</u>

Was drive shoe used? ☒ ☐ N Shoe Depth(s) 75
Was drive shoe seal tested? ☐ Y ☒ N How? _____

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
<u>8</u>	<u>7</u>	<u>75</u>	<u>250</u>	<u>Steel</u>	☒	☐	☒	☐
<u>6</u>	<u>14</u>	<u>354</u>	<u>160</u>	<u>Plc</u>	☐	☒	☐	☐

Length of Headpipe _____ Length of Tailpipe _____
Packer ☐ Y ☒ N Type _____

9. PERFORATIONS/SCREENS PACKER TYPE

Perforation Method Saw
Screen Type & Method of Installation _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						☐	☐
						☐	☐
						☐	☐

10. FILTER PACK

Filter Material	From	To	Weight / Volume	Placement Method

11. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

46 ft. below ground Artesian pressure _____ lb.
Depth flow encountered _____ ft. Describe access port or control devices: _____

12. WELL TESTS:

☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
<u>approx 2</u>		<u>350</u>	<u>1 Hr.</u>

Water Temp. _____ Bottom hole temp. _____
Water Quality test or comments: _____

13. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia	From	To	Remarks: Lithology, Water Quality & Temperature	Water
10	0	4	overburden	Y
10	4	75	Soft granit	Y
8	75	119	Soft granit	Y
8	119	162	granit, firm	Y
8	162	166	Soft granit	Y
8	166	177	granit, firm	Y
8	177	221	Soft granit	Y
8	221	354	granit, firm	Y

RECEIVED
MAR 13 2006
IDWR/North

RECEIVED
NOV 30 2004
IDWR/North

Completed Depth 354 (Measurable)
Date: Started 10/28/04 Completed 10/29/04

14. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Wittwell Drilling Firm No. 58
Principal Driller Regen Witt Date 11/1/04
and _____
Driller or Operator II _____ Date _____
Operator I _____ Date _____

Principal Driller and Rig Operator Required.
Operator I must have signature of Driller/Operator II.

FORWARD WHITE COPY TO WATER RESOURCES

40 N 5 W 18