RECEIVED
JAN 11 2002
IDWR/North

Form 238-7
11/97 JGE

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Office Use Only
Inspected by
Twp Rge Sec
1/4 1/4 1/4
Lat: Long:

1. WELL TAG NO. D 0017587
DRILLING PERMIT NO. 770085
Other IDWR No.

POSTED

2. OWNER:
Name WAYNE DEWITT
Address 5224 ROBINSON LAKE RD
City MOSCOW State ID Zip 83842

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location.

N / W / E / S

Twp. 39 North [X] or South [ ]
Rge. 5 East [ ] or West [X]
Sec. 1 1/4 NE (10 acres) 1/4 NE (40 acres) 1/4 NE (160 acres)
Gov't Lot County LATAH
Lat: Long:
Address of Well Site 5224 ROBINSON LAKE RD City MOSCOW
(Give at least name of road + Distance to Road or Landmark)
Lt. Blk. Sub. Name

4. USE:
[X] Domestic [ ] Municipal [ ] Monitor [ ] Irrigation
[ ] Thermal [ ] Injection [ ] Other

5. TYPE OF WORK: check all that apply (Replacement etc.)
[X] New Well [ ] Modify [ ] Abandonment [ ] Other

6. DRILL METHOD:
[X] Air Rotary [ ] Cable [ ] Mud Rotary [ ] Other

7. SEALING PROCEDURES:

Seal/Filter Pack Material	From	To	AMOUNT Sacks or Pounds	METHOD
BENTONITE	0	20	8	DRY

Was drive shoe used? [X] Y [ ] N Shoe Depth(s) 20
Was drive shoe seal tested? [X] Y [ ] N How? 300 PSI

8. CASING/LINER:

Diameter	From	To	Guage	Material	Casing	Liner	Welded	Threaded
8	+1	20	1/4	STEEL	[X]	[ ]	[ ]	[ ]
6	125	255	160	PVC	[ ]	[X]	[ ]	[ ]
					[ ]	[ ]	[ ]	[ ]

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS:
[X] Perforations Method SAW
[ ] Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
215	255	1/8	60	6	PVC	[ ]	[X]
						[ ]	[ ]
						[ ]	[ ]

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
87 ft. below ground Artesian pressure lb.
Depth flow encountered ft. Describe access port or control devices: WELL CAP

11. WELL TESTS:
[ ] Pump [ ] Bailer [X] Air [ ] Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
155		240	1 HR

Water Temp. 54 Bottom hole temp.
Water Quality test or comments:
Depth first Water Encounter 229

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia	From	To	Remarks: Lithology, Water Quality & Temperature	Water Y	Water N
14	0	1	SOIL		
14	1	5	CLAY		
14	5	20	GRANITE HARD BLACK & WHITE		
8	20	95	GRANITE HARD BLACK & WHITE		
8	95	103	GRANITE DECOMPOSED BROWN		
8	103	187	GRANITE HARD BLACK & WHITE		
8	187	193	GRANITE DECOMPOSED BROWN		
8	193	229	GRANITE HARD BLACK & WHITE		
8	229	235	GRANITE DECOMPOSED BROWN	X	
8	235		GRANITE MEDIUM BLACK &		
		255	WHITE		

Completed Depth 255 (Measurable)
Date: Started 7/23/2001 Completed 7/24/2001

13. DRILLER'S CERTIFICATION:
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name MCPHERSON & WRIGHT DRILLING Firm No. 0376
Firm Official [signature] Date 1/9/02
and
Driller or Operator [signature] Date 1/9/02
(Sign once if Firm Official & Operator)

39N 5W 1

FORWARD WHITE COPY TO WATER RESOURCES