RECEIVED
MAY 01 1995
NORTHERN REGION
IDWR

Form 238-7
7/94

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Use Typewriter
or
Ball Point Pen

1. DRILLING PERMIT NO. 87-95-N-5-000
Other IDWR No.

2. OWNER:
Name Bill Elliott
Address 1676 Damon
City Moscow State Id Zip 83843

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location.

N / W / E / S

Twp. 40 North ☒ or South ☐
Rge. 5 East ☐ or West ☒
Sec. 29, NE 1/4 (10 acres) NE 1/4 (40 acres) 1/4 (160 acres)
Gov't Lot ____ County Latah

Address of Well Site Northwest Rd
Moscow City Idaho
(Give at least name of road + Distance to Road or Landmark)

Lt. ____ Blk. ____ Sub. Name ____

4. PROPOSED USE:
☑ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK
☑ New Well ☐ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD
☐ Mud Rotary ☑ Air Rotary ☐ Cable ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
bentonite	0	80	200 lbs	

Was drive shoe used? ☑ Y ☐ N Shoe Depth(s)
Was drive shoe seal tested? Y ☐ N ☑ How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
8	+2	239	250	Steel	☑	☐	☑	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length of Headpipe ____ Length of Tailpipe ____

9. PERFORATIONS/SCREENS
☐ Perforations Method
☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
80 ft. below ground Artesian pressure ____ lb.
Depth flow encountered 238 ft. Describe access port or control devices:
NENE 29 40N 5W

11. WELL TESTS:
☐ Pump ☐ Bailer ☑ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
approx 30		220	30 min

Water Temp. ____ Bottom hole temp. ____
Water Quality test or comments: ____

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Water Y	Water N
10	0	80	overburden clay		✓
8	80	107	~~Quartz~~ clay		✓
8	107	112	Quartz		✓
8	112	127	clay		✓
8	127	134	Quartz		✓
8	134	237	clay		✓
8	237	238	Quartz	✓	

Completed Depth 238 (Measurable)
Date: Started 4/14/95 Completed 4/21/95

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name WITT Well Drilling Firm No. 58
Firm Official Earl L Witt Date 4/28/95
and
Supervisor or Operator Roger Witt Date 4/28/95
(Signature if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES