

RECEIVED

Form 238 SEP 17 2002
11/97

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

IDWR/North

1. WELL TAG NO. D 00 02609

DRILLING PERMIT NO. 783257

Other IDWR No.

2. OWNER:

Name Jackie OLSON
Address 623 2nd St.
City Clarkston State WA Zip 99403

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.

N
W
E
S

		X	

Twp. 39 North ☒ or South ☐
Rge. 5 East ☐ or West ☒
Sec. 14 1/4 NE 1/4 SE 1/4
Gov't Lot County LATAH
Lat. Long.
Address of Well Site 1 mile
East of City MOSCOW
(Give at least name of road + Distance to Road or Landmark)

Lt. Blk. Sub. Name

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK	AMOUNT		METHOD
	From	To	
Bentonite	0	38	450# Top Pour

Was drive shoe used? ☐ Y ☒ N Shoe Depth(s)
Was drive shoe seal tested? ☒ Y ☐ N How? Air Pressure

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6"	+2	-57	250	Steel	☒	☐	☒	☐
4.5	-50	-150	160	PVC	☐	☒	☐	☐

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS

☒ Perforations Method SAW
Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
-110	-150	1/4x4	72	4.5	PVC	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

12 ft. below ground Artesian pressure lb.
Depth flow encountered ft. Describe access port or control devices: Top of casing

39N 5W 14

FORWARD WHITE COPY TO WATER RESOURCES

Office Use Only
Inspected by
Twp. Rge. Sec.
1/4 1/4 1/4
Lat. Long.

11. WELL TESTS:

☐ Pump ☐ Bailor

Yield gal./min.	Drawdown	Pumping Level	Time
15			1.5

Water Temp. 56° Bottom hole temp.

Water Quality test or comments: Good

Depth first Water Encounter 125

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
10	0	3	Overburden		☒
10	3	38	Soft Clay		☒
10	38	58	Soft Decomposed Granite		☒
6	58	71	Med Hd Granite		☒
6	71	75	Soft Granite		☒
6	75	150	Med Hd Granite & Scams	RS	

Completed Depth 150 ft (Measurable)

Date: Started 8-12-02 Completed 8-13-02

13. DRILLER'S CERTIFICATION

We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name UHLENKOTT Drilling Firm No. 125

Firm Official Dan J. Uhlenkott Date 9-2-02

and Driller or Operator Stu Uhlenkott Date 9-2-02

(Sign once if Firm Official & Operator)