Form 238-7
3/95

RECEIVED
AUG 12 1997
NORTHERN REGION
IDWR

POSTED

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Use Typewriter or Ballpoint Pen

097947

Office Use Only
Inspected by _____
Twp____ Rge____ Sec____
____1/4____1/4____1/4
Lat: : : Long: : :

1. DRILLING PERMIT NO. D-55
Other IDWR No. 86-97-N-22

2. OWNER:
Name Will Green
Address 1050 Kottke Rd.
City Moscow State Id Zip 83843

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location.

N / W / E / S

Twp. 39 North ☑ or South ☐
Rge. 5 East ☐ or West ☑
Sec. 27, ____ 1/4 NE 1/4 NW 1/4
(10 acres, 40 acres, 160 acres)
Gov't Lot ____ County ____
Lat: : : Long: : :
Address of Well Site Same
City Moscow
(Give at least name of road + Distance to Road or Landmark)

Lt.____ Blk.____ Sub. Name____

4. USE:
☑ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other____

5. TYPE OF WORK check all that apply (Replacement etc.)
☑ New Well ☐ Modify ☐ Abandonment ☐ Other____

6. DRILL METHOD
☑ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other____

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
bentonite	0	19	100 lbs.	dry

Was drive shoe used? ☑ Y ☐ N Shoe Depth(s)____
Was drive shoe seal tested? ☐ Y ☑ N How?____

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
8	+1	19	250	Steel	☐	☐	☐	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length of Headpipe____ Length of Tailpipe____

9. PERFORATIONS/SCREENS
☐ Perforations Method____
☐ Screens Screen Type____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
____ft. below ground Artesian pressure ____lb.
Depth flow encountered ____ft. Describe access port or control devices:____

11. WELL TESTS:
☐ Pump ☐ Bailer ☑ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
dry			

Water Temp. ____ Bottom hole temp. ____
Water Quality test or comments: ____
____ Depth first Water Encountered ____

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Water Y	Water N
10	0	5	overburden		✓
10	5	19	granit, hard		✓
8	19	500	granit, hard		

Completed Depth 500 (Measurable)
Date: Started 6/18/97 Completed 6/27/97

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Witt Well Drilling Firm No. 58
Firm Official Roger Witt Date 7/9/97
and
Supervisor or Operator____ Date____
(Sign once if Firm Official & Operator)

NENW 27 39N 5W

FORWARD WHITE COPY TO WATER RESOURCES