

ENT'D

027829

REPORT OF WELL DRILLER
State of IdahoRECEIVED
APR 19 1966

Department of Reclamation

State law requires that this report shall be filed with the State Reclamation Engineer within 30 days after completion or abandonment of the well.

WELL OWNER: Malcolm Furniss
Name
Address 958 Orchard Ave
McDon, Idaho, 87-64-N-2

Owner's Permit No. 214
NATURE OF WORK (check): Replacement well ☐
New well ☒ Deepened ☐ Abandoned ☐

Water is to be used for: domestic

METHOD OF CONSTRUCTION: Rotary ☐ Cable ☒
Dug ☐ Other ☐

(explain)
CASING SCHEDULE: Threaded ☐ Welded ☒

8 "Diam. from 0 ft. to 110 ft.
"Diam. from ft. to ft.
"Diam. from ft. to ft.
"Diam. from ft. to ft.

Thickness of casing: 4 Material:
Steel ☒ concrete ☐ wood ☐ other ☐

(explain)
PERFORATED? Yes ☒ No ☐ Type of
perforator used: brush

Size of perforations: 8 " by 6 "
perforations from 95 ft. to 105 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

WAS SCREEN INSTALLED? Yes ☐ No ☒

Manufacturer's name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

CONSTRUCTION: Well gravel packed? Yes ☐

No. ☐ size of gravel Gravel

placed from ft. to ft. Surface seal

provided? Yes ☐ No ☐ To what depth?

ft. Material used in seal:

Did any strata contain unusable water? Yes ☐

No. ☐ Type of water:


Depth of strata ft. Method of sealing

strata off:

Surface casing used? Yes ☐ No. ☐

Cemented in place? Yes ☐ No ☐

Locate well in section



LOCATION OF WELL: County Blaine

SW 1/4 NE 1/4 Sec. 5 T. 39 N. R. 5 E. W

1 ac. # 344 1662

Use other side for additional remarks

Size of drilled hole: 8 Total
depth of well: 110 Standing water
level below ground: 55 Temp.
Fahr. 54 Test delivery: 10 gpm
or cfs Pump? ☐ Bail ☒
Size of pump and motor used to make test:

Length of time of test: Hrs. / Min.

Drawdown: 40 ft. Artesian pressure: ft.

above land surface Give flow cfs

or gpm. Shutoff pressure:

Controlled by: Valve ☐ Cap ☐ Plug ☐

No control ☐ Does well leak around casing?

Yes ☐ No ☒

DEPTH MATERIAL WATER

FROM TO YES OR NO

FEET FEET

0 55 yellow clay

55 80 quartz sand and yellow clay

80 95 yellow clay sand yes

95 105 white quartz sand about 7 gal per min of water

105 110 red clay with sand

Work started: June 26, 1964

Work finished: July 6, 1964

Well Driller's Statement: This well was

drilled under my supervision and this report

is true to the best of my knowledge.

Name: Philip Olson

Address: Box 354

Signed by: Philip Olson

License No. 214 Date: March 21, 1966