

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

1. WELL TAG NO. D

DRILLING PERMIT NO.

Water Right or Injection Well No.

00 51792
346278



2. OWNER:

Name

Address

City

MATT LARSEN
P.O. Box 88
Pothatch State ID Zip 83853

3. LOCATION OF WELL by legal description:

You must provide address or Lot, Blk, Sub. or Directions to well.

Twp. 71 North ☒ or South ☐

Rge. 4 East ☐ or West ☒

Sec. 17 1/4 NE 1/4 SE 1/4

Gov't Lot

Lat. : : Long. : :

Address of Well Site 1050 Guernsey Cutover Rd

City Pothatch

Lt. : Blk. : Sub. Name :

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply

(Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD:

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

Seal Material	From	To	Weight / Volume	Seal Placement Method
Bentonite	0	18	350*	Top Pour

Was drive shoe used? ☐ Y ☒ N Shoe Depth(s)

Was drive shoe seal tested? ☐ Y ☒ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6"	+2	-18	250	Steel	☒	☐	☒	☐
4.5"	-10	-350	160	PVC	☐	☒	☐	☐

Length of Headpipe Length of Tailpipe

Packer ☐ Y ☒ N Type

9. PERFORATIONS/SCREENS PACKER TYPE

Perforation Method SAW

Screen Type & Method of Installation

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
-280	-350	1/4x1/4	68	4.5"	PVC	☐	☒

10. FILTER PACK

Filter Material	From	To	Weight / Volume	Placement Method

11. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

144 ft. below ground Artesian pressure lb.

Depth flow encountered ft. Describe access point or control devices:

Top of casing

41 N 4W 17

Office Use Only
Well ID No. _____
Inspected by _____
Twp _____ Rge _____ Sec _____
1/4 1/4 1/4
Lat. : : Long. : :

12. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
10			1.5

Water Temp. 56°

Bottom hole temp.

Water Quality test or comments: Good

Depth first Water Encounter 225'

13. LITHOLOGIC LOG: (Describe repairs or abandonment)

Water

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
10	0	7	Brown Clay		
10	7	18	Med. Hd Bsh		
6	18	186	" "		
6	181	275	Brown w/ med Bsh		
6	275	350	Tan w/ med Bsh	10	

RECEIVED
APR 26 2007
IDWR/North

Completed Depth 350' (Measurable)

Date: Started 4-14-04 Completed 4-14-04

14. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Unhookoff Drilling Firm No. 125

Principal Driller [Signature] Date 4-14-07

and Driller or Operator II Date

Operator I Date

Principal Driller and Rig Operator Required.
Operator I must have signature of Driller/Operator II.