Form 238-7
11/97 JGE

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Office Use Only
Inspected by
Twp Rge Sec
1/4 1/4 1/4
Lat: Long:

1. WELL TAG NO. D 0035332
DRILLING PERMIT NO. 82987 1
Other IDWR No.

2. OWNER:
Name RALPH KERNS
Address 890 REGENT COURT
City SAN CARLOS State CA Zip 94070

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location.

N / W / E / S

Twp. 42 North [X] or South [ ]
Rge. 5 East [ ] or West [X]
Sec. 8
1/4 (10 acres) SW 1/4 (40 acres) SE 1/4 (160 acres)
Gov't Lot County LATAH
Lat: Long:
Address of Well Site 1100 CORA RD
City POTLATCH
(Give at least name of road + Distance to Road or Landmark)
Lt. Blk. Sub. Name

4. USE:
[X] Domestic [ ] Municipal [ ] Monitor [ ] Irrigation
[ ] Thermal [ ] Injection [ ] Other

5. TYPE OF WORK: check all that apply (Replacement etc.)
[X] New Well [ ] Modify [ ] Abandonment [ ] Other

6. DRILL METHOD:
[X] Air Rotary [ ] Cable [ ] Mud Rotary [ ] Other

7. SEALING PROCEDURES:

Seal/Filter Pack Material	From	To	AMOUNT Sacks or Pounds	METHOD
BENTONITE	0	134	45	DRY

Was drive shoe used? [X] Y [ ] N Shoe Depth(s) 134
Was drive shoe seal tested? [X] Y [ ] N How? 300 PSI

8. CASING/LINER:

Diameter	From	To	Guage	Material	Casing	Liner	Welded	Threaded
8	+1	134	1/4	STEEL	[X]	[ ]	[X]	[ ]
					[ ]	[ ]	[ ]	[ ]
					[ ]	[ ]	[ ]	[ ]

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS:
[ ] Perforations Method
[ ] Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						[ ]	[ ]
						[ ]	[ ]
						[ ]	[ ]

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
25 ft. below ground Artesian pressure lb.
Depth flow encountered ft. Describe access port or control devices: WELL CAP

11. WELL TESTS:
[ ] Pump [ ] Bailer [X] Air [ ] Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
15		200	1 HR

Water Temp. 55 Bottom hole temp.
Water Quality test or comments:
Depth first Water Encounter 171

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Water Y	Water N
14	0	4	SOIL		
14	4	26	CLAY		
14	26	117	ARGELITE SOFT		
8	117	171	ARGELITE MEDIUM		
8	171	199	ARGELLITE SOFT	X	
8	199	215	ARGELITE MEDIUM		

Completed Depth 215 (Measurable)
Date: Started 2/16/2005 Completed 2/20/2005

13. DRILLER'S CERTIFICATION:
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name MCPHERSON & WRIGHT DRILLING Firm No. 0376
Firm Official Date 4/21/2005
and
Driller or Operator Date 4/21/2005
(Signature if Firm Official & Operator)

42N 5W 8

FORWARD WHITE COPY TO WATER RESOURCES