

Form 238-7
6/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1 WELL TAG NO D 0067913
Drilling Permit No 875565

Water right or injection well #
2 OWNER Ted Kiblen

Name
Address 4626 Hwy. 95
City Moscow State Id. Zip 83843

3 WELL LOCATION:
Twp 40 North ☒ or South ☐ Rge. 5 East ☐ or West ☒

Sec 17 NW 1/4 SW 1/4 NE 1/4

Gov't Lot _____ County Latah

Lat N 46 ° 48.353 (Deg. and Decimal minutes)

Long W 117 ° 00.035 (Deg. and Decimal minutes)

Address of Well Site same

City _____

Lot _____ Bk _____ Sub. Name _____

4 USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation ☐ Thermal ☐ Injection
☐ Other _____

5 TYPE OF WORK:
☒ New well ☐ Replacement well ☐ Modify existing well
☐ Abandonment ☐ Other _____

6 DRILL METHOD:
☒ Air Rotary ☐ Mud Rotary ☐ Cable ☐ Other _____

7 SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
Bentonite	0	38	750 lbs	Dry

8 CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing Liner	Threaded	Welded
8"	+1	38	250	Steel	☒	☐	☒

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) _____

9 PERFORATIONS/SCREENS:
Perforations ☐ Y ☒ N Method _____
Manufactured screen ☐ Y ☒ N Type _____
Method of installation _____

From (ft)	To (ft)	Slot size	Number/m	Diameter (nominal)	Material	Gauge or Schedule

Length of headpipe _____ Length of Tailpipe _____

Packer ☐ Y ☒ N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method

11. FLOWING ARTESIAN:
Flowing Artesian? ☐ Y ☒ N Artesian Pressure (PSIG) _____

12. STATIC WATER LEVEL and WELL TESTS:
Depth first water encountered (ft) 258 Static water level 80'
Water temp. (°F) _____ Bottom hole temp. (°F) _____
Describe access point _____

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Boiler
	<u>approx 2</u>	<u>1 Hr.</u>	☐	☒

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp
8	0	17	overburden
8	17	32	soft granite
8	32	51	granite, firm
8	51	145	soft granite
8	145	239	granite, firm
8	239	303	granite, hard

RECEIVED
SEP 23 2015
IDWR / NORTH

Completed Depth (Measurable) 303'
Date Started: 6/8/15 Date Completed 6/12/15

14. DRILLER'S CERTIFICATION:
I/we certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name WITT Well Drilling Co Inc 58

*Principal Driller Roger WITT Date 6/12/15

*Driller Roger WITT Date _____

*Operator II _____ Date _____

Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required