

RECEIVED

Form 238-7
11/97

JUN 11 2002

IDAHO DEPARTMENT OF WATER RESOURCES

IDWR/Not:

WELL DRILLER'S REPORT

Office Use Only		
Inspected by		
Twp	Rge	Sec
1/4	1/4	1/4
Lat	Long	
☐ Pump ☐ Bailer ☒ Art ☐ Flowing Artesian		

1. WELL TAG NO. D 0022161

DRILLING PERMIT NO. 776948

Other IDWR No.

2. OWNER:

Name Mike Bell

Address P.O. Box 118

City Grinnell State ID Zip 83857

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.

N		Twp. 42		North ☒ or South ☐	
E		Rge. 4		East ☐ or West ☒	
S		Sec. 34		1/4 SW 1/4 NE 1/4	
W		Gov't Lot		County Catara	
		Lat		Long	
		Address of Well Site		2 miles east of Grinnell City Grinnell	

(Give at least some of road & distance to road or landmark)

Lt. Blk. Sub. Name

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK	AMOUNT	METHOD
Material From To	Sacks or Pounds	
Bentonite -2 19	200 lb	Dry

Was drive shoe used? ☐ Y ☒ N Shoe Depth(s)Was drive shoe seal tested? ☐ Y ☒ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6" +2	19	250		steel	☒	☐	☒	☐
4 1/2 -10	375	160		PVC	☐	☒	☐	☐

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS

☒ Perforations Method Circular SAW
Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
-330	375	1/4" x 3/8"	200	4 1/2"	PVC	☒	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

10 ft. below ground Artesian pressure lb.

Depth flow encountered ft. Describe access port or control devices: Top of well

42 N 4 W 34 FORWARD WHITE COPY TO WATER RESOURCES

11. WELL TESTS:

☐ Pump ☐ Bailer

Yield gal/min.	Drawdown	Pumping Level	Time
2 gpm			

Water Temp. 58.0 Bottom hole temp. 38.0

Water Quality test or comments: Good

Depth first Water Encounter

12. LITHOLOGIC LOG: (Describe repairs or abandonment) Water

Bore Dia	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
8"	0	2	clay		
	2	12	clay		
	12	20	med shale		
6"	20	130	med shale		
	130	190	stony shale		
	190	217	med shale		
	217	375	soft to med shale		

RECEIVED

JUN 18 2002

IDWR/Not

Completed Depth 375 ft (Measurable)
Date: Started 5/15/02 Completed 5/17/02

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Uhlentz & Drilling Firm No. 125
Firm Official Jim Uhlentz Date June 8, 02
and
Driller or Operator Jim Uhlentz Date June 8, 02
(Sign once if Firm Official & Operator)