



METONARS MAP LAYAN
COUNTY - T39N-R5W
SECTION 2

REPORT OF WELL DRILLER
MAR 13 1968 State of Idaho

State law requires that this report shall be filed with the State Reclamation Engineer within 30 days after completion or abandonment of the well.

WELL OWNER:

Name HOWARD BERGLUND

Address MOSCOW IDAHO

87-68-N-4

Owner's Permit No. _____

NATURE OF WORK (check): Replacement well ☐

New well ☒ Deepened ☐ Abandoned ☐

Water is to be used for: DOMESTIC

METHOD OF CONSTRUCTION: Rotary ☒ Cable ☐
Dug ☐ Other _____

(explain)

CASING SCHEDULE: Threaded _____ Welded _____

6" 50 "Diam. from 0 ft. to 80 ft.

"Diam. from _____ ft. to _____ ft.

"Diam. from _____ ft. to _____ ft.

"Diam. from _____ ft. to _____ ft.

Thickness of casing: .250 Material:

Steel ☒ concrete ☐ wood ☐ other ☐

(explain)

PERFORATED? Yes ☐ No ☒ Type of
perforator used: _____

Size of perforations: _____ " by _____ "

perforations from _____ ft. to _____ ft.

perforations from _____ ft. to _____ ft.

perforations from _____ ft. to _____ ft.

perforations from _____ ft. to _____ ft.

WAS SCREEN INSTALLED? Yes ☐ No ☒

Manufacturer's name _____

Type _____ Model No. _____

Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

CONSTRUCTION: Well gravel packed? Yes ☐

No ☒ size of gravel _____ Gravel

placed from _____ ft. to _____ ft. Surface seal

provided? Yes ☐ No ☐ To what depth?

_____ ft. Material used in seal:

CASING SET IN DECOMPOSED

Did any strata contain unusable water? Yes ☐


No ☒ Type of water: _____

Depth of strata _____ ft. Method of sealing
strata off: _____

Surface casing used? Yes ☐ No ☒

Cemented in place? Yes ☐ No ☐

Locate well in section



SECTION
2

LOCATION OF WELL: County JEFFERSON
_____ & _____ Sec. 2 T 39 N R. 5 W

Size of drilled hole: 6" Total
depth of well: 142 Standing water

level below ground: 62' Temp.

Fahr. 51 ° Test delivery: 10 gpm

or _____ cfs Pump? ☐ Bail ☐

Size of pump and motor used to make test:

AIR TEST BY R.I.G.

Length of time of test: 1 Hrs. Min.

Drawdown: _____ ft. Artesian pressure: ft.

above land surface Give flow _____ cfs

or _____ gpm. Shutoff pressure:

Controlled by: Valve ☐ Cap ☐ Plug ☐

No control ☐ Does well leak around casing?

Yes ☐ No ☒

DEPTH		MATERIAL	WATER YES OR NO
FROM	TO		
FEET	FEET		
0	76	CLAY (YELLOW)	
76	122	GRAY DECOMPOSED GRANITE	
122	142	SEALED GRAY DECOMPOSED GRANITE WATER BEARING AT 10 BPM	
		GOOD WELL FOR A GRANITE AREA	

Use other side for additional remarks

USGS