

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORTLocation Corrected by IDWR To:
T40N R02W Sec. 5 SENESE
By: mciscell 2013-09-11

1. WELL TAG NO. D 0057314

Drilling Permit No. 859359
Water right or injection well # _____

2. OWNER

Name KEITH & MARGARET BEHREND
Address 1102 EID ROAD
City MOSCOW State ID Zip 83843

3. WELL LOCATION:

Twp. 38 North ☒ or South ☐ Rge. 5 W East ☐ or West ☒
Sec. 6 SE 1/4 SW 1/4 1/4
10 acres 40 acres 160 acresGov't Lot _____ County _____
Lat. _____ (Deg. and Decimal minutes)
Long. _____ (Deg. and Decimal minutes)
Address of Well Site _____City _____
Lot _____ Blk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation ☐ Thermal ☐ Injection
☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Replacement well ☐ Modify existing well
☐ Abandonment ☐ Other _____

6. DRILL METHOD:

☒ Air Rotary ☐ Mud Rotary ☐ Cable ☐ Other _____

7. SEALING PROCEDURES

Seal material	From (ft)	To (ft)	Quantity (lbs or ft³)	Placement method/procedure
BENTONITE	0	63	37	DRY

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
8	+1	62	1/4	STEEL	☒	☐	☐	☒
6	45	165	200	PVC	☐	☒	☐	☐

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 62

9. PERFORATIONS/SCREENS:

Perforations ☒ Y ☐ N Method SAW
Manufactured screen ☐ Y ☐ N Type _____
Method of installation _____

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
45	165	12*1/8	60	6	PVC	200

Length of Headpipe _____ Length of Tailpipe _____
Packer ☐ Y ☐ N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft³)	Placement method
-----------------	-----------	---------	-----------------------	------------------

11. FLOWING ARTESIAN:

Flowing Artesian? ☐ Y ☐ N Artesian Pressure (PSIG) _____
Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 131 Static water level (ft) 15
Water temp. (°F) 55 Bottom hole temp. (°F) _____
Describe access port WELL CAP

Well test:

Test method:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
	10	1 HR	☐	☐	☒	☐

Water Quality test or comments:

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water Y	N
12	0	16	CLAY BROWN		
12	16	27	SAND		
12	27	56	GRANITE SOFT		
12	56	62	GRANITE BLACK & WHITE MEDIUM		
8	62	74	GRANITE BLACK & WHITE MEDIUM		
8	74	131	GRANITE SOFT BLACK & WHITE		
8	131	157	GRANITE & QUARTZ SOFT	X	
8	157	165	GRANITE BLACK & WHITE MEDIUM		

RECEIVED

AUG 02 2010

IDWR/North

Completed Depth (Measurable) 165
Date: Started 11/17/09 Completed 11/19/09

14. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

MCPHERSON & WRIGHT

Company Name DRILLING Co. No. 0376*Principal Driller Ted Wright Date 11/25/09*Driller Gray Wright Date 11/25/09

*Operator II _____ Date _____

Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.

38N 05W 06E