

Form 238-7
6/02

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

CORRECTED REPORT

Office Use Only	
Well ID No.	386345
Inspected by	B. Hynes
Twp	40N
Rge	5W
Sec	31
1/4	1/4 SW 1/4 S
Lat:	
Long:	60041

1. WELL TAG NO. D 00 33789
DRILLING PERMIT NO. 815667

Water Right or Injection Well No. _____

2. OWNER:

Name Lisa Greenville
Address 1217 Canterbury Rd.
City Moscow State ID Zip 83843

3. LOCATION OF WELL by legal description:

You must provide address or Lot, Blk, Sub. or Directions to well.

Twp. 40 North ☒ or South ☐
Rge. 5 East ☐ or West ☒
Sec. 31 SW 1/4 NW 1/4
Gov't Lot _____
County LATAH

Lat: _____ Long: _____
Address of Well Site 1217 Canterbury Rd
City Moscow

LI: _____ Blk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD:

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

Seal Material	From	To	Weight / Volume	Seal Placement Method
Bentonite	22	32	410 #	Top Pour

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 138'
Was drive shoe seal tested? ☒ Y ☐ N How? Air Pressure

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6"	+2	-138	250	Steel	☒	☐	☐	☐
4.5"	-27	-140	160	PVC	☐	☒	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

Packer ☐ Y ☒ N Type _____

9. PERFORATIONS/SCREENS PACKER TYPE

Perforation Method SAW

Screen Type & Method of Installation _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
-330	-370	6x4	36	4.5	PVC	☐	☒

10. FILTER PACK

Filter Material	From	To	Weight / Volume	Placement Method

11. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

176 ft. below ground Artesian pressure — lb.
Depth flow encountered — ft. Describe access port or control devices: Top of casing

40N 5W 31

12. WELL TESTS:

☐ Pump	☐ Baller	☒ Air	☐ Flowing Artesian
Yield gal./min.	Drawdown	Pumping Level	Time
<u>100</u>			<u>1.25</u>

Water Temp. 56° Bottom hole temp. _____

Water Quality test or comments: Good

Depth first Water Encounter 32'

13. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Ole.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
10	0	22	FIN CLAY		
2	22	49	Coarse White Sand		
7	49	140	Brown + gray Clay		
6	140	212	Hard Gray Silt		
6	212	289	Med. H. Silt		
6	289	312	CLAY		
6	312	460	SAND H ₂ O		

RECEIVED

JUN 03 2004

DWR/NORTH

Completed Depth 376 (Measurable)

Date: Started 5 19 04 Completed 5-19-04

14. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name WILEY/KOHL Drilling Firm No. 125

Principal Driller Tom Schlenker Date 5-23-04

Driller or Operator Bob Wile Date 5-23-04

Operator _____ Date _____

Principal Driller and Rig Operator Required.

Operator I must have signature of Driller/Operator II.

FORWARD WHITE COPY TO WATER RESOURCES