RECEIVED

MAR 24 2003

Form 238-7
11/97 JGE

IDWR/North

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Office Use Only
Inspected by
Twp Rge Sec
1/4 1/4 1/4
Lat: Long:

1. WELL TAG NO. D ~~0021691~~ D223911
DRILLING PERMIT NO. 787009
Other IDWR No.

2. OWNER: * Correct Tag #
Name VAN THOMPSON
Address 5285 HWY 95
City VIOLA State ID Zip 83872

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location.

POSTED

Twp. 41 North [X] or South [ ]
Rge. 5 East [ ] or West [X]
Sec. 17 1/4 (10 acres) NE 1/4 (40 acres) NE 1/4 (160 acres)
Gov't Lot County LATAH
Lat: Long:
Address of Well Site SAME City
(Give at least name of road + Distance to Road or Landmark)
Lt. Blk. Sub. Name

4. USE:
[X] Domestic [ ] Municipal [ ] Monitor [ ] Irrigation
[ ] Thermal [ ] Injection [ ] Other

5. TYPE OF WORK: check all that apply (Replacement etc.)
[X] New Well [ ] Modify [ ] Abandonment [ ] Other

6. DRILL METHOD:
[X] Air Rotary [ ] Cable [ ] Mud Rotary [ ] Other

7. SEALING PROCEDURES:

Seal/Filter Pack Material	From	To	AMOUNT Sacks or Pounds	METHOD
BENTONITE	0	20	8	DRY

Was drive shoe used? [X] Y [ ] N Shoe Depth(s) 20
Was drive shoe seal tested? [X] Y [ ] N How? 300 PSI

8. CASING/LINER:

Diameter	From	To	Guage	Material	Casing	Liner	Welded	Threaded
8	+1	20	1/4	STEEL	[X]	[ ]	[X]	[ ]
6	10	305	200	PVC	[ ]	[X]	[ ]	[ ]
					[ ]	[ ]	[ ]	[ ]

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS:
[ ] Perforations Method
[ ] Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						[ ]	[ ]
						[ ]	[ ]
						[ ]	[ ]

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
157 ft. below ground Artesian pressure lb.
Depth flow encountered ft. Describe access port or control devices: WELL CAP

11. WELL TESTS:
[ ] Pump [ ] Bailer [X] Air [ ] Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
1 1/2		405	1 HR

Water Temp. 55 Bottom hole temp.
Water Quality test or comments:
Depth first Water Encounter 395

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Water Y	Water N
14	0	1	SOIL		
14	1	13	CLAY BROWN		
14	13	20	BASALT WEATHERED		
8	20	133	BASALT WEAHTERED		
8	133	455	ARGELITE SOFT	X	

Completed Depth 455 (Measurable)
Date: Started 9/13/2002 Completed 9/21/2002

13. DRILLER'S CERTIFICATION:
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name MCPHERSON & WRIGHT DRILLING Lic. No. 0376
Firm Official Ted Cwright Date 3/17/2003
and
Driller or Operator Gary L Wright Date 3/17/2003
(Sign once if Firm Official & Operator)

4/N 5W 17

FORWARD WHITE COPY TO WATER RESOURCES