Form 238-7
7/98
Starships Consulting and Management Services

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT 78239

RECEIVED
OCT 14 1998
NORTHERN REGION
IDWR

Office Use Only
Inspected by_____
Twp____Rge____Sec____
____1/4____1/4____1/4
Lat: : : Long: : :

1. WELL TAG NO. D5300
Drilling Permit No:
Other IDWR No. 97-98-N-34

2. OWNER **Well Number:** 768
Name MCDOWELL, DON
Address 1045 PENNISULA RD
City PRIEST RIVER State ID Zip 83856

3. LOCATION OF WELL by legal description
sketch map location must agree with written location



Twp. 56 ☑ North or ☐ South
Rge. 04 ☐ East or ☑ West
Sec. 06 1/4 NW 1/4 NW 1/4
Gov't Lot_____ County BONNER
Lat: : : Long: :
Address of Well Site SAME AS ABOVE
City PRIEST RIVER
(Give at least name of road + Distance to Road or Landmark)
Lt._____ Blk. _____ Sub. Name _____

4. USE:
☑ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement, etc.)
☑ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD
☑ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
BENTONITE	0	20	10 SACKS	DRY

Was drive shoe used? ☑ Y ☐ N Shoe Depth(s) 346
Was drive shoe seal tested? ☐ Y ☐ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+2	-346	.250	STEEL	☑	☐	☑	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS
☐ Perforations Method _____
☐ Screens Screen Type _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
200 ft. below ground Artesian pressure_____ lb.
Depth flow encountered_____ ft. Describe access port or control devices: _____

56N 4W 6

11. WELL TESTS:
☐ Pump ☐ Bailer ☑ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
20			

Water Temp. _____ Bottom Hole Temp _____
Water Quality test or comments: _____
Depth first Water encountered 315

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Water Y	Water N
8	0	20	Sand fine Tan	☐	☑
6	20	36	Sand Tan	☐	☑
6	36	310	Clay Gray Sitly	☐	☑
6	310	325	Clay Brown Sand	☑	☐
6	325	346	Gravels & Sand	☑	☐

Completed Depth 346' (Measurable)
Date: Started 9/16/98 Completed 9/17/98

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H20 WellService, Inc. Firm No. 448
Firm Official _____ Date 9/17/98
and
Supervisor or Operator _____ Date 9/17/98
(Sign Once if Firm Offical and Operator)
(Jim McLeslie)