Form 238-7
6/93

POSTED

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

95685

RECEIVED
Ball Point Pen
AUG 2 0 1994
NORTHERN REGION
IDWR

1. DRILLING PERMIT NO. 97-94-N-44
Other IDWR No.

2. OWNER:
Name Bruce + Chris Mortensen
Address RT 4 Box 1000
City Oldtown State ID Zip 83823

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location.

N / W / E / S — X

T. 56 North ☒ or South ☐
R. 5 East ☐ or West ☒
Sec. 19, NW 1/4 (10 acres) SW 1/4 (40 acres) ____ 1/4 (160 acres)
Gov't Lot ____ County Bonner

Address of Well Site Hyway #2 mile marker 1 west of Hyway
(Give at least Direction + Distance to Road or Landmark)

Lot No. ____ Block No. ____ Subd. Name

4. PROPOSED USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK
☒ New Well ☐ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD
☐ Mud Rotary ☐ Air Rotary ☒ Cable ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
Betonite	0	18	6	Temp Casing

Was drive shoe seal tested? Y☐ N☒ How?

8. CASING/LINER:

Diameter	From	To	Guage	Casting	Liner	Steel	Plastic	Welded	Threaded
6	0	75	250			☒	☐	☒	☐
						☐	☐	☐	☐
						☐	☐	☐	☐
						☐	☐	☐	☐

Final location of shoes 75'
Top Packer or Headpipe ____ Bottom Tailpipe ____

9. PERFORATIONS/SCREENS
☐ Perforations Method Johnson
☒ Screens Type Telescoping Material Stainless Steel

From	To	Slot Size	Number	Diameter	Tele/Pipe Size	Casting	Liner
75	80	25		6"		☐	☐
						☐	☐
						☐	☐
						☐	☐

NWSW 19 56N 5W

10. WELL TESTS:
☐ Pump ☒ Bailer ☐ Air ☐ ~~Flowing Artesian~~

Yield gal./min.	Drawdown	Pumping Depth	Time
10	3	37'	1 hr

Temperature of water ____ Was a water analysis done? Yes ☐ No ☐
By whom?
Water Quality (odor, etc.)
Bottom Hole Temperature

11. STATIC WATER LEVEL:
35 ft. below surface Depth artesian flow found
Artesian pressure ____ lb. Describe access port
Describe Controlling Devices:

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	GPM	SWL
8	0	18	Clay		
6	18	25	clay		
	25	35	Clay + Sand		
	35	45	Clay + Sand		X
	45	65	Clay + Sand		
	65	70	Clay + Sand		
	70	80	Sand		

OFFICE USE ONLY
Inspected by TDK
Twp 56N Rge 5W Sec 19
NE 1/4 SW 1/4

MICROFILMED DEC 29 1998
MICROFILMED AUG 25 1999

Date: Started 6-21-94 Completed 6-22-94

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Carl Pitts + Sons Firm No 168
Firm Official Carl Pitts Date 6-22-94
and
Supervisor or Operator Steve Pitts Date 6-22-94
(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES

SCANNED
DEC 30 2021