

March 10, 2021

Manuel Rauhut
Idaho Department of Water Resources
P.O. Box 83720
Boise, ID 83720-0098

Subject: Annual Monitoring Report for Permits 63-32680, 63-33207, 63-33296, 63-34038, 63-34221, and 63-34202

Dear Manuel:

Accompanying this letter, please find one copy of the 2020 monitoring report for permits 63-32680, 63-33207, 63-33296, 63-34038, 63-34221, and 63-34202.

This report complies with the annual report requirement for permits 63-32680 and 63-33296. Although annual reports are not required for the other permits listed above, they all have monitoring requirements and share some of the same diversion points and places of use so we have combined the monitoring data into a single comprehensive report. An excel spreadsheet of the water level data (Appendix D) will be provided to IDWR in a separate email through a file sharing website.

Please contact me with any questions.

Sincerely,



Terry M. Scanlan, P.E., P.G.
Principal Engineer/Hydrogeologist

Enclosure

Cc: Steve Meyer – CS Beef Packers
Vic Conrad – JR Simplot Company
Ann Vonde, Deputy Attorney General – Attorney for Idaho Department of Corrections
Michael Lawrence, Givens Pursley – Attorney for Suez

**2020 MONITORING REPORT FOR WATER RIGHT
PERMIT NOS. 63-32680, 63-33207, 63-33296,
63-34038, 63-34202, AND 63-34221**


Prepared for

**CS Beef Packers, LLC
17365 South Cole Road
Kuna, ID 83634**

Prepared by

**SPF Water Engineering, LLC
300 East Mallard, Suite 350
Boise, Idaho 83706
(208) 383-4140**

March 10, 2021



Executive Summary

This report is the seventh annual report prepared as required by the monitoring plan for water right permits 63-32680 and 63-33296 and the fifth annual report prepared for permits 63-34038 and 63-33207. Additionally, this is the third year that this report contains data for permits 63-34202 and 63-34221.

2020 Permit Activities

1. Four irrigation supply wells (Irrigation Wells No. 1, No. 2, No. 3, and No. 4) and a monitoring well were monitored throughout the 2020 irrigation season.
2. Two industrial supply wells (Plant Wells 1 and 2) for the CS Beef packing plant were monitored throughout 2020.
3. After downloading the pressure transducer data from Irrigation Well No. 3 on November 11, 2020 the transducer and cable were lost down the monitoring tube. After multiple attempts to retrieve the logger it was determined that the monitoring tube was compromised to such a degree that any further attempt to retrieve the logger, deploy a new logger, or obtain water level measurements with an electric sounder posed the risk of more items being lost or stuck in the monitoring tube. Until the monitoring tube is replaced, Irrigation Well No. 3 will be monitored via airline and steel tape top-of-oil measurements only.
4. Based on the surveyed measuring point elevation at the Monitoring Well, static water-level elevations ranged from approximately 2587 to 2594 feet during 2020. Water levels in January 2021 were roughly 0.90 foot lower compared to January 2020.
5. The flow meter at Irrigation Well No. 3 stopped working after the 2019 irrigation season and was replaced between April 16 and May 21, 2020. A negligible but unmeasured amount of water was diverted from Irrigation Well No. 3 before the new flow meter was installed.
6. For the 2020 irrigation season, the totalizer on Irrigation Well No. 1 showed a total diversion volume of 727.7 acre-feet, the totalizer on Irrigation Well No. 2 showed a total diversion volume of 714.8 acre-feet, the totalizer on Irrigation Well No. 3 showed a total diversion volume of 789.3 acre-feet, and the totalizer on Irrigation Well No. 4 showed a total diversion volume of 219.1 acre-feet. The total combined diversion volume for the four irrigation wells in 2020 is then 2,451 acre-feet.
7. Total diversion volume in 2020 was approximately 695.2 acre-feet from Plant Well 1 (East) and 550.6 acre-feet from Plant Well 2 (West), which results in a combined total diversion volume of 1,246 acre-feet. These diversions are covered by permits 63-33207 and 63-34038.

Table of Contents

1. Background.....	1
1.1. Applicable Water Right Permits	1
1.1.1. Permits 63-32680 and 63-33296	1
1.1.2. Permit 63-33207	2
1.1.3. Permit 63-34038	2
1.1.4. Permit 63-34202	2
1.1.5. Permit 63-34221	2
1.2. Project Site.....	3
2. 2020 Activities.....	5
2.1. Water Level Monitoring	5
2.2. Flow Monitoring.....	7
3. Summary.....	9

List of Figures

Figure 1. Project Location Map	4
Figure 2. Water-level Hydrograph through January 28, 2021	7

List of Tables

Table 1. Authorized Points of Diversion and Well Locations.....	3
Table 2. Irrigation Wells Monthly Flow Monitoring (through 12/2/2020).....	8
Table 3. Plant Wells Monthly Flow Monitoring	9

Appendices

Appendix A: Water Right Reports and 63-32680/63-33296 Monitoring Plan

Appendix B: Well Driller's Reports for Production and Monitoring Wells

Appendix C: Water Level Data

1. BACKGROUND

1.1. Applicable Water Right Permits

Six water right permits utilize wells monitored under this monitoring program. Water right permit reports are provided as Appendix A and the permits are described below.

1.1.1. Permits 63-32680 and 63-33296

Kuna Cole-880, LLC, Azel Development Group, LLC, Boise Investment Group, LLC, Noelle Holdings, LLC, as tenants in common, applied for water right permit 63-32680 on May 22, 2007. The water right application sought 7.0 cfs for municipal use by 2250 homes as part of a proposed planned community. The application was amended on September 1, 2009 to seek 5.22 cfs for irrigation of 261 acres, and was subsequently assigned to Kirkwood Bank & Trust Company on September 22, 2011.

Kuna Cole-880, LLC, Azel Development Group, LLC, Boise Investment Group, LLC, Noelle Holdings, LLC, as tenants in common, applied for water right permit 63-33296 on November 6, 2009. The water right application sought 15.22 cfs for irrigation of 761 acres. The application was assigned to Kirkwood Bank & Trust Company on September 22, 2011 and was subsequently amended to seek 10.46 cfs for irrigation of 521 acres on January 12, 2012.

Both permit applications were protested by United Water Idaho and the Idaho Department of Corrections. A stipulation was entered between the protestants and the applicant to settle the protests. The stipulation included combined limits on diversion rates and irrigated acres, and the requirement for compliance with an approved monitoring plan (Appendix A). The monitoring plan requires monitoring of water levels and pumping volumes, and includes specific requirements for monitoring equipment at a dedicated monitoring well and at each supply well

The permits were approved by the Idaho Department of Water Resources (IDWR) on July 17, 2013. The two permits authorize irrigation of up to 784 acres within the property, with a combined maximum diversion rate of 11.76 cfs (5,278 gpm) and a maximum annual diversion volume of 3,528 acre-feet (4.5 acre feet per acre).

- Permit 63-32680 authorizes diversion of up to 5.22 cfs for irrigation of up to 261 acres within a 360-acre permissible located in Sections 11 and 14. The permit authorized construction of up to 2 wells located in Sections 11 and 14. Priority date is May 22, 2007.
- Permit 63-33296 authorizes diversion of up to 10.46 cfs for irrigation of up to 523 acres located within a 1022-acre permissible place of use. The permit authorized construction of up to 2 wells located in Sections 12 and 13. Priority date is November 6, 2009.

Kirkwood Bank assigned the permits to Ray and Susan Montierth on March 14th, 2014. Ray and Susan Montierth assigned the permits to J.R. Simplot Company on January 6, 2015. J.R. Simplot Company assigned the permits to CS Property Development LLC on April 6, 2016. Statements of completion for submitting proof of beneficial for 63-32680 and 63-33296 were submitted to the Idaho Department of Water Resources (IDWR) on June 20, 2018.

1.1.2. Permit 63-33207

Jim Hutchings applied for water right 63-33207 on May 15, 2009 and amended the permit on March 24, 2010. The permit application sought 3.0 cfs for irrigation of 200 acres. The permit was approved on September 25, 2013, and assigned to J.R. Simplot Company on March 26, 2015. The application was amended to change the use to industrial purposes, and was subsequently assigned to CS Property Development, LLC on April 6, 2016. There is a 700-acre-foot annual diversion limit associated with this permit. The permit requires monthly measurement of flow rate and volume, and requires monthly water-level measurements from one point of diversion authorized for this right.

1.1.3. Permit 63-34038

J.R. Simplot Company applied for water right 63-34038 on February 6, 2015 and amended the application on June 26, 2015. The amended permit application sought 3.2 cfs for irrigation of 160 acres and 4.0 cfs for industrial use, with a total diversion rate of 4.0 cfs. The permit was approved on October 26, 2015, and assigned to CS Property Development LLC on April 6, 2016. The permit requires monthly measurement of flow rate and volume, and requires monthly water-level measurements from all points of diversion authorized for this right.

1.1.4. Permit 63-34202

CS Property Development LLC applied for water right 63-34202 on February 29, 2016 seeking 4.96 cfs for irrigation of 248 acres. The permit was approved April 21, 2017 and requires monthly recording of flow rates diversion volumes, and water levels at the points of diversion. An annual report is not required, but a report will be needed for submission with proof of beneficial use.

1.1.5. Permit 63-34221

Ray and Susan Montierth applied for water right 63-33884 on December 6, 2013, then submitted an amended application on February 2, 2015 and a second amended application on March 16, 2015. A portion of 63-33884 was subsequently assigned to J.R. Simplot Company on September 28, 2015 and the assigned portion was renumbered to 63-34221. Permit 63-34221 sought 0.44 cfs for irrigation of up to 22 acres within a 147-acre permissible place of use. J.R. Simplot Company then assigned permit 63-34221 to CS Property Development LLC on May 26, 2016, who amended the permit on August 16, 2017. The permit requires monthly flow rate and diversion volume

records as well as installation of a permanent water-level transducer in one of the production wells. Water-level measurements are not required on a monthly basis, but manual water levels are to be taken approximately 30 days before and after irrigation season. No annual report is required, but a report will be needed for submission with proof of beneficial use.

1.2. Project Site

The project area is located approximately 7 miles southeast of Kuna, Idaho, in portions of Sections 11, 12, 13, 14, 23, and 24 of Township 1 North, Range 1 East, and Section 6 of Township 1 North, Range 2 East, Ada County, Idaho (Figure 1). Total area is approximately 1,900 acres.

The project site is accessed from South Cole Road. The northern portion of the property is bisected by the Union Pacific Railroad.

Two irrigation wells (Irrigation Wells 1 & 2), a monitoring well, and a drill water supply well were constructed in 2014. Two plant industrial water supply wells were constructed in 2015. One irrigation well (Irrigation Well 3) was constructed in 2016, and one irrigation well (Irrigation Well 4) was constructed in 2018.

Well locations and authorized diversion points are summarized in Table 1 and driller's reports for each well are provided in Appendix B.

Center pivot sprinklers were installed in the winter of 2014-15, and irrigation began in 2015. Additional pivot sprinklers were installed in 2017.

Table 1. Authorized Points of Diversion and Well Locations

Township	Range	Section	1/4-1/4	Well	Authorized Point of Diversion					
					63-34038	63-33207	63-32680	63-33296	63-34221	63-34202
1N	1E	11	SWSE		X	X	X			X
1N	1E	11	SESE		X	X	X			X
1N	1E	12	SWNW		X	X		X		X
1N	1E	12	SENE		X	X		X		X
1N	1E	13	NWNE		X	X		X		X
1N	1E	13	NWNW	Irr. Well 2	X	X		X		X
1N	1E	13	NESE		X	X		X		X
1N	1E	14	NENE	Irr Well 1	X	X	X			X
1N	1E	14	NWNE		X	X	X			X
1N	1E	14	SWNE		X	X	X			X
1N	1E	14	SENE		X	X	X			X
1N	1E	14	NESE	Irr. Well 3	X	X	X			X
1N	1E	14	NWSE		X	X	X			X
1N	2E	6	NWSW Lt6		X	X				
1N	2E	6	NWSW Lt6		X	X				
1N	2E	6	SWSW Lt7	Plant Well 1	X	X			X	
1N	2E	6	SWSW Lt7	Plant Well 2	X	X			X	
1N	2E	6	SESW	Irr. Well 4					X	




Figure 1. Project Location Map

2. 2020 ACTIVITIES

2.1. Water Level Monitoring

Water-level data from electronic transducers in the irrigation wells and Monitoring Well are required to be collected 3 times per year. The current schedule specifies that these events should occur between January 15th and 30th, March 1st and 15th, and November 15th and 30th of each year. During the data collection events, manual groundwater level measurements are also to be taken at each well with a non-stretch electric well sounder and flow meter readings should be recorded. Water level measurements are often difficult to obtain in irrigation wells due to a substantial amount of oil on top of the water column. When water-level measurements are not obtainable, top-of-oil measurements are taken instead. To maintain consistency, all depth measurements reported here for Irrigation Well Nos. 1, 2, 3, and 4 are to top of oil. Monthly airline water-level measurements and flow meter readings are also scheduled for each of the four irrigation wells and both of the plant wells.

Monitoring details for each well during the 2020 monitoring period are provided below.

Irrigation Well No. 1. The Van Essen Micro-Diver transducer in Irrigation Well No. 1 recorded data for all of 2020. Manual water-level measurements were collected in January, March, and November. Airline water-level measurements were recorded in every month. Water-level measurements indicate groundwater levels fluctuated approximately 29 feet during the irrigation season and had recovered to within 1 foot of pre-irrigation levels by January 2021.

Irrigation Well No. 2. The Solinst Levellogger transducer in Irrigation Well No. 2 recorded data for all of 2020. Manual water-level measurements were collected in January and November. Airline water-level measurements were recorded in every month. Water-level measurements indicate groundwater levels fluctuated approximately 30 feet during the irrigation season and had recovered to within 1.5 foot of pre-irrigation levels by the end of January 2021.

Irrigation Well No. 3. The Solinst Levellogger transducer in Irrigation Well No. 3 recorded data until it was lost in the well on November 16, 2020. Manual water-level measurements were collected in January and November. Airline water-level measurements were recorded in every month. Analysis of the transducer data appears to show that the transducer was hanging above the pumping water level for a portion of the irrigation season. However, airline water-level measurements could still be made and indicate groundwater levels fluctuated approximately 37 feet during the irrigation season. Water levels had recovered to within 2 feet of pre-irrigation levels by the end of January 2021.

The time series transducer data for Irrigation Well No. 3 has been adjusted to represent top-of-oil for data points after January 30, 2019. This was done to maintain consistency with the other irrigation well data collected as part of this monitoring

program and because top-of-oil hand measurements can be obtained on a more consistent basis. The resulting discontinuity can be seen in the Well No. 3 transducer data plotted in Figure 2.

Irrigation Well No. 4. Airline water-level measurements were recorded for Irrigation Well No. 4 during every month in 2020, although there is some uncertainty about the airline's setting depth and the water-level readings do not match anticipated groundwater levels. Since there is no access port in the well head, a sounder cannot be used to calibrate the airline and a transducer cannot be installed. Based on airline measurements, water levels fluctuated roughly 12.5 feet during the irrigation season and had recovered to within 7.5 feet of pre-irrigation water levels by the end of January 2021.

Monitoring Well. A non-stretch electric line well sounder was used to determine water levels in the Monitoring Well in January, March, April, and November 2020. The transducer collected data consistently throughout the year and was downloaded in January, March, and November. Transducer data shows approximately 7 feet of water-level fluctuation over the course of the irrigation season, and the groundwater had recovered to within 1.5 feet of pre-irrigation levels by the end of January 2021.

Plant Well No. 1. Plant Well No. 1 was completed in 2015, but had not been used for water supply until late spring of 2017 when the CS Beef Packers plant opened. A manual water-level measurement was collected on August 30, 2017 using a well sounder, but subsequent water-level measurements have been taken using an airline to minimize potential for contamination of this public drinking water system well. Airline measurements were taken every month in 2020. Plant Well No. 1 was pumping water during every 2020 site visit. The minimum depth to water during the year was 309.5 feet in February, and the maximum depth to water was 314 feet in August and September for a total fluctuation of 4.5 feet.

Plant Well No. 2. Plant Well No. 2 was also completed in 2015 and first used in 2017. The well is equipped with an airline which is calibrated against a non-stretch well sounder. A new Solinst Edge water-level transducer was installed in this well on October 4, 2018 to meet the monitoring requirements of water permit 63-34221. Plant Well No. 1 was not pumping water during any 2020 site visit. The transducer data shows three distinct water-level trendlines: one when the well is being pumped, one when Plant Well No. 1 is being pumped, and one when neither Plant Well is being pumped. Water levels fluctuated from roughly 288 to 293 feet with both wells off, from 290 to 297 feet with Plant Well No. 1 pumping, and 307 to 313 feet with Plant Well No. 2 pumping. Water levels for each case fluctuated by approximately 5 to 7 feet.

Water-level data through January 28, 2021 are provided electronically to IDWR and summarized below in Figure 2.




Figure 2. Water-level Hydrograph through January 28, 2021

2.2. Flow Monitoring

All four of the irrigation wells are equipped with electromagnetic flow meters. Irrigation pumping occurred between April 16 and November 16 in 2020. Total volume pumped was 2,451 acre-feet.

- The flow meters at Irrigation Well No. 1 and Irrigation Well No. 2 have complete totalizer readings for 2020.
- The flow meter at Irrigation Well No. 3 stopped working after the 2019 irrigation season and was replaced between April 16 and May 21, 2020. As a result, totalizer readings were not available during this time. A negligible but unmeasured amount of water was diverted from Irrigation Well No. 3 before the new flow meter was installed. The new flow meter gave a complete totalizer record for 2020 after it was installed on May 21.

- Table 2 summarizes the monthly instantaneous and totalized flow readings for the Irrigation Wells. Data from 2019 are given for comparison. Total diversion volume from the irrigation wells was approximately 480 acre-feet less in 2020 compared to 2019.

Table 2. Irrigation Wells Monthly Flow Monitoring (through 12/2/2020)

Date	Irrigation Well 1			Irrigation Well 2			Irrigation Well 3			Irrigation Well 4		
	Flow (gpm)	Totalizer (af)	AF since previous reading	Flow (gpm)	Totalizer (af)	AF since previous reading	Flow (gpm)	Totalizer (af)	AF since previous reading	Flow (gpm)	Totalizer (af)	AF since previous reading
1/30/2019	0	639.83	0.00	0	1745.65	0.00	0	1956.45	0.00	0.00	2.46	-0.55
2/28/2019	0	639.89	0.06	0	1745.65	0.00	---	---	---	---	---	---
3/15/2019	0	639.89	0.00	0	1745.65	0.00	0	1956.45	0.00	0.00	2.46	0.00
4/30/2019	0	639.89	0.00	1843	1751.07	5.42	0	1956.73	0.28	---	---	---
5/30/2019	0	917.90	278.01	0	1819.27	68.20	0	1967.22	10.50	0.00	1.49	-0.97
6/28/2019	2226	1040.35	122.45	1812.7	1952.41	133.14	2600	2166.00	198.78	---	---	---
7/30/2019	2235	1332.82	292.46	745	2163.40	210.99	2630	2421.92	255.92	708.00	271.08	269.59
8/30/2019	2328	1638.48	305.66	0	2278.60	115.20	2700	2774.05	352.13	753.00	330.95	59.87
9/30/2019	0	1728.70	90.23	836	2341.69	63.09	0	2844.01	69.96	0.00	346.62	15.68
10/31/2019	0	1728.70	0.00	0	2345.28	3.59	0	2844.11	0.10	0.00	356.00	9.37
11/26/2019	0	1728.70	0.00	0	2345.28	0.00	0	2844.11	0.00	0.00	357.23	1.23
12/30/2019	0	1728.70	0.00	0	2345.28	0.00	0	2844.11	0.00	0.00	357.23	0.00
2019 TOTAL		1088.87			599.63			887.66			355.00	
1/22/2020	0.00	1728.70	0.00	0.00	2345.28	0.00	0.00	2844.11	0.00	0.00	357.21	0.00
2/28/2020	0.00	1728.70	0.00	0.00	2345.28	0.00	0.00	2844.11	0.00	0.00	357.21	0.00
3/12/2020	0.00	1728.70	0.00	0.00	2345.28	0.00	0.00	2844.11	0.00	0.00	357.21	0.00
4/16/2020	0.00	1728.70	0.00	0.00	2345.28	0.00	0.00	2844.11	0.00	0.00	357.21	0.00
5/21/2020	0.00	1797.98	69.28	0.00	2446.86	101.58	0.00	0.01	(1)	0.00	387.98	30.76
6/17/2020	0.00	1889.41	91.43	0.00	2533.54	86.68	0.00	86.49	86.48	0.00	410.35	22.37
7/29/2020	2546.00	2105.76	216.35	2698.10	2722.19	188.65	0.00	309.90	223.41	681.00	456.91	46.57
8/21/2020	0.00	2256.13	150.37	1399.50	2842.27	120.08	2552.00	496.27	186.37	0.00	488.17	31.25
9/22/2020	0.00	2445.37	189.24	0.00	3001.28	159.01	0.00	760.63	264.36	0.00	559.01	70.84
10/15/2020	0.00	2456.43	11.06	1711.10	3051.32	50.04	0.00	773.52	12.89	0.00	566.53	7.52
11/16/2020	0.00	2456.43	0.00	0.00	3060.04	8.72	0.00	789.31	15.79	0.00	576.29	9.76
12/2/2020	0.00	2456.43	0.00	0.00	3060.06	0.02	0.00	789.31	0.00	0.00	576.29	0.00
2020 TOTAL		727.73			714.78			789.30			219.08	

(1) – Flow meter replaced. Negligible amount of flow unmeasured before replacement

2020 IRRIGATION TOTAL (af)	2451
-----------------------------------	-------------

The two Plant Wells were put into service in 2017 and both are equipped with electromagnetic flow meters. These wells are used year-round to supply water to the CS Beef Packers plant. From December 30, 2019 to December 2, 2020, Plant Well No. 1 provided 695 acre-feet to the plant and Plant Well No. 2 supplied 551 acre-feet for a combined volume of 1,246 acre-feet. Table 3 provides a summary of the recorded instantaneous and totalized flows from the Plant Wells. Data from 2019 is provided for comparison. Total diversion volume from the Plant Wells was approximately 74 acre-feet less in 2020 compared to 2019.

Table 3. Plant Wells Monthly Flow Monitoring

Date	Plant Well #1 (East)			Plant Well #2 (West)		
	Flow (gpm)	Totalizer (af)	AF since previous reading	Flow (gpm)	Totalizer (af)	AF since previous reading
1/30/2019	1117	1417.76	67.09	0	786.25	69.11
2/28/2019	1119	1472.51	54.75	0	832.31	46.06
3/15/2019	1120	1498.78	26.27	0	857.63	25.32
4/30/2019	1121	1583.13	84.34	0	932.85	75.22
5/30/2019	1120	1638.77	55.64	0	986.92	54.07
6/28/2019	1115	1698.21	59.45	0	1038.93	52.00
7/30/2019	0	1760.62	62.41	1093	1092.83	53.91
8/30/2019	1108	1818.93	58.31	0	1144.69	51.86
9/30/2019	1108	1875.70	56.77	0	1190.38	45.69
10/31/2019	1111	1936.47	60.76	0	1243.82	53.44
11/26/2019	1111	1985.57	49.10	0	1288.01	44.19
12/30/2019	1117	2044.49	58.92	0	1342.77	54.76
2019 TOTAL		693.81			625.63	
1/22/2020	1120	2085.52	41.04	0	1382.98	40.21
2/28/2020	1123	2154.60	69.08	0	1446.66	63.68
3/12/2020	1130	2178.12	23.51	0	1469.07	22.41
4/16/2020	1115	2245.81	67.69	0	1523.17	54.09
5/21/2020	1127	2317.05	71.24	0	1575.88	52.71
6/17/2020	1139	2372.53	55.48	0	1619.78	43.90
7/29/2020	1145	2471.96	99.43	0	1679.78	60.00
8/21/2020	1138	2525.38	53.42	0	1715.88	36.10
9/22/2020	1135	2590.84	65.46	0	1769.89	54.01
10/15/2020	1147	2643.91	53.07	0	1811.51	41.62
11/16/2020	1143	2711.72	67.81	0	1862.89	51.38
12/2/2020	1146	2739.69	27.97	0	1893.38	30.49
2020 TOTAL		695.20			550.61	

2020 PLANT WELL TOTAL (af)	1246
-----------------------------------	-------------

3. SUMMARY

1. Monitoring was conducted in 2020 as required for permits 63-32680, 63-33296, 63-33207, 63-34038, 63-34202, and 63-34221.
2. Pressure transducers collected water level data without incident from Plant Well No. 2, the Monitoring Well, Irrigation Well No. 1, and Irrigation Well No. 2 for all of 2020.
3. After downloading the pressure transducer data from Irrigation Well No. 3 on November 11, 2020 the transducer and cable were lost down the monitoring tube. Until the monitoring tube is replaced and the transducer can be retrieved, Irrigation Well No. 3 will be monitored via airline and steel tape top-of-oil measurements only.
4. An airline is installed in Irrigation Well No. 4, but no sounder access is available and the airline water-level measurements are suspect.

5. The 2020 water-level fluctuation in the Monitoring Well was approximately 7 feet. There was an approximate 0.90-foot water-level decrease between January 2020 and January 2021.
6. Irrigation diversions in 2020 occurred from Irrigation Wells No. 1, No. 2, No. 3, and No. 4. Total diversion volumes for the four wells was determined based on totalizer readings collected from each of the well sites. The combined total diversion volume was approximately 2,450.9 acre-feet in 2020 with 727.73 acre-feet from Well No. 1, 714.78 acre-feet from Well No. 2, 789.30 acre-feet from Well No. 3, and 219.08 acre-feet from Well No. 4.
7. Plant Wells #1 (East) and #2 (West) were used throughout 2020 to supply industrial water for the CS Beef Packers plant. The wells are equipped with airlines for water-level measurements and electromagnetic flow meters. Total combined diversion volume was approximately 1,245.8 acre-feet in 2020 based on readings from the flow meter totalizers.

Appendix A
Water Right Reports and
63-32680/63-33296 Monitoring Plan

Close

IDAHO DEPARTMENT OF WATER RESOURCES
Water Permit Report

2/5/2017

WATER RIGHT NO. 63-32680

<u>Owner Type</u>	<u>Name and Address</u>
Current Owner	CS PROPERTY DEVELOPMENT LLC PO BOX 27 BOISE, ID 83707 (208)336-2110
Original Owner	BOISE INVESTMENT GROUP LLC C/O NICK FERGIS 12515 COUNTY RD 22 CORTEZ, CO 81321 (602)980-8182
Original Owner	AZEL DEVELOPMENT GROUP LLC
Original Owner	KUNA COLE 880
Original Owner	NOELLE HOLDINGS LLC C/O NICK FERGIS BOISE INVESTMENT GROUP LLC 12515 COUNTY RD 22 CORTEZ, CO 81321 (602)980-8182
Security Interest	WELLS FARGO BANK FOOD & AGRIBUSINESS COMMERCIAL BANKING OFFICE 905 S FILLMORE STE 701 MAC T3005-072 AMARILLO, TX 79101 806-371-3769

Priority Date: 05/22/2007

Status: Active

<u>Source</u>	<u>Tributary</u>
GROUND WATER	

<u>Beneficial Use</u>	<u>From</u>	<u>To</u>	<u>Diversion Rate</u>	<u>Volume</u>
IRRIGATION	03/01	11/15	5.22 CFS	
Total Diversion			5.22 CFS	

Location of Point(s) of Diversion:

GROUND WATER	SWSE	Sec. 11	Township 01N	Range 01E	ADA County
GROUND WATER	SESE	Sec. 11	Township 01N	Range 01E	ADA County
GROUND WATER	NENE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWNE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	SWNE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	SENE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NESE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWSE	Sec. 14	Township 01N	Range 01E	ADA County

Place(s) of use:

Place of Use Legal Description: IRRIGATION ADA County

<u>Township</u>	<u>Range</u>	<u>Section</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>
01N	01E	11		SWSE	40		SESE	40						
		12		NENW	40		NWNW	40		SWNW	40		SENE	40
				NESW	40		NWSW	40		SWSW	40		SESE	40
				NWSE	40		SWSE	40		SESE	40			
		13		NENE	40		NWNE	40		SWNE	40		SENE	40
				NENW	40		NWNW	40						
				NESE	40									
		14		NENE	40		NWNE	40		SWNE	40		SENE	40
				SWNW	40		SENE	40						
				NESW	40		NWSW	40		SWSW	40		SESE	40
				NESE	40		NWSE	40		SWSE	40		SESE	40
		23		NENE	40		NWNE	40						
				NENW	40		NWNW	40						
		24		NENW	40		NWNW	40		SWNW	40		SENE	40

Total Acres: 1680

Conditions of Approval:

1. Rights 63-32680 and 63-33296, when combined, shall not exceed a total diversion rate of 11.76 cfs, a total annual maximum diversion volume of 3,528 af at the field headgate, and the irrigation of 784 acres.
2. This right is limited to the irrigation of 261 acres within the place of use described above in a single irrigation season.
Diversion and use of water in connection with this right is subject to a Monitoring Plan approved by the Department. In the event of a failure to comply with any component of the Monitoring Plan, after actual notice and a reasonable opportunity to cure, the right holder shall cease further diversions under the right until such noncompliance is remedied. Failure to comply with any approval condition, including the Monitoring Plan, shall be cause for the Department to cancel or revoke this right, or for an administrative or judicial action enjoining use of the right after actual notice and a reasonable opportunity to cure.
3. Proof of application of water to beneficial use shall be submitted no sooner than July 1, 2017 and no later than July 1, 2018.
4. No less than four (4) years of ground water monitoring data shall be submitted in connection with filing proof of beneficial use for this right. The right holder shall also submit a report from a qualified professional engineer, hydrologist, or hydrogeologist summarizing hydrogeologic data collected to fulfill the approved Monitoring Plan and the conditions of approval of this right. Submittal of a proof of beneficial use statement without the required report will not be accepted by the Department and may result in lapsing or cancellation of the permit.
5. Prior to submitting proof of beneficial use, the right holder shall not assign ownership of the permit to another individual, corporation, partnership, or association without prior notification to the Department.
6. Project construction shall commence within one year from the date of permit issuance and shall proceed diligently to completion unless it can be shown to the satisfaction of the Director of the Department of Water Resources that delays were due to circumstances over which the permit holder had no control.
7. 26A Diversion and use of water with a temperature greater than 85 degrees Fahrenheit is not authorized under his right.
8. Right holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code and applicable Well Construction Rules of the Department.
9. 046 The Director retains jurisdiction to require the right holder to provide purchased or leased natural flow or stored water to offset depletion of Lower Snake River flows if needed for salmon migration purposes. The amount of water required to be released into the Snake River or a tributary, if needed for this purpose, will be determined by the Director based upon the reduction in flow caused by the use of water pursuant to this permit.
10. 121 This right does not grant any right-of-way or easement across the land of another.
11. 004 This right when combined with all other rights shall provide no more than 0.02 cfs per acre nor more than 4.5 afa per acre at the field headgate for irrigation of the place of use.
12. R65 This right authorizes the construction of 2 supply wells as points of diversion.
13. The Department shall be notified prior to the installation and calibration of flow meters on all supply wells.
- 14.

Dates:

Proof Due Date: 07/01/2018

Proof Made Date:

Approved Date: 07/17/2013

Moratorium Expiration Date:

Enlargement Use Priority Date:

Enlargement Statute Priority Date:

Application Received Date: 09/07/2016

Protest Deadline Date: 01/02/2017

Number of Protests: 0

Field Exam Date::

Date Sent to State Off:

Date Received at State Off:

Other Information:

State or Federal:

Owner Name Connector:

Water District Number:

Generic Max Rate per Acre: 0.02

Generic Max Volume per Acre: 4.5

Swan Falls Trust or Nontrust:

Swan Falls Dismissed:

DLE Act Number:

Cary Act Number:

Mitigation Plan: False

Close

Close

IDAHO DEPARTMENT OF WATER RESOURCES
Water Application Report

2/5/2017

WATER RIGHT NO. 63-33207

<u>Owner Type</u>	<u>Name and Address</u>
Current Owner	CS PROPERTY DEVELOPMENT LLC PO BOX 27 BOISE, ID 83707 (208)336-2110
Original Owner	JIM HUTCHINGS 13690 S CLOVERDALE RD KUNA, ID 83634 (208)362-2963
Security Interest	WELLS FARGO BANK FOOD & AGRIBUSINESS COMMERCIAL BANKING OFFICE 905 S FILLMORE STE 701 MAC T3005-072 AMARILLO, TX 79101 806-371-3769

Priority Date: 03/24/2010

Status: Active

<u>Source</u>	<u>Tributary</u>
GROUND WATER	

<u>Beneficial Use</u>	<u>From</u>	<u>To</u>	<u>Diversion Rate</u>	<u>Volume</u>
INDUSTRIAL	01/01	12/31	3 CFS	
Total Diversion			3 CFS	

Location of Point(s) of Diversion:

GROUND WATER	SWSE	Sec. 11	Township 01N	Range 01E	ADA County
GROUND WATER	SESE	Sec. 11	Township 01N	Range 01E	ADA County
GROUND WATER	SWNW	Sec. 12	Township 01N	Range 01E	ADA County
GROUND WATER	SENE	Sec. 12	Township 01N	Range 01E	ADA County
GROUND WATER	NWNE	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NWNW	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NESE	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NENE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWNE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	SWNE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	SENE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NESE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWSE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWSW Lt 6	Sec. 06	Township 01N	Range 02E	ADA County
GROUND WATER	NWSW Lt 6	Sec. 06	Township 01N	Range 02E	ADA County
GROUND WATER	SWSW Lt 7	Sec. 06	Township 01N	Range 02E	ADA County
GROUND WATER	SWSW Lt 7	Sec. 06	Township 01N	Range 02E	ADA County

Place(s) of use:

Place of Use Legal Description: INDUSTRIAL ADA County

<u>Township</u>	<u>Range</u>	<u>Section</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>
01N	01E	11		SWSE			SESE							
		12		NENW			NWNW			SWNW			SENE	
				NESW			NWSW			SWSW			SESW	
				NWSE			SWSE			SESE				
		13		NENE			NWNE			SWNE			SENE	
				NENW			NWNW							
				NESE										
		14		NENE			NWNE			SWNE			SENE	
				NESE			NWSE							
		23		NENE			NWNE							
				NENW			NWNW							
		24		NENW			NWNW			SWNW			SENE	
	02E	6		NESW	6		NWSW	7		SWSW			SESW	
				NWSE			SWSE							

Conditions of Approval:

1. 004 This right does not grant any right-of-way or easement across the land of another.
The right holder shall install a measuring device acceptable to the Department at the points of diversion authorized under this right. The measuring device shall be capable of displaying diversion flow rate and totalized volume measurement. The right holder shall record the flow rate and volume measurements monthly for any calendar year in which water is diverted and used in connection with this right until notified by the Department. The records shall be made available to the Department upon request.
- 2.
3. 073 Diversion and use of water with a temperature greater than 85 degrees Fahrenheit is not authorized under this right.
4. Use of water under this permit shall not exceed an annual diversion volume of 700 acre-feet. If the Department determines, based on credible evidence, measurement reports, area data, or otherwise, there is a substantial likelihood that diversion and use of groundwater under this right is causing material injury to any senior water right(s), the Department may issue an order to the right holder to show cause why existing diversions should not be reduced under the permit, forego additional diversions, or provide adequate mitigation to remedy any such material injury. Any senior water user alleging material injury may petition the Department to commence a show cause hearing, and the Department shall conduct a hearing.
5. The Director retains jurisdiction to require the right holder to provide purchased or leased natural flow or stored water to offset depletion of Lower Snake River flows if needed for salmon migration purposes. The amount of water required to be released into the Snake River or a tributary, if needed for this purpose, will be determined by the Director based upon the reduction in flow caused by the use of water pursuant to this permit.
6. 121 Industrial use is for a meat processing and packing facility.
One point of diversion (well) authorized for this right shall include a measuring device or other suitable method to allow measurement of the static water level in the well. Water level measurements shall be made monthly throughout the year from the beginning of the diversion and use of water in connection with this right until notified by the Department. The records shall be made available to the Department upon request.
- 7.
8. The right holder shall install or construct a straight length of conduit or ditch suitable for installation of a device for measuring the entire flow of water being diverted in connection with this right. If the right holder uses conduit, the straight length of conduit shall be at least fifteen times the diameter of the conduit and shall be above ground or otherwise easily accessible.
9. 196 Right holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code and applicable Well Construction Rules of the Department.
10. 046 Failure of the right holder to comply with any condition of approval is cause for the Director to cancel this permit.
11. 069 Project construction shall commence within one year from the date of permit issuance and shall proceed diligently to completion unless it can be shown to the satisfaction of the Director of the Department of Water Resources that delays were due to circumstances over which the permit holder had no control.
12. 26A Proof of application of water to beneficial use shall be submitted no sooner than October 1, 2017, and no later than October 1, 2018. A report with no less than 4 years of diversion measurement and aquifer level water monitoring data shall be submitted in connection with filing proof of beneficial use. Submittal of a proof of beneficial use statement without the required report will not be accepted by the Department and may result in cancellation of the permit.
- 13.

Dates:

Date Application Received: 09/07/2016

Date Application Denied:

Last Date of Beneficial Use:

Extension End Date:

Protest Deadline Date: 1/2/2017

Number of Protests: 0

Enlargement Use Priority Date:

Enlargement Statute Priority Date:

Other Information:

State or Federal:

Owner Name Connector:

Water District Number:

Generic Max Rate per Acre:

Generic Max Volume per Acre:

Application Type: Amendment

Applicant Remarks: The proposed change is to increase the size of the place of industrial use.

Other Water Rights:

Time to Complete Works:

Transfer Affected Description:

Transfer Affected Contracts:

Old Transfer Number:

Transfer Reason:

Transfer Return Flows:

Swan Falls Trust or Nontrust:

Swan Falls Dismissed:

DLE Act Number:

Cary Act Number:

Mitigation Plan: False

Close

IDAHO DEPARTMENT OF WATER RESOURCES
Water Permit Report

2/5/2017

WATER RIGHT NO. 63-33296

<u>Owner Type</u>	<u>Name and Address</u>
Current Owner	CS PROPERTY DEVELOPMENT LLC PO BOX 27 BOISE, ID 83707 (208)336-2110
Original Owner	BOISE INVESTMENT GROUP LLC C/O NICK FERGIS 12515 COUNTY RD 22 CORTEZ, CO 81321 (602)980-8182
Original Owner	KUNA COLE 880 LLC C/O NICK FERGIS BOISE INVESTMENT GROUP 12515 COUNTY RD 22 CORTEZ, CO 81321 (208)383-4140
Original Owner	AZEL DEVELOPMENT GROUP LLC
Original Owner	NOELLE HOLDINGS LLC C/O NICK FERGIS BOISE INVESTMENT GROUP LLC 12515 COUNTY RD 22 CORTEZ, CO 81321 (602)980-8182
Security Interest	WELLS FARGO BANK FOOD & AGRIBUSINESS COMMERCIAL BANKING OFFICE 905 S FILLMORE STE 701 MAC T3005-072 AMARILLO, TX 79101 806-371-3769

Priority Date: 11/06/2009

Status: Active

<u>Source</u>	<u>Tributary</u>
GROUND WATER	

<u>Beneficial Use</u>	<u>From</u>	<u>To</u>	<u>Diversion Rate</u>	<u>Volume</u>
IRRIGATION	03/01	11/15	10.46 CFS	
Total Diversion			10.46 CFS	

Location of Point(s) of Diversion:

GROUND WATER	SWNW	Sec. 12	Township 01N	Range 01E	ADA County
GROUND WATER	SENW	Sec. 12	Township 01N	Range 01E	ADA County
GROUND WATER	NWNE	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NWNW	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NESE	Sec. 13	Township 01N	Range 01E	ADA County

Place(s) of use:

Place of Use Legal Description: IRRIGATION ADA County

<u>Township</u>	<u>Range</u>	<u>Section</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>
01N	01E	11		SWSE	40		SESE	40						
		12		NENW	40		NWNW	40		SWNW	40		SENW	40
				NESW	40		NWSW	40		SWSW	40		SESW	40
				NWSE	40		SWSE	40		SESE	40			
		13		NENE	40		NWNE	40		SWNE	40		SENE	40
				NENW	40		NWNW	40						
				NESE	40									
		14		NENE	40		NWNE	40		SWNE	40		SENE	40
				SWNW	40		SENW	40						
				NESW	40		NWSW	40		SWSW	40		SESW	40
				NESE	40		NWSE	40		SWSE	40		SESE	40
		23		NENE	40		NWNE	40						
				NENW	40		NWNW	40						
		24		NENW	40		NWNW	40		SWNW	40		SENW	40

Total Acres: 1680

Conditions of Approval:

1. Rights 63-32680 and 63-33296, when combined, shall not exceed a total diversion rate of 11.76 cfs, a total annual maximum diversion volume of 3,528 af at the field headgate, and the irrigation of 784 acres.
2. This right is limited to the irrigation of 523 acres within the place of use described above in a single irrigation season.
Diversion and use of water in connection with this right is subject to a Monitoring Plan approved by the Department. In the event of a failure to comply with any component of the Monitoring Plan, after actual notice and a reasonable opportunity to cure, the right holder shall cease further diversions under the right until such noncompliance is remedied. Failure to comply with any approval condition, including the Monitoring Plan, shall be cause for the Department to cancel or revoke this right, or for an administrative or judicial action enjoining use of the right after actual notice and a reasonable opportunity to cure.
3. Proof of application of water to beneficial use shall be submitted no sooner than July 1, 2017 and no later than July 1, 2018.
No less than four (4) years of ground water monitoring data shall be submitted in connection with filing proof of beneficial use for this right. The right holder shall also submit a report from a qualified professional engineer, hydrologist, or hydrogeologist summarizing hydrogeologic data collected to fulfill the approved Monitoring Plan and the conditions of approval of this right. Submittal of a proof of beneficial use statement without the required report will not be accepted by the Department and may result in lapsing or cancellation of the permit.
4. Prior to submitting proof of beneficial use, the right holder shall not assign ownership of the permit to another individual, corporation, partnership, or association without prior notification to the Department.
5. Project construction shall commence within one year from the date of permit issuance and shall proceed diligently to completion unless it can be shown to the satisfaction of the Director of the Department of Water Resources that delays were due to circumstances over which the permit holder had no control.
6. 26A Diversion and use of water with a temperature greater than 85 degrees Fahrenheit is not authorized under his right.
7. 046 Right holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code and applicable Well Construction Rules of the Department.
The Director retains jurisdiction to require the right holder to provide purchased or leased natural flow or stored water to offset depletion of Lower Snake River flows if needed for salmon migration purposes. The amount of water required to be released into the Snake River or a tributary, if needed for this purpose, will be determined by the Director based upon the reduction in flow caused by the use of water pursuant to this permit.
8. 121 This right does not grant any right-of-way or easement across the land of another.
9. 004 This right when combined with all other rights shall provide no more than 0.02 cfs per acre nor more than 4.5 afa per acre at the field headgate for irrigation of the place of use.
10. R65 This right authorizes the construction of 2 supply wells as points of diversion.
11. The Department shall be notified prior to the installation and calibration of flow meters on all supply wells.
12. 004
13. R65
14. This right authorizes the construction of 2 supply wells as points of diversion.

Dates:

Proof Due Date: 07/01/2018

Proof Made Date:

Approved Date: 07/17/2013

Moratorium Expiration Date:

Enlargement Use Priority Date:

Enlargement Statute Priority Date:

Application Received Date: 09/07/2016

Protest Deadline Date: 01/02/2017

Number of Protests: 0

Field Exam Date::

Date Sent to State Off:

Date Received at State Off:

Other Information:

State or Federal:

Owner Name Connector:

Water District Number:

Generic Max Rate per Acre: 0.02

Generic Max Volume per Acre: 4.5

Swan Falls Trust or Nontrust:

Swan Falls Dismissed:

DLE Act Number:

Cary Act Number:

Mitigation Plan: False

Close

Close

IDAHO DEPARTMENT OF WATER RESOURCES
Water Permit Report

2/5/2017

WATER RIGHT NO. 63-34038

<u>Owner Type</u>	<u>Name and Address</u>
Current Owner	CS PROPERTY DEVELOPMENT LLC PO BOX 27 BOISE, ID 83707 (208)336-2110
Original Owner	J R SIMPLOT COMPANY PO BOX 27 BOISE, ID 83707 (208)336-2110
Security Interest	WELLS FARGO BANK FOOD & AGRIBUSINESS COMMERCIAL BANKING OFFICE 905 S FILLMORE STE 701 MAC T3005-072 AMARILLO, TX 79101 806-371-3769

Priority Date: 06/26/2015

Status: Active

<u>Source</u>	<u>Tributary</u>
GROUND WATER	

<u>Beneficial Use</u>	<u>From</u>	<u>To</u>	<u>Diversion Rate</u>	<u>Volume</u>
IRRIGATION	03/01	11/15	3.2 CFS	
INDUSTRIAL	01/01	12/31	4 CFS	
Total Diversion			4 CFS	

Location of Point(s) of Diversion:

GROUND WATER	SWSE	Sec. 11	Township 01N	Range 01E	ADA County
GROUND WATER	SESE	Sec. 11	Township 01N	Range 01E	ADA County
GROUND WATER	SWNW	Sec. 12	Township 01N	Range 01E	ADA County
GROUND WATER	SENE	Sec. 12	Township 01N	Range 01E	ADA County
GROUND WATER	NWNE	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NWNW	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NESE	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NENE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWNE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	SWNE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	SENE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NESE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWSE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWSW Lt 6	Sec. 06	Township 01N	Range 02E	ADA County
GROUND WATER	NWSW Lt 6	Sec. 06	Township 01N	Range 02E	ADA County
GROUND WATER	SWSW Lt 7	Sec. 06	Township 01N	Range 02E	ADA County
GROUND WATER	SWSW Lt 7	Sec. 06	Township 01N	Range 02E	ADA County

INDUSTRIAL Use:

Number of other uses: meat process & packing

Place(s) of use:

Place of Use Legal Description: IRRIGATION ADA County

<u>Township</u>	<u>Range</u>	<u>Section</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>
01N	01E	11		SWSE	40		SESE	40						
		12		NENW	40		NWNW	40		SWNW	40		SENE	40
				NESW	40		NWSW	40		SWSW	40		SESW	40
				NWSE	40		SWSE	40		SESE	40			
		13		NENE	40		NWNE	40		SWNE	40		SENE	40
				NENW	40		NWNW	40						
				NESE	40									
		14		NENE	40		NWNE	40		SWNE	40		SENE	40
				SWNW	40		SENE	40						
				NESW	40		NWSW	40		SWSW	40		SESW	40
				NESE	40		NWSE	40		SWSE	40		SESE	40
		23		NENE	40		NWNE	40						
				NENW	40		NWNW	40						
		24		NENW	40		NWNW	40		SWNW	40		SENE	40

Place of Use Legal Description: INDUSTRIAL ADA County

<u>Township</u>	<u>Range</u>	<u>Section</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>
01N	01E	11		SWSE			SESE							
		12		NENW			NWNW			SWNW			SENE	
				NESW			NWSW			SWSW			SESE	
				NWSE			SWSE			SESE				
		13		NENE			NWNE			SWNE			SENE	
				NENW			NWNW			SWNW			SENE	
				NESW			NWSW			SWSW			SESE	
				NESE			SWSE			SESE				
		14		NENE			NWNE			SWNE			SENE	
				NESE			NWSE							
		23		NENE			NWNE							
				NENW			NWNW							
		24		NENW			NWNW			SWNW			SENE	
	02E	6		NESW			SESW							
				NWSE			SWSE							

Total Acres: 1680

Conditions of Approval:

1. 26A Project construction shall commence within one year from the date of permit issuance and shall proceed diligently to completion unless it can be shown to the satisfaction of the Director of the Department of Water Resources that delays were due to circumstances over which the permit holder had no control.
2. Each point of diversion (well) authorized for this right shall include a measuring device or other suitable method to allow measurement of the static water level in the well. Water level measurements shall be made monthly throughout the year from the beginning of the diversion and use of water in connection with this right until notified by the Department. The records shall be made available to the Department upon request.
3. 196 The right holder shall install or construct a straight length of conduit or ditch suitable for installation of a device for measuring the entire flow of water being diverted in connection with this right. If the right holder uses conduit, the straight length of conduit shall be at least fifteen times the diameter of the conduit and shall be above ground or otherwise easily accessible.
4. The right holder shall install a measuring device acceptable to the Department at each point of diversion authorized under this right. The measuring device shall be capable of displaying diversion flow rate and totalized volume measurement. The right holder shall record the flow rate and volume measurements monthly for any calendar year in which water is diverted and used in connection with this right until notified by the Department. The records shall be made available to the Department upon request.

5. 073 Diversion and use of water with a temperature greater than 85 degrees Fahrenheit is not authorized under this right.
6. If the Department determines based on credible evidence, measurement reports, area data or otherwise that diversion and use of ground water under this right is causing material injury to any senior water right(s), the Department may order the diversion reduced, the diversion curtailed, or the right holder to provide adequate mitigation to remedy the injury.
7. Prior to submitting proof of beneficial use, the right holder shall not assign ownership of the permit to another individual, corporation, partnership, or association without prior approval of the Department.
8. Proof of beneficial use may not be submitted until one month prior to the deadline to submit proof of beneficial use set forth in these conditions; provided, however, if less than four (4) years of ground water monitoring data have been collected while beneficial use authorized under this permit has occurred, then an extension of time for up to five additional years shall be requested by the permit holder. The permit holder shall submit a report from a qualified professional engineer, hydrologist, or hydrogeologist summarizing hydrogeologic data collected to fulfill the conditions of approval of this permit. Submittal of a proof of beneficial use statement without the required data and report will not be accepted by the Department and may result in lapse of the permit.
9. 046 Right holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code and applicable Well Construction Rules of the Department.
10. R65 This right when combined with all other rights shall provide no more than 0.02 cfs per acre nor more than 4.5 afa per acre at the field headgate for irrigation of the place of use.
11. 121 The Director retains jurisdiction to require the right holder to provide purchased or leased natural flow or stored water to offset depletion of Lower Snake River flows if needed for salmon migration purposes. The amount of water required to be released into the Snake River or a tributary, if needed for this purpose, will be determined by the Director based upon the reduction in flow caused by the use of water pursuant to this permit.
12. 069 Failure of the right holder to comply with any condition of approval is cause for the Director to cancel this permit.

Dates:

Proof Due Date: 11/01/2020

Proof Made Date:

Approved Date: 10/26/2015

Moratorium Expiration Date:

Enlargement Use Priority Date:

Enlargement Statute Priority Date:

Application Received Date: 09/07/2016

Protest Deadline Date: 01/02/2017

Number of Protests: 0

Field Exam Date::

Date Sent to State Off:

Date Received at State Off:

Other Information:

State or Federal:

Owner Name Connector:
Water District Number:
Generic Max Rate per Acre: 0.02
Generic Max Volume per Acre: 4.5
Swan Falls Trust or Nontrust:
Swan Falls Dismissed:
DLE Act Number:
Cary Act Number:
Mitigation Plan: False

WATER RIGHT REPORT

4/25/2019
 IDAHO DEPARTMENT OF WATER RESOURCES
 Water Permit Report
 WATER RIGHT NO. 63-34202

<u>Owner Type</u>	<u>Name and Address</u>
Current Owner	CS PROPERTY DEVELOPMENT LLC PO BOX 27 BOISE, ID 83707 2083362110
Security Interest	WELLS FARGO BANK FOOD & AGRIBUSINESS COMMERCIAL BANKING OFFICE 905 S FILLMORE STE 701 MAC T3005-072 AMARILLO, TX 79101 8063713769

Priority Date: 02/29/2016
 Status: Active

<u>Source</u>	<u>Tributary</u>
GROUND WATER	

<u>Beneficial Use</u>	<u>From</u>	<u>To</u>	<u>Diversion Rate</u>	<u>Volume</u>
IRRIGATION	03/01	11/01	4.96 CFS	
Total Diversion			4.96 CFS	

Location of Point(s) of Diversion:

GROUND WATER	SWSE	Sec. 11	Township 01N	Range 01E	ADA County
GROUND WATER	SESE	Sec. 11	Township 01N	Range 01E	ADA County
GROUND WATER	SWNW	Sec. 12	Township 01N	Range 01E	ADA County
GROUND WATER	SENE	Sec. 12	Township 01N	Range 01E	ADA County
GROUND WATER	NWNE	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NWNW	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NESE	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NENE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWNE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	SWNE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	SENE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NESE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWSE	Sec. 14	Township 01N	Range 01E	ADA County

Place(s) of use:

Place of Use Legal Description: IRRIGATION ADA County

Township	Range	Section	Lot	Tract	Acres	Lot	Tract	Acres	Lot	Tract	Acres	Lot	Tract	Acres
01N	01E	14		SWSE	31		SESE	31						
		23		NENE	31		NWNE	31						
		24		NENW	31		NWNW	31		SWNW	31		SENW	31

Total Acres: 248

Conditions of Approval:

1. Each point of diversion (well) authorized for this right shall include a measuring device or other suitable method to allow measurement of the static water level in the well. Water level measurements shall be made monthly throughout the year from the beginning of the diversion and use of water in connection with this right until notified by the Department. The records shall be made available to the Department upon request.
2. The right holder shall install a measuring device acceptable to the Department at each point of diversion authorized under this right. The measuring device shall be capable of displaying diversion flow rate and totalized volume measurement. The right holder shall record the flow rate and volume measurements monthly for any calendar year in which water is diverted and used in connection with this right until notified by the Department. The records shall be made available to the Department upon request.
3. 073 Diversion and use of water with a temperature greater than 85 degrees Fahrenheit is not authorized under this right.
4. Proof of beneficial use may not be submitted until one month prior to the deadline to submit proof of beneficial use set forth in these conditions; provided, however, if less than four (4) years of ground water monitoring data have been collected while beneficial use authorized under this permit has occurred, then an extension of time for up to five additional years shall be requested by the permit holder. The permit holder shall submit a report from a qualified professional engineer, hydrologist, or hydrogeologist summarizing hydrogeologic data collected to fulfill the conditions of approval of this permit. Submittal of a proof of beneficial use statement without the required data and report will not be accepted by the Department and may result in lapse of the permit.
5. R65 This right when combined with all other rights shall provide no more than 0.02 cfs per acre nor more than 4.5 afa per acre at the field headgate for irrigation of the place of use.
6. 004 This right does not grant any right-of-way or easement across the land of another.
7. 26A Project construction shall commence within one year from the date of permit issuance and shall proceed diligently to completion unless it can be shown to the satisfaction of the Director of the Department of Water Resources that delays were due to circumstances over which the permit holder had no control.
8. 121 The Director retains jurisdiction to require the right holder to provide purchased or leased natural flow or stored water to offset depletion of Lower Snake River flows if needed for salmon migration purposes. The amount of water required to be released into the Snake River or a tributary, if needed for this purpose, will be determined by the Director based upon the reduction in flow caused by the use of water pursuant to this permit.
9. 046 Right holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code and applicable Well Construction Rules of the Department.
10. 069 Failure of the right holder to comply with any condition of approval is cause for the Director to cancel this permit.

Dates:

Proof Due Date: 05/01/2022

Proof Made Date:

Approved Date: 04/21/2017
Moratorium Expiration Date:
Enlargement Use Priority Date:
Enlargement Statute Priority Date:
Application Received Date: 02/29/2016
Protest Deadline Date: 02/20/2017
Number of Protests: 1
Field Exam Date:
Date Sent to State Off:
Date Received at State Off:

Other Information:

State or Federal:
Owner Name Connector:
Water District Number: TBD
Generic Max Rate per Acre: 0.02
Generic Max Volume per Acre: 4.5
Swan Falls Trust or Nontrust:
Swan Falls Dismissed:
DLE Act Number:
Cary Act Number:
Mitigation Plan: False

WATER RIGHT REPORT

4/25/2019
 IDAHO DEPARTMENT OF WATER RESOURCES
 Water Permit Report
 WATER RIGHT NO. 63-34221

<u>Owner Type</u>	<u>Name and Address</u>
Current Owner	CS PROPERTY DEVELOPMENT LLC PO BOX 27 BOISE, ID 83707 2083362110
Security Interest	WELLS FARGO BANK FOOD & AGRIBUSINESS COMMERCIAL BANKING OFFICE 905 S FILLMORE STE 701 MAC T3005-072 AMARILLO, TX 79101 8063713769

Priority Date: 02/02/2015
 Status: Active

<u>Source</u>	<u>Tributary</u>
GROUND WATER	

<u>Beneficial Use</u>	<u>From</u>	<u>To</u>	<u>Diversion Rate</u>	<u>Volume</u>
IRRIGATION	03/01	11/15	0.44 CFS	
Total Diversion			0.44 CFS	

Location of Point(s) of Diversion:

GROUND WATER	SWSW Lt 7	Sec. 06	Township 01N	Range 02E	ADA County
GROUND WATER	SWSW Lt 7	Sec. 06	Township 01N	Range 02E	ADA County
GROUND WATER	SESW	Sec. 06	Township 01N	Range 02E	ADA County

IRRIGATION Use:
 Acre Limit: 22
 Place(s) of use:
 Place of Use Legal Description: IRRIGATION ADA County

<u>Township</u>	<u>Range</u>	<u>Section</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>
01N	02E	6		NESW	40		SESW	40						
				NWSE	34		SWSE	33						

Total Acres: 147
 Conditions of Approval:

- X27 This right is limited to the irrigation of 22 acres within the authorized place of use in a single irrigation season.

2. R65 This right when combined with all other rights shall provide no more than 0.02 cfs per acre nor more than 4.5 afa per acre at the field headgate for irrigation of the place of use.
3. Each authorized point of diversion constructed after issuance of this permit shall contain a dedicated sounding tube extending from above ground level to near the top of the pump bowls to facilitate groundwater-level measurements.
4. The right holder shall install a measuring device acceptable to the Department at each point of diversion authorized under this right. The measuring device shall be capable of displaying diversion flow rate and totalized volume measurement. The right holder shall record the flow rate and volume measurements monthly for any calendar year in which water is diverted and used in connection with this right until notified otherwise by the Department. The records shall be made available to the Department upon request.
5. Each point of diversion (well) authorized for this right shall include a measuring device or other suitable method to allow measurement of the static water level in the well. Water level measurements shall be made approximately thirty (30) days before the start and approximately thirty (30) days following cessation of seasonal irrigation from the beginning of the diversion and use of water in connection with this right until notified by the Department. The records shall be made available to the Department upon request.
6. At least one production well shall be equipped with a non-vented submersible pressure transducer/digital data logger suspended by stainless steel cable of a known length and at a depth that will allow the pressure transducer to always remain submerged. The submersible pressure transducer(s) shall be housed in a sounding tube. The data logger shall be set to collect two (2) water level and temperature readings per day on a year-round basis.
7. 020 The diversion and use of water described in this right may be subject to additional conditions and limitations agreed to by the protestant and the right holder under a separate agreement to which the Department is not a party. Because the Department is not a party, the Department is not responsible for enforcement of any aspect of the agreement not specifically addressed in other conditions herein. Enforcement of those portions of the agreement not specifically addressed in other conditions shall be the responsibility of the protestant and the water right holder.
8. Proof of beneficial use may not be submitted until one month prior to the deadline to submit proof of beneficial use set forth in these conditions; provided, however, if less than four (4) years of ground water monitoring data have been collected while beneficial use authorized under this permit has occurred, then an extension of time for up to five additional years shall be requested by the permit holder. The permit holder shall submit a report from a qualified professional engineer, hydrologist, or hydrogeologist summarizing hydrogeologic data collected to fulfill the conditions of approval of this permit. The report shall include raw water level measurements, barometrically corrected water level data, and diversion data. Submittal of a proof of beneficial use statement without the required data and report will not be accepted by the Department and may result in lapse of the permit.
9. 069 Failure of the right holder to comply with any condition of approval is cause for the Director to cancel this permit.
10. 046 Right holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code and applicable Well Construction Rules of the Department.
11. 004 This right does not grant any right-of-way or easement across the land of another.

12. 26A Project construction shall commence within one year from the date of permit issuance and shall proceed diligently to completion unless it can be shown to the satisfaction of the Director of the Department of Water Resources that delays were due to circumstances over which the permit holder had no control.
13. 121 The Director retains jurisdiction to require the right holder to provide purchased or leased natural flow or stored water to offset depletion of Lower Snake River flows if needed for salmon migration purposes. The amount of water required to be released into the Snake River or a tributary, if needed for this purpose, will be determined by the Director based upon the reduction in flow caused by the use of water pursuant to this permit.

Dates:

Proof Due Date: 10/01/2021

Proof Made Date:

Approved Date: 09/20/2016

Moratorium Expiration Date:

Enlargement Use Priority Date:

Enlargement Statute Priority Date:

Application Received Date: 08/16/2017

Protest Deadline Date: 03/05/2018

Number of Protests: 0

Field Exam Date::

Date Sent to State Off:

Date Received at State Off:

Other Information:

State or Federal:

Owner Name Connector:

Water District Number: TBD

Generic Max Rate per Acre: 0.02

Generic Max Volume per Acre: 4.5

Swan Falls Trust or Nontrust:

Swan Falls Dismissed:

DLE Act Number:

Cary Act Number:

Mitigation Plan: False

Monitoring, Recording, and Reporting Plan Applications for Permit 63-32680 and 63-33296

Submitted by


Kirkwood Bank & Trust Company
2911 N. 14th Street, Suite 101
Bismarck, North Dakota 58503



Pete Jahner, Senior Vice President
Kirkwood Bank & Trust Company

Prepared by

SPF Water Engineering, LLC
300 East Mallard, Suite 350
Boise, Idaho 83706
(208) 383-4140



April 19, 2013



SPF WATER
ENGINEERING

Exhibit A

1. INTRODUCTION

This document presents a monitoring plan for Applications 63-32680 and 63-33296. The monitoring plan is based on (1) anticipated Idaho Department of Water Resources (IDWR) requirements and (2) a Stipulation and Joined Motion to Approve Conditions, signed by the Kirkwood Bank & Trust Company ("Applicant," "Kirkwood," or "Right Holder"), United Water Idaho Inc. ("United Water"), and Idaho Department of Correction ("IDOC"), completed on December 13, 2012.

Application for Permit 63-32680 and amended Application for Permit 63-33296 request authorization to divert 11.76 cfs of ground water for the irrigation of 784 acres in Township 1 North, Range 1 East. The places of use (POUs) under both applications are overlapping, and are located between Cloverdale and Cole roads approximately eight miles southeast of the City of Kuna (Figures 1 and 2).

2. MONITORING PLAN

This monitoring plan includes the construction of a dedicated monitoring well, discharge measurements from production wells, and groundwater-level measurements in production and monitoring wells. Specifically, the monitoring plan consists of the following:

Supply Wells

1. Each new Supply Well¹ shall contain a dedicated sounding tube extending from above ground level to near the top of the pump bowls to facilitate groundwater-level measurements.
2. An airline tube of known length extending from above ground level to near the top of the pump bowls shall be installed in all supply wells with oil-lubricated pump shafts.
3. Each Supply Well will be pump-tested in connection with the completion of its construction. The water-level drawdown versus time, discharge, and water-level recovery data from these pump test will be submitted to IDWR, United Water, and IDOC as part of the monitoring data reported for the year in which the well was constructed.

¹ There are no known existing supply wells within the place of use for applications 63-32680 and 63-33296.

4. Each authorized point of diversion ("Supply Well") constructed under approved Permits 63-32680 and 63-33296 will be equipped with an electromagnetic induction totalizing flowmeter ("mag meter") of a type approved by IDWR (an approved list is attached as Attachment A).

Monitoring Well

5. One dedicated, non-pumped monitoring well ("Monitoring Well") will be drilled and constructed for electronic and manual water level measurements. Siting criteria include proximity to protestants' wells, access, and distance from supply wells and irrigated areas.
6. The monitoring well shall be constructed within one year of application approval and permit issuance, and shall be constructed prior to the drilling and construction of supply wells.
7. The Monitoring Well shall be constructed with at least 10 feet of stainless steel well screen placed at the same depth as the anticipated uppermost portion of the screened interval of the first Supply Well constructed under these rights (e.g., 100 feet or more below the water table).
8. The Monitoring Well will be developed by pumping (using a temporary electric pump or by air-lifting) to confirm that the wells capable of producing water and therefore suitable for monitoring water level changes. In the event that the monitoring well is not suitable for monitoring, the well will be decommissioned and a new monitoring well will be drilled at a similar location.

Monitoring Period

9. Manual and digital measurements in the Monitoring Well and in the Supply Wells will commence no later than the start of withdrawals under the rights and shall continue for a period of 10 years following the beginning of withdrawals under the approved permits/licensed rights (the "Monitoring Period").
10. No less than 4 years of groundwater monitoring data shall be submitted in connection with filing proof of beneficial use for this right.
11. After the Monitoring Period has ended, the Right Holder shall continue to submit flowmeter data from Supply Wells on an annual basis as set forth above, but shall have no further obligations with respect to other data submissions listed in this Monitoring Plan.

Instrumentation

12. Each Supply Well will be equipped with a non-vented submersible pressure transducer/digital datalogger.
13. The Monitoring Well shall initially be equipped with two non-vented submersible pressure transducers/dataloggers. Following the completion of the first supply well, one of these pressure transducers/dataloggers will be moved to the first

supply well, leaving one pressure transducer/datalogger installed in the monitoring well.

14. Submersible pressure transducers will be suspended by a stainless steel cable of known length and at a depth that will allow the pressure transducers to always remain submerged. Submersible pressure transducers in the Supply Wells will be housed in the sounding tube.
15. The Monitoring Well will be equipped with a digital barometric datalogger inside the well head.

Manual Measurements

16. Manual groundwater-level measurements from all Supply Wells and the Monitoring Well will be obtained using chalked-steel tapes and/or non-stretch electric well sounders.
17. All manual water level measurements will be recorded and reported to 0.01 foot. All electronic water-level measurements (e.g., those recorded by pressure transducers/dataloggers) will be recorded and reported to 0.5 foot or less. The height of the measurement datum above the land surface or floor level of known elevation will be documented for each manual measurement.
18. After the Monitoring Period, the Right Holder or successor shall provide the Department reasonable access to the Monitoring Well for continued electronic and manual water level measurements at the Department's discretion.
19. The Right Holder shall be responsible for the groundwater measuring, monitoring, and reporting obligations set forth in this Monitoring Plan, and for keeping the instrument and equipment maintained in working order so that the Monitoring Plan's data submitting and reporting goals are fulfilled during the Monitoring Period.

Measurement and Data-Retrieval Frequency

20. All electronic dataloggers will be set to measure and record pressures at 6-hour intervals.
21. Manual on-site water-level measurements in each Supply Well and in the Monitoring Well will be taken at a minimum frequency of 3 times per year. Measurements will be taken according to the following schedule (the "Measuring Times"):
 - a. Between November 15 and November 30;
 - b. Between January 15 and January 31; and
 - c. Between March 1 and March 15.
22. Data from the electronic dataloggers and flow meters will be retrieved at the same time that manual measurements are taken.

Reporting

23. The Right Holder shall prepare and submit to IDWR an annual interpretive report ("Monitoring Report") by April 30 of each year during the Monitoring Period². The Monitoring Report shall include the following:
- a. Water right numbers (e.g., permits 63-32680 and 63-33296);
 - b. Legal description of the points of diversion;
 - c. Well locations (established by GPS coordinates) and well-head elevation referenced to sea-level datum;
 - d. Monthly volumes diverted per supply well during irrigation season;
 - e. Total volume diverted during the reporting period;
 - f. Description of physical changes to the diversion works that have been made during the reporting period;
 - g. Depth of water in any well prior to commencement of pumping (based on measurement taken between March 1 and March 15 as outlined above);
 - h. Depth of water during the pumping (presented as hydrographs for each monitored well, along with a discussion of notable changes in water levels and an explanation of any other factors or anomalies that may have influenced the measured water levels);
 - i. All raw submersible transducer and barometric data, flow meter readings, and manual measurements in Microsoft Excel format.
24. Hydrographs in the Monitoring Report shall be based on digital pressure-transducer data that have been corrected for barometric pressure changes.
25. All hydrographs in the Monitoring Report will show both groundwater-level data derived from digital recorders and manual measurements.
26. A copy of each annual Monitoring Report prepared during the monitoring period shall be sent to United Water and IDOC.
27. The Monitoring Report shall be prepared by a registered professional engineer or registered professional geologist.

² Idaho Code § 42-701(5) gives the Director of IDWR general authority to require monitoring and reporting of diversions and groundwater levels. Such monitoring could be requested by IDWR following the Monitoring Period.




Figure 1. Location map.




Figure 2. Place of Use and Points of Diversion for Amended Application 63-32680 and Application 63-33296.

Attachment A: IDWR Approved Flow Meter List

Idaho Department of Water Resources List of Approved Closed Conduit Flow meters

The table below lists flow meters **that have been tested and approved by IDWR for use in closed conduit measurement applications where the installation configuration and application meet manufacturer's requirements for the selected model.** These approved flow meters were subject to testing requirements outlined by IDWR and conducted by staff from Utah State's NIST¹ traceable lab in Logan Utah and performed at or above IDWR minimum acceptable standards for accuracy when installed in piping distances that met or exceeded minimum straight run piping requirements specified by IDWR. The approved list is current as of this printing, but may change as additional models and manufacturers undergo testing and approval. The current version of these standards, including this list, is posted on the IDWR Internet site at the following URL:

[http://www.idwr.idaho.gov/WaterManagement/WaterMeasurement/PDFs/Approved flow meter list.pdf](http://www.idwr.idaho.gov/WaterManagement/WaterMeasurement/PDFs/Approved_flow_meter_list.pdf)

Note that not all models are appropriate for every application. Pipe size, available straight pipe lengths, water chemistry, pressure, velocity, environmental exposure, and power requirements are among the factors affecting whether a given meter will perform for a given application. Prior to selecting a meter, consult the manufacturer's installation requirements to assure they can be met.

Manufacturer	Model/Specifications	Type	IDWR-accepted Pipe Applications (Nominal Pipe Size)
Siemens	CLAMP-ON ULTRASONIC -SITRANS FUS 1010 w/ HIGH PRECISION TRANSDUCERS	Clamp-On Ultrasonic	>12"
Siemens	SITRANS F M MAGFLO MAG 5100W w/ 5000 converter	Full profile Electro-Magnetic	1" to 78"
Siemens	SITRANS FM, MAGFLO 8000, model 7ME6880	Full profile Electro-Magnetic	1" to 48"
Fuji	Time Delta C w/ 1MHz transducers	Clamp-On Ultrasonic	>12"
Seametrics	AG 2000	Full profile Electro-Magnetic	4" to 10"
GE Panametrics	AT868 w/ 1MHz transducers	Clamp-On Ultrasonic or Wetted Transducer	>12"
McCrometer	Ultra Mag w/ M-Series Converter	Full profile Electro-Magnetic	2" to 48"

(continued on next page)

¹ NIST - National Institute of Standards and Technology.

Manufacturer	Model/Specifications	Type	IDWR-accepted Pipe Applications (Nominal Pipe Size)
Badger	M2000 Amplifier w/ M2000 Detector	Full profile Electro-Magnetic	1/4" to 54"
Khrone	Enviromag 2000 w/ Optiflux 2000 F/G	Full profile Electro-Magnetic	3/8" to 80"
Rosemount	8705 w/ 8732E transmitter	Full profile Electro-Magnetic	1/2" to 36"
Burkert	8054/8055 w/ Magflow transmitter	Full profile Electro-Magnetic	1" to 80"
Sparling	Tiger Mag W/FM6561051110 Converter	Full profile Electro-Magnetic	3/8" to 48"
Sensus	IPerl	Full profile Electro-Magnetic	5/8"-1"

(Approved Flow Meter list continued)

Appendix B
**Well Driller's Reports for Production and
Monitoring Wells**

Plant Well 1

RECEIVED

Form 238-7
6/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

OCT 06 2015

WATER RESOURCES
WESTERN REGION

03

1. WELL TAG NO. D 0069003

Drilling Permit No. 9168748 - 874825

Water right or injection well # _____

2. OWNER: JR Simplot Co.

Name _____

Address P.O. Box 27

City Boise State Idaho Zip 83707

3. WELL LOCATION:

Twp. 1 North or South Rge. 2 East or West

Sec. 6 NW 1/4 SW 1/4 SE 1/4

Gov't Lot _____ County ADA

Lat. 43 ° 26.841 (Deg. and Decimal minutes)

Long. 116 ° 16.380 (Deg. and Decimal minutes)

Address of Well Site S. Cole Rd. 1/4 mile North of Barker

City Kuna

Lot _____ Blk. _____ Sub. Name _____

4. USE:

Domestic Municipal Monitor Irrigation Thermal Injection
 Other _____

5. TYPE OF WORK:

New well Replacement well Modify existing well
 Abandonment Other _____

6. DRILL METHOD:

Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
Neat cement	188ft	0	9 yd3	pumped
Neat cement	315ft	0	11 yd3	pumped

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
20"	0	188	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
14"	+2	395	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:

Perforations Y N Method _____

Manufactured screen Y N Type Joston

Method of installation set in

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
395	455	30	60ft	14"	ss	.375

Length of Headpipe _____ Length of Tailpipe _____

Packer Y N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method
6-9	315	455	9850lbs	trimmie

11. FLOWING ARTESIAN:

Flowing Artesian? Y N Artesian Pressure (PSIG) _____

Describe control device plat

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 315 Static water level (ft) 294

Water temp. (°F) 83 Bottom hole temp. (°F) 83

Describe access port _____

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Test method:			
			Pump	Bailer	Air	Flowing artesian
43.1	1520	7.7 hrs	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
24	0	2	top soil		
24	2	8	sandy dirt and gravel		
24	8	30	hard black lava		
24	30	38	broken soft black lava		
24	38	44	hard black lava		
24	44	48	soft red lava		
24	48	55	hard black lava		
24	55	77	soft black lava		
24	77	95	hard black lava		
24	95	105	soft black lava		
24	105	135	hard black lava		
24	135	145	soft black lava		
24	145	155	red cinders		
24	155	162	hard black lava		
24	162	177	hard black lava		
19	177	312	large gravel and sand		
19	312	315	rock and clay		
19	315	320	sand and gravel		
19	320	325	rock and clay		
19	325	402	sand and gravel		
19	402	425	white clay		
19	425	448	sand and gravel		
19	448	460	brown clay with gravel		
19	460	465	sand and gravel		
19	465	471	brown clay and little rock		
19	471	477	sand and gravel		
19	477	490	brown clay and rock		
19	490	523	big gravel and sand		
19	523	531	sand and gravel		
19	531	543	gravel and sand with clay		
19	543	555	sandstone		
19	555	560	gravel and sand		

Completed Depth (Measurable) 455
Date Started: 6/1/2015 Date Completed: 9/16/2015

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling Co. No. 560
*Principal Driller: [Signature] Date 9-22-15

*Driller _____ Date _____

*Operator II _____ Date _____

Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0069003

Drilling Permit No. _____
Water right or injection well # _____

2. OWNER: J R Simplot Co.

Name _____
Address P.O. Box 27
City Boise State ID Zip 83707

3. WELL LOCATION:

Twp. 1 North or South Rge. 2 East or West
Sec. 6 NW 1/4 SW 1/4 _____

Gov't Lot _____ County Ada

Lat. _____ (Deg. and Decimal minutes)

Long. _____ (Deg. and Decimal minutes)

Address of Well Site S Cole Rd. 1/4 mile north of center

City Kuna

Lot _____ Blk. _____ Sub. Name _____

4. USE:

Domestic Municipal Monitor Irrigation Thermal Injection
 Other _____

5. TYPE OF WORK:

New well Replacement well Modify existing well
 Abandonment Other _____

6. DRILL METHOD:

Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
Neat cement	188	0	13 Yards	Pumped
Neat cement	315	0	10 1/2 Yards	Pumped

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing Liner	Threaded	Welded
30"	0	188	.375	Steel casing	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
14"	42	395	.375	Steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:

Perforations Y N Method _____

Manufactured screen Y N Type Alloy Screen

Method of installation Set in

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
395	455		60'		Stainless	.375

Length of Headpipe _____ Length of Tailpipe _____

Packer Y N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method
6-9	315	455	9,850 lbs	Tremie

11. FLOWING ARTESIAN:

Flowing Artesian? Y N Artesian Pressure (PSIG) _____

Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 315 Static water level (ft) 294

Water temp. (°F) 83 Bottom hole temp. (°F) 83

Describe access port _____

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
33	200	60	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
24"	0	2	TOP SOIL		
"	2	8	Sandy dirt + Gravel		
"	8	30	Hard black lava		
"	30	38	Broken / soft black lava		
"	38	44	Hard black lava		
"	44	48	soft red lava		
"	48	55	Hard black lava		
"	55	77	soft black lava		
"	77	95	Hard black lava		
"	95	105	soft black lava		
"	105	135	Hard black lava		
"	135	145	soft black lava		
"	145	155	red cinders		
"	155	160	Hard black lava		
"	160	177	Hard black lava		
19"	177	312	Big Gravels + sand		
"	312	315	Rock + clay		
"	315	320	sand + Gravel		
"	320	325	rock + clay		
"	325	402	Sand + Gravel		
"	402	425	White Clay		
"	425	448	Sand + Gravel		
"	448	460	brn clay with gravel		
"	460	465	Sand + Gravel		
"	465	471	Brn clay + little rock		
"	471	477	Sand + Gravel		
"	477	490	Brn clay + rock		
"	490	523	Big Gravels + sand		
"	523	531	Sand + Gravel		
"	531	543	Gravels and little clay		
"	543	555	sandstone		
"	555	560	Gravel + Sand		

Completed Depth (Measurable): 455

Date Started: 7-1-15 Date Completed: 8-30-15

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling and Pump #560

*Principal Driller Shawn Mikelsen Date 9-28-15

*Driller Shawn Mikelsen Date 9-28-15

*Operator II _____ Date _____

Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.

RECEIVED

OCT 02 2015

Plant Well 2

Form 238-7
6/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0070211

Drilling Permit No. 970455-876512

Water right or injection well # 63-33207

2. OWNER: JR Simplot Company

Name _____

Address PO Box 27

City Boise State Idaho Zip 83707

3. WELL LOCATION:

Twp. 1 North or South Rge. 2 East or West

Sec. 6 1/4 SW 1/4 SW 1/4

Gov't Lot 7 County _____

Lat. 43 ° 26.845 (Deg. and Decimal minutes)

Long. -116 ° 16.419 (Deg. and Decimal minutes)

Address of Well Site 150' East of south cole rd

1075' North of Barker Rd City Near Kuna

(Give at least name of road + Distance to Road or Landmark)

Lot. _____ Blk. _____ Sub. Name _____

4. USE:

Domestic Municipal Monitor Irrigation Thermal Injection

Other Industrial

5. TYPE OF WORK:

New well Replacement well Modify existing well

Abandonment Other _____

6. DRILL METHOD:

Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
Neat cement	188	0	9yd3	pumped
Neat cement	315	0	11yd3	pumped

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
26	0	11	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
20	+1	176	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
14	+1	395	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:

Perforations Y N Method _____

Manufactured screen Y N Type _____

Method of installation _____

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
395	455	40	60	14	ss	.375

Length of Headpipe _____ Length of Tailpipe _____

Packer Y N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method
silica sand	320	455	8400lbs	trimmie

11. FLOWING ARTESIAN:

Flowing Artesian? Y N Artesian Pressure (PSIG) _____

Describe control device plat

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 290 Static water level (ft) 289

Water temp. (°F) 82 Bottom hole temp. (°F) 82

Describe access port _____

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
338	2190	4hrs	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
32	0	1	top soil		X
32	1	11	cleachy basalt		
26	11	93	weathered basalt		
26	93	97	red cinders		
26	97	124	black basalt		
26	124	128	red cinders		
26	128	176	hard black basalt		
20	176	186	sand and gravel		
20	186	211	gravel and basalt boulders		
20	211	255	sand and gravel boulders		
20	255	266	cemented gravel		
20	266	290	sand and gravel		X
20	290	367	clay		
20	367	376	sand		
20	376	460	pea gravel and silty sand		

Completed Depth (Measurable): 455

Date Started: 9/10/2015 Date Completed: 9/30/2015

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling Co. No. 560

*Principal Driller: [Signature] Date 9-30-15

*Driller _____ Date _____

*Operator II _____ Date _____

Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.

Drill Water Supply Well (Monitoring)

Form 238-7
6/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0066263

Drilling Permit No. _____
Water right or injection well # _____

2. OWNER

Name Ray Montierth
Address 825 Hartland Dr
City Nampa State ID Zip 83686

3. WELL LOCATION:

Twp. 1 North or South Rge. 1 East or West
Sec. 14 1/4 SE 1/4 NE 1/4
Gov't Lot _____ County ADA

Lat. 34 ° 25.612 (Deg. and Decimal minutes)
Long. 116 ° 17.845 (Deg. and Decimal minutes)
Address of Well Site Cross tracks on Cole heading south first right 1 mile left 1/2 mile left 1/4 mile City Kuna

Lot _____ Blk. _____ Sub. Name _____

4. USE:

Domestic Municipal Monitor Irrigation Thermal Injection
 Other

5. TYPE OF WORK check all that apply (Replacement etc.)

New Well Replacement well Modify existing well
 Abandonment Other

6. DRILL METHOD:

Air Rotary Mud Rotary Cable Other

7. SEALING PROCEDURES

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
Bentonite	0	38	950lbs	Pour

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
6	+2	38	.230	Steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:

Perforations Y N Method _____
Manufactured screen Y N Type _____
Method of installation _____

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule

Length of Headpipe _____ Length of Tailpipe _____

Packer Y N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method
na	na	na	na na	na

11. FLOWING ARTESIAN:

Flowing Artesian? Y N Artesian Pressure (PSIG) _____
Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 265 Static water level (ft) 230
Water temp. (°F) 56 Bottom hole temp. (°F) _____
Describe access port Cap

Well test:	Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Test method:			Flowing artesian
				Pump	Bailer	Air	
	35	20	1HR	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
10	0	2	Top Soil		x
10	2	8	Sandy Clay		x
10	8	15	Brown Clay		x
10	15	34	Brown Sandy Clay		x
10	34	38	Broken up Lava		x
6	38	54	Lava		x
6	54	57	Red Lava		x
6	57	81	Black Lava		x
6	81	83	Red Lava		x
6	83	101	Black Lava		x
6	101	104	Brown Lava		x
6	104	232	Brown Lava		x
6	232	245	Fractured Lava		x
6	245	258	Lava		x
6	258	265	Brown Lava		x
6	265	270	Corse Sand	x	
6	270	280	Lava		x
6	280		Gravel	x	

Completed Depth (Measurable) 270
Date: Started 04/17/2014 Completed 4/20/2014

14. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.
Company Name Treasure Valley Drilling Co. No. 560
*Principal Driller _____ Date _____
*Driller _____ Date _____
*Operator II _____ Date _____
Operator I _____ Date _____
* Signature of Principal Driller and rig operator are required.

Irrigation Well 1

Form 238-7
6/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0066300

Drilling Permit No. 965586-871645
Water right or injection well # 63-32680

2. OWNER

Name Ray Montierth
Address 825 Heartland Dr.
City Nampa State Id Zip 83686

3. WELL LOCATION:

Twp. 1 North or South Rge. 1 East or West
Sec. 14 sw 1/4 ne 1/4 ne 1/4
10 acres 40 acres 160 acres

Gov't Lot _____ County Ada
Lat. 43 ° 25.967 (Deg. and Decimal minutes)
Long. 116 ° 16.803 (Deg. and Decimal minutes)
Address of Well Site 1 mi. w. of S.Cole Rd 1 mi. S. of railroad ROW
City Kuna

(Give at least name of road + Distance to Road or Landmark)

Lot. _____ Blk. _____ Sub. Name _____

4. USE:

Domestic Municipal Monitor Irrigation Thermal Injection
 Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

New Well Replacement well Modify existing well
 Abandonment Other _____

6. DRILL METHOD:

Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
<u>3/4 bentonite</u>	<u>0</u>	<u>38</u>	<u>23000 lbs</u>	<u>pour</u>
<u>cement</u>	<u>150</u>	<u>300</u>	<u>43 ft 3</u>	<u>trimmed</u>

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
<u>26</u>	<u>0</u>	<u>38</u>	<u>.375</u>	<u>steel</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<u>20</u>	<u>0</u>	<u>149</u>	<u>.375</u>	<u>steel</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<u>16</u>	<u>1</u>	<u>150</u>	<u>.250</u>	<u>steel</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:

Perforations Y N Method _____
Manufactured screen Y N Type johnson
Method of installation set in

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
<u>330</u>	<u>430</u>	<u>.40</u>	<u>100</u>	<u>16</u>	<u>ss</u>	<u>.375</u>
<u>440</u>	<u>540</u>	<u>.40</u>	<u>100</u>	<u>16</u>	<u>ss</u>	<u>.375</u>

Length of Headpipe na Length of Tailpipe _____
Packer Y N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method
<u>silico sand</u>	<u>80</u>	<u>540</u>	<u>23000 lbs</u>	<u>pour</u>

11. FLOWING ARTESIAN:

Flowing Artesian? Y N Artesian Pressure (PSIG) _____
Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) _____ Static water level (ft) _____
Water temp. (°F) 70 Bottom hole temp. (°F) 70
Describe access port flat plat

Well test:

Test method:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
<u>23</u>	<u>3300</u>	<u>20 hr</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water Quality test or comments:

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water Y	N
30	0	2	top soil		X
30	2	8	sandy clay		X
30	8	17	brown clay		X
30	17	35	brown sandy clay		X
30	35	38	broken up lava		X
25	38	73	lava		X
25	73	85	brown lava		X
25	85	130	lava		X
25	130	140	brown lava		X
25	140	153	fractured lava		X
25	153	175	red lava		X
25	175	186	brown lava		X
25	186	200	fractured lava		X
25	200	255	lava		X
25	255	266	brown lava		X
25	266	270	sand	X	
25	270	273	brown clay		X
25	273	278	lava		X
25	278	284	gravel	X	
20	284	291	corse sand	X	
20	291	305	brown clay		X
20	305	317	brown sand	X	
20	317	335	brown clay		X
20	335	356	gravel	X	
20	356	360	brown clay		X
20	360	368	corse sand	X	
20	368	373	medium sand	X	
20	373	378	brown clay		X
20	378	381	brown sand	X	
20	381	389	gravel	X	
20	389	410	corse sand and gravel	X	
20	410	430	medium sand	X	

Completed Depth (Measurable)

Date: Started 4-16-14 Completed _____

14. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling Co. No. 560

*Principal Driller Monte Post Date 6-27-14

*Driller [Signature] Date 7-31-14

*Operator II _____ Date _____

Operator I Jeremy Bullock Date [Signature]

*Signature of Principal Driller and rig operator are required.

JUL 03 2014

Irrigation Well 2

10f2

Form 238-7
6/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0067448

Drilling Permit No. 967343-873402

Water right or injection well # _____

2. OWNER:

Name Ray Montierth

Address 825 Hartland

City Nampa State ID Zip 83686

3. WELL LOCATION:

Twp. 1 North or South Rge. 1 East or West

Sec. 13 1/4 NW 1/4 NW 1/4

Gov't Lot _____ County ADA

Lat. 43 25.608 (Deg. and Decimal minutes)

Long. 116 17.611 (Deg. and Decimal minutes)

Address of Well Site S. Cole

City Kuna

(Give at least name of road - Distance to Road or Landmark)

Lot _____ Blk. _____ Sub. Name _____

4. USE:

Domestic Municipal Monitor Irrigation Thermal Injection

Other _____

5. TYPE OF WORK:

New well Replacement well Modify existing well

Abandonment Other _____

6. DRILL METHOD:

Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
3/4 bentonite	0	39	4000 lbs	pour
concrete	270	300	3 1/2 yd	pumped

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
26	0	39	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
20	1	284	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
16	270	350	.250	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
16	510	535	.250	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:

Perforations Y N Method _____

Manufactured screen Y N Type Alloy

Method of installation set in

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
350	510	.35	160	16	ss	.98
535	575	.35	40	16	ss	.98

Length of Headpipe 80 Length of Tailpipe _____

Packer Y N Type double wing k-packer

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method
6/9 silica sand	305	575	16500 lbs	pour

11. FLOWING ARTESIAN:

Flowing Artesian? Y N Artesian Pressure (PSIG) _____

Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 293 Static water level (ft) 236

Water temp. (°F) 70 Bottom hole temp. (°F) 70

Describe access port flat plate

Well test:	Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Test method:			
				Pump	Bailer	Air	Flowing artesian
	22	2980	6 hr	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
30	0	3	top soil		x
30	3	27	sandy clay		x
30	27	35	coarse sand		x
30	35	39	red clay		x
24	39	65	hard lava		x
24	65	69	red cinders		x
24	69	82	gray lava		x
24	82	87	red broken up lava		x
24	87	99	black lava		x
24	99	101	broken up lava		x
24	101	107	gray lava		x
24	107	111	red lava		x
24	111	122	gray lava		x
24	122	151	gray broken up lava		x
24	151	158	black broken up lava		x
24	158	170	brown and red cinders		x
24	170	223	gray lava		x
24	223	230	broken up lava		x
24	230	258	black lava		x
24	258	267	coarse sand		x
24	267	286	brown lava		x
24	286	293	broken up lava		x
24	293	305	red cinders	x	
20	305	320	brown clay and red cinders		x
20	320	335	brown clay		x
20	335	370	gravel	x	
20	370	373	brown clay		x
20	373	429	coarse sand and gravel	x	
20	429	431	brown clay		x
20	431	435	coarse sand	x	
20	435	438	brown clay		x
20	438	445	gravel	x	

RECEIVED
JAN 05 2015
WATER RESOURCES
WESTERN REGION

Completed Depth (Measurable): 575

Date Started: 9-14-14 Date Completed: 11-21-14

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling Co. No. 560

*Principal Driller Monte Post Date 11-30-14

*Driller Jeremy Bullock Date 11-30-14

*Operator II _____ Date _____

Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.

63

2 of 2

Form 238-7
6/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0067448

Drilling Permit No. 9167343-873402
Water right or injection well # _____

2. OWNER:

Name Ray Montierth
Address 825 Hartland
City Nampa State Id Zip 83686

3. WELL LOCATION:

Twp. 1 North or South Rge. 1 East or West
Sec. 13 10 acres 1/4 40 acres NW 1/4 180 acres NW 1/4
Gov't Lot _____ County ada
Lat. 43 ° 25.608 (Deg. and Decimal minutes)
Long. 116 ° 17.611 (Deg. and Decimal minutes)
Address of Well Site S.Cole
City Kuna

(Give at least name of road + Distance to Road or Landmark)
Lot _____ Blk. _____ Sub. Name _____

4. USE:

Domestic Municipal Monitor Irrigation Thermal Injection
 Other _____

5. TYPE OF WORK:

New well Replacement well Modify existing well
 Abandonment Other _____

6. DRILL METHOD:

Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
3/4 bentonite	270	250	750 lbs	pour

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:

Perforations Y N Method _____
Manufactured screen Y N Type _____
Method of installation _____

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule

Length of Headpipe _____ Length of Tailpipe _____
Packer Y N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method

11. FLOWING ARTESIAN:

Flowing Artesian? Y N Artesian Pressure (PSIG) _____
Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 293 Static water level (ft) 236
Water temp. (°F) 70 Bottom hole temp. (°F) 70
Describe access port flat plate

Well test:			Test method:			
Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
22	2980	6 hr	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
20	445	447	brown clay		x
20	447	496	gravel	x	
20	496	511	brown clay		x
20	511	513	gravel	x	
20	513	516	brown clay		x
20	516	519	gravel	x	
20	519	536	brown clay		x
20	536	540	gravel	x	
20	540	547	brown clay		x
20	547	549	gravel	x	
20	549	551	brown clay		x
20	551	569	gravel	x	
20	569	575	brown clay		x

RECEIVED

JAN 05 2015

WATER RESOURCES
WESTERN REGION

Completed Depth (Measurable): 575

Date Started: 9-14-14 Date Completed: 11-21-14

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling Co. No. 560

*Principal Driller Monte Kost Date 11-30-14

*Driller Jeremy Balllock Date 11-30-14

*Operator II _____ Date _____

Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.

Irrigation Well 3

Form 238-7
6/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D0071844

Drilling Permit No. _____
Water right or injection well # 63-33207-3403863-32680

2. OWNER:
Name JR Simplot Company
Address PO box 27
City Boise State Idaho Zip 83707

3. WELL LOCATION:
Twp. 1 North or South Rge. 1 East or West
Sec. 14 1/4 NE 1/4 SE 1/4

Gov't Lot _____ County Ada
Lat. 43 ° 25.154 (Deg. and Decimal minutes)
Long. 116 ° 17.628 (Deg. and Decimal minutes)
Address of Well Site West of S. Cole rd. south of train tracks
City Kuna

(Give at least name of road + Distance to Road or Landmark)

Lot. _____ Blk. _____ Sub. Name _____

4. USE:
 Domestic Municipal Monitor Irrigation Thermal Injection
 Other _____

5. TYPE OF WORK:
 New well Replacement well Modify existing well
 Abandonment Other _____

6. DRILL METHOD:
 Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
3/8 chip	0	53	15800	overbore
3/8 chip	280	265	500lbs	overbore

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
26	0	53	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
20	+1	280	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
16	257	345	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:
Perforations Y N Method _____
Manufactured screen Y N Type Johnson S.S.
Method of installation set in

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
545	345	.040		16"	S.S.	.250

Length of Headpipe _____ Length of Tailpipe _____
Packer Y N Type Double k 257-255

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method
6-9 silica	545	273	8700lbs	overbore

11. FLOWING ARTESIAN:
Flowing Artesian? Y N Artesian Pressure (PSIG) _____
Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:
Depth first water encountered (ft) 280 Static water level (ft) 270
Water temp. (°F) 74 Bottom hole temp. (°F) _____
Describe access port flat plate

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
60'	3425		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
36	0	4	top soil		
36	4	12	sand		
36	42	53	brown clay		
25	53	78	black basalt		
25	78	86	red cinder		
25	86	192	black basalt		
25	192	204	brown clay		
25	204	227	sand and brown clay		
25	227	259	fractured basalt		
25	259	271	brown sand		
25	271	280	basalt		X
19	280	303	basalt		X
19	303	309	fractured basalt		X
19	309	318	baked brown clay		
19	318	324	sticky brown clay		
19	324	326	brown silt		X
19	326	329	sticky brown clay		
19	329	334	fine brown sand and silt		
19	334	347	sticky brown clay		
19	347	349	fine brown sand		X
19	349	357	sticky brown clay		
19	357	368	cemented sand		X
19	368	370	sticky brown clay		
19	370	394	brown sand and pea gravel		X
19	394	417	sticky brown clay		
19	417	436	brown sand		X
19	436	444	sticky brown clay		
19	444	529	brown sand with small clay seams		
19	529	555	sticky tan clay		

Completed Depth (Measurable): 545
Date Started: 5-15-16 Date Completed: 6-30-16

14. DRILLER'S CERTIFICATION:
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.
Company Name Treasure Valley Drilling Co. No. 560
*Principal Driller _____ Date Jul 26, 2016
*Driller [Signature] Date Jul 26, 2016
*Operator II [Signature] Date Jul 27 2016
Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.

63

Irrigation Well 4

Form 238-7
6/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D W 77537

Drilling Permit No. 885283

Water right or injection well # _____

2. OWNER: Simplet hand & live stock

Name _____

Address 1301 Hwy 67

City Grandview State ID Zip 83629

3. WELL LOCATION:

Twp. 1 North or South Rge. 2 East or West

Sec. 6 SE 1/4 50 1/4 1/4

Gov't Lot _____ County Ada

Lat. 43 ° 26.694 (Deg. and Decimal minutes)

Long. 116 ° 16.113 (Deg. and Decimal minutes)

Address of Well Site South Lake & Barber Rd

(Give at least name of road + Distance to Road or Landmark) City _____

Lot. _____ Blk. _____ Sub. Name _____

4. USE:

Domestic Municipal Monitor Irrigation Thermal Injection
 Other _____

5. TYPE OF WORK:

New well Replacement well Modify existing well
 Abandonment Other _____

6. DRILL METHOD:

Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft)	Placement method/procedure
Med. Ch. p	18	1600	1600	Poured
Granular	0	193	7600	Poured

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
20"	+1	18	.250	Steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
16"	+1	193	.250	Steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
12"	+1	450	.250	Steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:

Perforations Y N Method _____

Manufactured screen Y N Type Johnson

Method of installation Set in

From (ft)	To (ft)	Slot size	Number	Diameter (nominal)	Material	Gauge or Schedule
450	530	.020		12"	S.S.	.250

Length of Headpipe _____ Length of Tailpipe _____

Packer Y N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft)	Placement method
6-9 Sand	550	350	8400	Poured

11. FLOWING ARTESIAN:

Flowing Artesian? Y N Artesian Pressure (PSIG) _____

Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 301 Static water level (ft) 301

Water temp. (°F) 85.7 Bottom hole temp. (°F) 85.7

Describe access port _____

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)
14'	1800	2 days

Test method:

Pump	Bailer	Air	Flowing artesian
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
25	0	2	TOP SOIL		
25	2	6	CLAY		
25	6	18	Weathered Basalt		
20	18	47	Weathered Basalt		
20	47	63	Red Cinder		
20	63	177	Solid Basalt		
20	177	183	Fractured Basalt		
20	183	193	Gravel and Sand		
16	193	496	Gravel and Sand	X	
16	496	507	S. Hy Tan Clay		
16	507	538	Sand and Gravel	X	
16	538	537	Tan Clay		
16	537	542	Fine to Med Sand	X	
16	542	555	Sticky Tan Clay		

RECEIVED
JUN 07 2018

WATER RESOURCES
WESTERN REGION

Completed Depth (Measurable): 550

Date Started: 5-1-18 Date Completed: 6-1-18

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling No. 560

*Principal Driller [Signature] Date 6-7-18

*Driller [Signature] Date 6-7-18

*Operator II _____ Date _____

Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.

Monitoring Well

Form 238-7
6/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0066301

Drilling Permit No. **965601-871660**
Water right or injection well # _____

2. OWNER

Name **Ray Montierth**
Address **825 Hearland Dr**
City **Nampa** State **Id** Zip **83686**

3. WELL LOCATION:

Twp. **1** North or South Rge. **1** East or West
Sec. **12** **NE** 1/4 **SW** 1/4 **SE** 1/4
10 acres 40 acres 160 acres

Gov't Lot _____ County **Ada**
Lat. **43 ° 25.967** (Deg. and Decimal minutes)
Long. **116 ° 16.803** (Deg. and Decimal minutes)
Address of Well Site **1/4 mi.w.of Cole Rd 1/4 mi.s.of railroad ROW**
City **Kuna**

(Give at least name of road + Distance to Road or Landmark)

Lot. _____ Blk. _____ Sub. Name _____

4. USE:

Domestic Municipal Monitor Irrigation Thermal Injection
 Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

New Well Replacement well Modify existing well
 Abandonment Other _____

6. DRILL METHOD:

Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
gran/bentonite	0	80	3600/lbs	pour

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
10	+3	4	.250	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
6	+2	378	.250	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
5	368	388	.250	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) **376**

9. PERFORATIONS/SCREENS:

Perforations Y N Method _____
Manufactured screen Y N Type **johnson**
Method of installation **set in**

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
388	398	.16	10 ft	5	ss	.250

Length of Headpipe **20** Length of Tailpipe _____

Packer Y N Type **neoprene**

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method

11. FLOWING ARTESIAN:

Flowing Artesian? Y N Artesian Pressure (PSIG) _____
Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) **280** Static water level (ft) **268**
Water temp. (°F) **72** Bottom hole temp. (°F) _____
Describe access port **cap**

Well test:	Discharge or yield (gpm)	Test duration (minutes)	Test method:			Flowing artesian
			Pump	Bailer	Air	
122	40	2hr	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Water Quality test or comments: **tested great, no smell, no sand**

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
10	0	2	top soil		X
10	2	9	brokin up lava		X
10	9	37	black lava		X
10	37	40	soft		X
8	39	46	brown lava		X
8	46	68	black lava		X
8	68	70	brown lava		X
8	70	84	black lava		X
8	84	86	fractured lava		X
8	86	88	crack		X
8	88	127	lava		X
8	127	131	soft lava		X
8	131	162	lava		X
8	162	170	soft lava		X
8	170	230	lava		X
8	230	238	sinders		X
6	238	262	gravel	X	
6	262	268	clay		X
6	268	340	gravel sand	X	
6	340	343	clay		X
6	343	347	gravel	X	
6	347	351	clay		X
6	351	356	sand	X	
6	356	360	clay		X
6	360	367	sand	X	
6	367	370	clay		X
6	370	375	sand	X	
6	375	378	clay		X
6	378	385	gravel	X	
6	385	387	clay		X
6	387	404	corse sand	X	

Completed Depth (Measurable) **398**

Date: Started **July 8, 2014** Completed **July 20, 2014**

14. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name **Treasure Valley Drilling** Co. No. **560**

*Principal Driller *Monte Ross* Date **4-3-15**

*Driller _____ Date _____

*Operator II _____ Date _____

Operator I *Pete Langa* Date **4-3-15**

Signature of Principal Driller and rig operator are required.

RECEIVED

APR 03 2015

WATER RESOURCES
WESTERN REGION

Appendix C
Water Level Data
(Submitted Electronically)