

RECEIVED

APR 30 2021

DEPARTMENT OF
WATER RESOURCESSTATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
STATEMENT OF COMPLETION
FOR SUBMITTING PROOF OF BENEFICIAL USE

FOR OFFICE USE ONLY

Amt. of Fee \$ N/A
Receipt No. W/ C110335
Received By KEL
Date Received 4/30/21

The Idaho Department of Water Resources considers this form a statement by the permit holder(s) that development of a water right has been **completed** and that water has been applied to beneficial use to the extent described below. **This form must be accompanied by an examination fee, when necessary, or by a completed Beneficial Use Field Report prepared by a certified water right examiner.** Please refer to the instructions and fee schedule for this form. If ownership of the permit has changed, contact any Department office or visit the Department's website at idwr.idaho.gov for an *Assignment of Permit* form. If you wish to relinquish your permit because you have not established the authorized use of the water and are not applying for an extension, please notify the Department in writing.

- Permit No. 63-34186 Telephone No. 208 420 7472
- Name of Permit Holder(s) CHARLES JIMMIE HOWARD
- Mailing Address 155 14TH ST City BOISE
State ID Zip 83702 Email joseph.howard123@gmail.com
- Source of Water GROUND WATER If **GROUND WATER** (well), Date Drilled mo. 10 / yr. 2016
Well Driller HIDDLESTON DRILLING & PUMP CO. Drilling Permit Number D0074427
- Extent of use(s) completed as authorized by the water right permit:
Domestic (No. of households) 1 Stockwater (No. and type of stock) _____
Irrigation (No. of acres) _____ Other _____
- Total rate of diversion or storage volume for which proof is submitted .04 cfs OR _____ acre-feet.

- Compliance with a measuring device requirement, lockable controlling device requirement, and/or other conditions of permit:
Refer to the approval conditions on your permit and respond accordingly.

The Department will not issue a license if permit conditions are not met.

Measuring Device	Is a measuring device required?	Yes ☐	No ☒
	If yes, has the measuring device been installed?	Yes ☐	No ☒
Lockable Controlling Device	Is a lockable device required to control the diversion?	Yes ☐	No ☒
	If yes, has the lockable device been installed?	Yes ☐	No ☒
Fish Screen	Is a fish screen required?	Yes ☐	No ☒
	If yes, has the fish screen been installed?	Yes ☐	No ☒

Other Conditions of Permit

Do the approval conditions on your permit require you to submit additional information in connection with your proof of beneficial use? If yes, list the conditions below and attach documents with the required information.

N/A Completed? Yes ☐ No ☒

- Fee Enclosed \$ _____ or not applicable ☒. See fee schedule on page 2 of the instructions.
Proof statements filed without an appropriate fee, will be considered incomplete.
- Person to contact to accompany the Department representative during field examination of the water system.

Name C. JOE HOWARD Telephone Number 208 420 7472
Mailing Address 155 14TH ST City BOISE
State ID Zip _____ Email joseph.howard123@gmail.com

The information given on this form is my true statement of the extent to which the above numbered permit has been developed and water has been diverted and applied to a beneficial use. I understand that any undeveloped portion of the permit is relinquished to the State of Idaho.

Signature of Permit Holder [Signature] Date 4/30/21
(Include your title, if on behalf of company or organization)

Mail to: Idaho Department of Water Resources, PO Box 83720, Boise, ID 83720-0098

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0074427

Drilling Permit No. _____
Water right or injection well # _____

2. OWNER:

Name Doug Howard
Address 854 South Twin Pine Drive
City Pine State Id. Zip 83647

3. WELL LOCATION:

Twp. 2 North ☒ or South ☐ Rge. 10 East ☒ or West ☐
Sec. 31 10 acres 1/4 SE 40 acres 1/4 SW 160 acres 1/4

Gov't Lot _____ County Elmore
Lat. 43 ° 27.506 (Deg. and Decimal minutes)
Long. -115 ° 18.848 (Deg. and Decimal minutes)
Address of Well Site 854 South Twin Pine Drive

City Pine
(Give at least name of road + Distance to Road or Landmark)
Lot. 10 Blk. 1 Sub. Name Twin Pine Sub.

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation ☐ Thermal ☐ Injection
☐ Other _____

5. TYPE OF WORK:

☒ New well ☐ Replacement well ☐ Modify existing well
☐ Abandonment ☐ Other _____

6. DRILL METHOD:

☒ Air Rotary ☐ Mud Rotary ☐ Cable ☐ Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft³)	Placement method/procedure
Bentonite #5	0	41'	1400 lbs	Overbore pour

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Linear	Threaded	Welded
6 5/8"	+2'	118'	.250	Steel	☒	☐	☐	☒
4.5"	-7'	147'	40	PVC	☐	☒	☒	☐
4.5"	157'	167'	40	PVC	☐	☒	☒	☐

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 118 feet

9. PERFORATIONS/SCREENS:

Perforations ☐ Y ☒ N Method _____
Manufactured screen ☒ Y ☐ N Type Johnson screens
Method of installation Set with rig

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
147'	157'	.010	10	4.5"	PVC	40
167'	177'	.010	10	4.5"	PVC	40
177'	197'	.020	20	4.5"	PVC	40

Length of Headpipe 140 feet Length of Tailpipe 4 inch

Packer ☐ Y ☒ N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft³)	Placement method
none				

11. FLOWING ARTESIAN:

Flowing Artesian? ☐ Y ☒ N Artesian Pressure (PSIG) _____

Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 90 Static water level (ft) 114.22 = 136
Water temp. (°F) 52 Bottom hole temp. (°F) _____
Describe access port Top of well through the well seal

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Ball	Air	Flowing artesian
<u>22</u>	<u>12.5</u> <u>15</u>	<u>120</u>	☒	☐	☐	☐

Test method: Pump & 180

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
10"	0	4'	Top soil		X
10"	4'	27'	Sand and gravel		X
10"	27'	33'	Tan sand with some gravel		X
10"	33'	41'	Tan clay		X
6"	41'	81'	Tan sand with small gravel		X
6"	81'	90'	Tan sand with seams of tan clay		X
6"	90'	93'	Gray sand and gravel	X	
6"	93'	100'	Gray sand and gravel with clay		X
6"	100'	104'	Gray sand and clay		X
6"	104'	116'	Decomposed granite		X
6"	116'	200'	Granite with seams of broken zones	X	

Completed Depth (Measurable): 197 Feet

Date Started: Oct 25, 2016 Date Completed: Nov 11, 2016

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Hiddleston Drilling Co. No. 35

*Principal Driller [Signature] Date Nov 14, 2016

*Driller _____ Date Nov 14, 2016

*Operator II _____ Date Nov 14, 2016

Operator I [Signature] Date Nov 14, 2016

* Signature of Principal Driller and rig operator are required.

SERVICE AND REPAIRS RECORD

[illegible]

From: doug howard dougandmarylou@gmail.com
Subject:
Date: January 10, 2017 at 11:15 AM
To:

Form 238-7
6/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0074427

Drilling Permit No. 97-191-880981

Water right or injection well #

2. OWNER:

Name Doug Howard

Address 854 South Twin Pine Drive

City Pine State Id Zip 83647

3. WELL LOCATION:

Twp 3 North ☒ or South ☐ Rgn 10 East ☒ or West ☐

Sec 31 1/4 SE 1/4 SW 1/4

Geol Loc Elmore County

Lot 43 +27.506 (Dep and Decoral minutes)

Long -115 +18.848 (Dep and Decoral minutes)

Address of Well Site 854 South Twin Pine Drive

City Pine

Section 10 Bk 1 Sub Name Twin Pine Sub.

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation ☐ Thermal ☐ Injection

☐ Other

5. TYPE OF WORK:

☒ New well ☐ Replacement well ☐ Modify existing well

☐ Abandonment ☐ Other

6. DRILL METHOD:

☒ Air Rotary ☐ Mud Rotary ☐ Cable ☐ Other

7. SEALING PROCEDURES:

Seal material Bentonite #5 From (ft) 0 To (ft) 41 Quantity (lb or gal) 1400 lbs Placement method Overbore pour

8. CASING/LINER:

Casing/Liner From (ft) To (ft) Size (in) Schedule Material Casing Liner Threaded Welded

6 5/8" +2' 118' 250 Steel ☒ ☐ ☐ ☐

4.5" -7' 147' 40 PVC ☐ ☒ ☐ ☐

4.5" 157' 167' 40 PVC ☐ ☒ ☐ ☐

Weld drive shoe used? ☒ Y ☐ N Shoe Depth (ft) 118 feet

9. PERFORATIONS/SCREENS:

Perforations ☐ Y ☒ N Method

Manufactured screen ☒ Y ☐ N Type Johnson screens

Method of installation Set with rig

From (ft) To (ft) Size (in) Number of Screens Material Gauge or Schedule

147' 157' .010 10 4.5" PVC 40

167' 177' .010 10 4.5" PVC 40

177' 197' .020 20 4.5" PVC 40

Length of Headpipe 140 feet Length of Tailpipe 4 inch

Packer ☐ Y ☒ N Type

10. FILTER PACK:

Filter Material From (ft) To (ft) Quantity (lb or ft) Placement Method

none

11. FLOWING ARTESIAN:

Flowing Artesian? ☐ Y ☒ N Artesian Pressure (PSID)

Describe control device

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 90 Static water level (ft) 114

Water temp. (°F) 52 Bottom hole temp. (°F)

Describe access point Top of well through the well seal

Well test:

Drawdown (feet) Discharge or Test duration (minutes) Test method:

22 12.15 120 ☒ Pump ☐ Bailer ☐ Air ☐ Flowing Artesian

Water quality test or comments:

13. LITHOLOGIC LOG and/or repairs or abandonment:

From (ft) To (ft) Remarks, lithology or description of repairs or abandonment, water temp.

10' 0' 4' Top soil

10' 4' 27' Sand and gravel

10' 27' 33' Tan sand with some gravel

10' 33' 41' Tan clay

8' 41' 81' Tan sand with small gravel

6' 81' 90' Tan sand with seams of tan clay

8' 90' 93' Gray sand and gravel

8' 93' 100' Gray sand and gravel with clay

6' 100' 104' Gray sand and clay

6' 104' 118' Decomposed granite

6' 118' 200' Granite with seams of broken zones

RECEIVED

DEC 07 2016

WATER RESOURCES
WESTERN REGION

Completed Depth (Maximum) 197 Feet

Date Started Oct 25, 2016 Date Completed Nov 11, 2016

14. DRILLER'S CERTIFICATION:

I/we certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Hiddleston Drilling Co. No. 35

*Principal Driller [Signature] Date Nov 14, 2016

*Driller [Signature] Date Nov 14, 2016

*Operator II [Signature] Date Nov 14, 2016

Operator I [Signature] Date Nov 14, 2016

*Signature of Principal Driller and rig operator are required