

RECEIVED

AUG 14 2006

IDWR/North

TP-95-59

Page Two

Received by db

Date

8/14/06

Time

3:38 p

\$50.00 fee received by db

#

N017822

Date

8/14/06

Watermaster Comments received? \_\_\_\_\_

Date \_\_\_\_\_

**ACTION OF THE DIRECTOR, DEPARTMENT OF WATER RESOURCES**

This is to certify that the department has examined this application for temporary approval to use water under the provisions of Section 42-202a, Idaho Code, and has determined that:

- ☐ a) The application for temporary approval should be denied.
- ☒ b) The application for temporary approval should be approved, since
1. The temporary approval can be properly administered.
  2. Other water sources are not readily available.
  3. The approval is in the public interest.
  4. The approval will not injure known public values associated with the water source or any known water rights.

This application is therefore hereby:

☐ a) DENIED

☒ b) APPROVED, subject to the following conditions:

1. Diversion and use of water under this approval is subject to all valid existing water rights.
2. The applicant assumes all risk the use of the water under this approval may injure other water rights.
3. This approval authorizes a maximum diversion of 5 AF and a maximum rate of diversion of 0.17 cfs.
4. This approval does not grant a right-of-way across the land of another, does not create a continuing right to use the water and may not be used in connection with a use which requires a continuing water supply.
5. The department may cancel this approval at any time if the department identifies injury to other water rights.
6. This approval expires on 11/1/06.
7. This approval does not create a continuing right to use water.
8. The holder of this temporary permit shall not divert at a rate or in a manner that will significantly reduce the flow in the water source or otherwise adversely affect fish, wildlife or other public values.
9. Other: Water intakes should be screened to prevent entrainment or impingement of fish or other aquatic life. The maximum screen mesh size should be 0.25 inches; approach velocities should not exceed 0.5 ft/second.
10. Contact the DEPARTMENT OF WATER RESOURCES prior to diversion of water from streams.

DATED this 15 day of August, 2006.

Robert G. Haynes  
For the Director

RECEIVED  
AUG 14 2006  
IDWR/NorthIdent. No. TP-95-59STATE OF IDAHO  
DEPARTMENT OF WATER RESOURCES

## APPLICATION FOR TEMPORARY APPROVAL OF WATER APPROPRIATION

(5 AF of less)

Name of Applicant M.A. Dlatkey Construction Phone 509-751-1580Address 829 Evans Road, PO Box 490, Clarkston, WA 994031. Source of water Private Water Well Tributary to \_\_\_\_\_2. Location of point of diversion SW 1/4 SE 1/4 Sec. 1 Township 48 N, Range 5 W B.M.,County Kootenai3. Location of place of use \_\_\_\_\_ 1/4 \_\_\_\_\_ 1/4 Sec. 28+33 Township 48 N, Range 5 W B.M.,County Kootenai4. Proposed use of water Water for Dust Abatement on Construction Project


## 5. Amount of water:

Maximum rate of diversion \_\_\_\_\_ cfs or 75 gpm.Maximum daily volume 60,000 gallons 1.4 AF AF; Total volume 5 AF.6. Duration of diversion: From 08-01-06 to 11-01-06  
Day-month Day-month7. Proposed diverting works N/A8. Who owns the property at the requested point of diversion? Rodney Shriner9. Describe the arrangement allowing access to the water Access Pull water right from water well

10. Remarks \_\_\_\_\_

I hereby acknowledge that I assume all risk if the diversion and use of the water under this approval injures other water rights. I certify this is a temporary use and that I am not seeking a continuing right to use water.

8-10-06  
DateDust In  
Applicant





State of Idaho

**DEPARTMENT OF WATER RESOURCES**

Northern Region, 1910 Northwest Blvd. Suite 210, Coeur d'Alene, Idaho 83814-2615

Phone: (208) 769-1450

Fax: (208) 769-1454

Web Site: [www.idwr.idaho.gov](http://www.idwr.idaho.gov)

08/15/2006

JAMES E. RISCH  
Governor

KARL J. DREHER  
Director

M A DeATLEY CONSTRUCTION  
829 EVANS ROAD  
PO BOX 490  
CLARKSTON WA 99403

RE: Temporary Permit No. TP-95-59

Dear Applicant(s):

Your application for Temporary approval of Water Appropriation has been granted and assigned number TP-95-59.

Please be advised that THE PERMIT IS SUBJECT TO THE EFFECTIVE DATES AND CONDITIONS STATED ON PAGE TWO OF THE APPLICATION.

If you have any questions or if this office can be of further assistance, please contact us.

Sincerely,

Robert G. Haynes, P.E.  
Regional Manager

Enclosure