



RECEIVED

APR 26 2019

DEPARTMENT OF  
WATER RESOURCES

April 26, 2019

Manuel Rauhut  
Idaho Department of Water Resources  
P.O. Box 83720  
Boise, ID 83720-0098

*Subject: Annual Monitoring Report for Permits 63-32680, 63-33207, 63-33296, 63-34038, 63-34221, and 63-34202*

Dear Manuel:

Enclosed please find one copy of the 2018 monitoring report for permits 63-32680, 63-33207, 63-33296, 63-34038, 63-34221, and 63-34202.

This report presents the fifth year of monitoring under permits 63-32680 and 63-33296 the third year of monitoring under permits 63-33207 and 63-34038 and the second and first years of monitoring under permits 63-34202 and 63-34221, respectively. These permits share some of the same diversion points so it made sense to combine the monitoring data into a single comprehensive report. An excel spreadsheet of the water level data (Appendix D) will be provided to IDWR in a separate email through a file sharing website.

Please contact me with any questions.

Sincerely,

A handwritten signature in blue ink that reads "Kurt Newbry".

Kurt Newbry, P.G.

Enclosure

Cc: Steve Meyer – CS Beef Packers  
Vic Conrad – JR Simplot Company  
Ann Vonde, Deputy Attorney General – Attorney for Idaho Department of Corrections  
Michael Lawrence, Givens Pursley – Attorney for Suez

**2018 MONITORING REPORT FOR WATER RIGHT  
PERMIT NOS. 63-32680, 63-33207, 63-33296, 63-  
34038, 63-34202, AND 63-34221**


*Prepared for*

**CS Beef Packers, LLC  
17365 South Cole Road  
Kuna, ID 83634**

*Prepared by*

**SPF Water Engineering, LLC  
300 East Mallard, Suite 350  
Boise, Idaho 83706  
(208) 383-4140**

**April 2019**



**SPF WATER  
ENGINEERING**

## Executive Summary

---

This report is the fifth annual report prepared as required by the monitoring plan for water right permits 63-32680 and 63-33296 and the third annual report prepared for permits 63-34038 and 63-33207. Included beginning with this report is data for permits 63-34202 and 63-34221.

### Permits

1. Water right permits 63-32680 and 63-33296 authorize irrigation of up to 784 acres, with a combined maximum diversion rate of 11.76 cfs (5,278 gpm) and a maximum annual diversion volume of 3,528 acre feet (4.5 acre feet per acre).
  - a. A condition of water right permits 63-32680 and 63-33296 is compliance with an approved monitoring plan. The monitoring plan requires monitoring of water levels and pumping volumes, and includes specific requirements for monitoring equipment at a dedicated monitoring well and at each supply well.
  - b. Statements of completion for submitting proof of beneficial for 63-32680 and 63-33296 were submitted to the Idaho Department of Water Resources (IDWR) on June 20, 2018.
2. Water right permit 63-33207 authorizes diversion of 3.0 cfs for industrial purposes.
  - a. The permit requires measurement of water levels in one well authorized under the permit on a monthly basis and monthly measurements of flow rate and diversion volume.
3. Water right permit 63-34038 authorizes diversion of 3.2 cfs for irrigation of 160 acres and 4.0 cfs for industrial purposes, with a maximum diversion rate of 4.0 cfs.
  - a. The permit requires measurement of water levels in each well authorized under the permit shall on a monthly basis and monthly measurements of flow rate and diversion volume.
4. Data collected under the above permits may also be useful for permits 63-34202 and 63-34221.
  - a. Water right permit 63-34202 authorizes diversion of 4.96 cfs for irrigation purposes from the same points of diversion authorized under permits 63-32680, 63-33296, 63-33207 and 63-34038, which currently include Irrigation Well Nos. 1, 2, and 3.
  - b. Water right permit 63-34221 authorizes diversion of 0.44 cfs for irrigation purposes from some of the same points of diversion as authorized by permits 63-33207 and 63-34038, including Plant Well Nos. 1 and 2.

## 2018 Permit Activities

1. Three irrigation supply wells (Irrigation Wells No. 1, No. 2, and No. 3) were monitored throughout the 2018 irrigation season.
2. Two industrial supply wells (Plant Wells 1 and 2) for the CS Beef packing plant were monitored throughout 2018.
3. The sounding tube in Irrigation Well No. 1 is pinched, preventing reinstallation of a transducer. Water levels can now be measured, but the presence of pump oil in the well makes water level readings difficult. The airline water level gauge was recalibrated in December 2017.
4. A transducer was installed in the Drill Water Supply Well in January 2018. Since Irrigation Well No. 1 and the Drill Water Supply Well are approximately 100 feet from each other, transducer data collected from the Drill Water Supply Well will act as a surrogate for Irrigation Well No. 1.
5. The pump in Irrigation Well No. 2 seized up in August 2018 due to lack of lubrication and overheating. The pump system and monitoring tube were removed at that time. The water-level transducer for Well No. 2 was reinstalled to a depth of approximately 320 feet on October 17, 2018.
6. A new Solinst Edge transducer was installed in Irrigation Well No. 3 on December 29, 2017 to a depth of approximately 260 feet. After removing and downloading the logger data in January 2018, it was apparent that the transducer had been lodged in the sounding tube roughly 5.35 feet higher than before. The transducer was redeployed to its original depth of 260 feet on March 22, 2018.
7. Water level data could not be downloaded from the transducer in the Monitoring Well during the January 2019 monitoring event. The old logger was removed at this time and a new Solinst Edge was installed using the same cable on February 28, 2019. As a result, there are gaps in the Monitoring Well data from December 27, 2018 to January 28, 2018 and from January 30, 2018 to February 28, 2019.
8. A Solinst Edge water-level data logger was installed in Plant Well No. 2 on October 4, 2018 for monitoring purposes associated with permit 63-34221.
9. Based on the surveyed measuring point elevation at the Monitoring Well, static water level elevations at the Monitoring Well ranged from approximately 2588 to 2596 feet during 2018. Water levels in November 2018 were roughly 2 feet lower compared to November 2017.
10. For the 2018 irrigation season, the totalizer on Irrigation Well No. 1 provides a total diversion volume of 620.19 acre-feet, the totalizer on Irrigation Well No. 2 provides a total diversion volume of 692.74 acre-feet, and the totalizer on Irrigation Well No. 3 provides a total diversion volume of 1,195.09 acre-feet. The total diversion volume for the three irrigation wells in 2018 is then 2,508 acre-feet, which is below

the combined diversion limit of 3,528 acre-feet listed under permits 63-32680 and 63-33296.

11. Total diversion volume in 2018 was approximately 638 acre-feet for Plant Well 1 (East) and 542 acre-feet for Plant Well 2 (West), which is equivalent to a total diversion volume of 1,100 acre-feet. These diversions are covered by permits 63-33207 and 63-34038.

## Table of Contents

---

1. Background.....	1
1.1. Applicable Water Right Permits .....	1
1.1.1. Permits 63-32680 and 63-33296 .....	1
1.1.2. Permit 63-33207 .....	2
1.1.3. Permit 63-34038 .....	2
1.2. Project Site .....	3
2. 2017 Activities .....	5
2.1. Water Level Monitoring .....	5
2.2. Flow Monitoring .....	8
3. Summary.....	10

## List of Figures

---

Figure 1. Project Location Map.....	4
Figure 2. Water Level Hydrograph through 12/29/2017 .....	8

## List of Tables

---

Table 1. Authorized Points of Diversion and Well Locations .....	3
Table 2. Irrigation Wells Monthly Flow Monitoring .....	<b>Error! Bookmark not defined.</b>
Table 3. Irrigation Well Volume Estimates Based on Power Consumption.....	<b>Error! Bookmark not defined.</b>
Table 4. Plant Wells Monthly Flow Monitoring .....	10
Table 5. Plant Water Use .....	<b>Error! Bookmark not defined.</b>

## **Appendices**

---

Appendix A: Water Right Reports

Appendix B: Well Driller's Reports for Production and Monitoring Wells

Appendix C: Totalizer Photos

Appendix D: Water Level Data

# 1. BACKGROUND

---

## 1.1. Applicable Water Right Permits

Six water right permits utilize wells monitored as part of this monitoring program. Water right permit reports are provided as Appendix A and the permits are described below.

### 1.1.1. Permits 63-32680 and 63-33296

Kuna Cole-880, LLC, Azel Development Group, LLC, Boise Investment Group, LLC, Noelle Holdings, LLC, as tenants in common, applied for water right 63-32680 on May 22, 2007. The water right application sought 7.0 cfs for municipal use by 2250 homes as part of a proposed planned community. The application was amended on September 1, 2009 to seek 5.22 cfs for irrigation of 261 acres, and was subsequently assigned to Kirkwood Bank & Trust Company on September 22, 2011.

Kuna Cole-880, LLC, Azel Development Group, LLC, Boise Investment Group, LLC, Noelle Holdings, LLC, as tenants in common, applied for water rights 63-33296 on November 6, 2009. The water right application sought 15.22 cfs for irrigation of 761 acres. The application was assigned to Kirkwood Bank & Trust Company on September 22, 2011 and was subsequently amended to seek 10.46 cfs for irrigation of 521 acres on January 12, 2012.

Both water right permit applications were protested by United Water Idaho and the Idaho Department of Corrections. A stipulation was entered between the protestants and the applicant to settle the protests. The stipulation included combined limits on diversion rates and irrigated acres, and the requirement for compliance with an approved monitoring plan.

The permits were approved by the Idaho Department of Water Resources (IDWR) on July 17, 2013. The two permits authorize irrigation of up to 784 acres within the property, with a combined maximum diversion rate of 11.76 cfs (5,278 gpm) and a maximum annual diversion volume of 3,528 acre-feet (4.5 acre feet per acre).

- Permit 63-32680 authorizes diversion of up to 5.22 cfs for irrigation of up to 261 acres within a 360-acre permissible located in Sections 11 and 14. The right authorizes construction of up to 2 wells located in Sections 11 and 14. Priority date is May 22, 2007.
- Permit 63-33296 authorizes diversion of up to 10.46 cfs for irrigation of up to 523 acres located within a 1022-acre permissible place of use that covers the entire property. The right authorizes construction of up to 2 wells located in Sections 12 and 13. Priority date is November 6, 2009.

Kirkwood Bank assigned the permits to Ray and Susan Montierth on March 14<sup>th</sup>, 2014. Ray and Susan Montierth assigned the permits to J.R. Simplot Company on January

6, 2015. J.R. Simplot Company assigned the permits to CS Property Development LLC on April 6, 2016.

#### **1.1.2. Permit 63-33207**

Jim Hutchings applied for water right 63-33207 on May 15, 2009 and amended the permit on March 24, 2010. The permit application sought 3.0 cfs for irrigation of 200 acres. The permit was approved on September 25, 2013, and assigned to J.R. Simplot Company on March 26, 2015. The application was amended to change the use to industrial purposes, and was subsequently assigned to CS Property Development, LLC on April 6, 2016. There is a 700-acre-foot annual diversion limit associated with this permit. The permit requires monthly measurement of flow rate and volume, and requires monthly water level measurements from one point of diversion authorized for this right.

#### **1.1.3. Permit 63-34038**

J.R. Simplot Company applied for water right 63-34038 on February 6, 2015 and amended the application on June 26, 2015. The amended permit application sought 3.2 cfs for irrigation of 160 acres and 4.0 cfs for industrial use, with a total diversion rate of 4.0 cfs. The permit was approved on October 26, 2015, and assigned to CS Property Development LLC on April 6, 2016. The permit requires monthly measurement of flow rate and volume, and requires monthly water level measurements from all points of diversion authorized for this right.

#### **1.1.4. Permit 63-34202**

CS Property Development LLC applied for water right 63-34202 on February 29, 2016 seeking 4.96 cfs for irrigation of 248 acres. The permit was approved April 21, 2017 and requires monthly recording of flow rates, diversion volumes, and water level measurements at the points of diversion. An annual report is not required, but a report will be needed for submission with proof of beneficial use.

#### **1.1.5. Permit 63-34221**

Ray and Susan Montierth applied for water right 63-33884 on December 6, 2013, then submitted an amended application on February 2, 2015 and a second amended application on March 16, 2015. A portion of 63-33884 was subsequently assigned to J.R. Simplot Company on September 28, 2015 and the assigned portion was renumbered to 63-34221. Permit 63-34221 sought 0.44 cfs for irrigation of up to 22 acres within a 147-acre permissible place of use. J.R. Simplot Company then assigned permit 63-34221 to CS Property Development LLC on May 26, 2016, who amended the permit on August 16, 2017. The permit requires monthly flow rate and diversion volume records as well as installation of a permanent water-level transducer in one of the point of diversion wells. Water level measurements are not required on a monthly basis, although manual water levels are to be taken within 30 days before and

after irrigation season. No annual report is required, but a report will be needed for submission with proof of beneficial use.

## 1.2. Project Site

The project area is located approximately 7 miles southeast of Kuna, Idaho, in portions of Sections 11, 12, 13, 14, 23, and 24 of Township 1 North, Range 1 East, and Section 6 of Township 1 North, Range 2 East, Ada County, Idaho (Figure 1). Total area is approximately 1900 acres.

The project site is accessed from Cole Road. The northern portion of the property is bisected by the Union Pacific Railroad.

Two irrigation wells (Irrigation Wells 1 & 2), a monitoring well, and a drill water supply well were constructed in 2014. Two plant industrial water supply wells were constructed in 2015. One irrigation well (Irrigation Well 3) was constructed in 2016. An irrigation well was constructed east of the plant (Irrigation Well 4) in 2018.

Well locations and authorized diversion points are summarized in Table 1 and driller's reports for each listed well are provided in Appendix B.

Center pivot sprinklers were installed in the winter of 2014-15, and irrigation began in 2015. Additional pivot sprinklers were installed in 2017.

Table 1. Authorized Points of Diversion and Well Locations

Township	Range	Section	1/4-1/4	Well	Authorized Point of Diversion					
					63-34038	63-33207	63-32680	63-33296	63-34221	63-34202
1N	1E	11	SWSE		X	X	X			X
1N	1E	11	SESE		X	X	X			X
1N	1E	12	SWNW		X	X		X		X
1N	1E	12	SENE		X	X		X		X
1N	1E	13	NWNE		X	X		X		X
1N	1E	13	NWNW	Irr. Well 2	X	X		X		X
1N	1E	13	NESE		X	X		X		X
1N	1E	14	NENE	Irr Well 1	X	X	X			X
1N	1E	14	NWNE		X	X	X			X
1N	1E	14	SWNE		X	X	X			X
1N	1E	14	SENE		X	X	X			X
1N	1E	14	NESE	Irr. Well 3	X	X	X			X
1N	1E	14	NWSE		X	X	X			X
1N	2E	6	NWSW Lt6		X	X				
1N	2E	6	NWSW Lt6		X	X				
1N	2E	6	SWSW Lt7	Plant Well 1	X	X			X	
1N	2E	6	SWSW Lt7	Plant Well 2	X	X			X	
1N	2E	6	SESW	Irr. Well 4					X	




Figure 1. Project Location Map

## 2. 2018 ACTIVITIES

---

### 2.1. Water Level Monitoring

Water level data from electronic transducers in the irrigation wells and Monitoring Well are required to be collected at a minimum of 3 times per year. The current schedule specifies that these events should occur between November 15 and November 30, between January 15 and January 30, and between March 1 and March 15 of each year. At the time of collection, manual groundwater level measurements are to be taken at each well with a non-stretch electric well sounder, and flow meter readings should also be recorded. Monthly airline water-level measurements and flow-meter readings are also scheduled for each of the four irrigation wells and both of the plant wells.

Monitoring details for each well during the 2018 monitoring period are provided below.

**Irrigation Well No. 1.** The transducer for Irrigation Well No. 1 was removed on November 29, 2016, but could not be redeployed due to a pinched sounding tube. In 2018, manual water level measurements were collected from January to March and in November. Airline water level measurement were taken in every month except December. Water level measurements indicate groundwater levels fluctuated approximately 43 feet during the irrigation season. Totalizer readings were also taken during each site visit.

Because of the inability to install a transducer in Irrigation Well No. 1, SPF installed a new water level transducer in the Drill Water Supply Well located 100 feet southeast of Irrigation Well No. 1. The transducer was installed on January 24, 2018 to a depth of approximately 270 feet.

**Irrigation Well No. 2.** The pump in Irrigation Well No. 2 seized up in August 2018 due to overheating and poor lubrication. It was removed for servicing prior to a site visit on August 31 and had been reinstalled by the subsequent site visit on September 28, but the monitoring tube was not reinstalled until October 17. As a result, transducer data are not available from when the pump was removed to when the monitoring tube was reinstalled. Manual measurements to the top of the oil layer in the well were taken in every month except May, June, July, and December. Airline water level measurements were every month except for August and December. Transducer data indicate water levels fluctuated approximately 25 feet during the irrigation season, but the compiled hydrograph also indicates that the transducer may hang above the groundwater level at certain times during pumping. The transducer data also indicate that groundwater had recovered to within 3 feet of pre-irrigation levels by November 30.

**Irrigation Well No. 3.** Irrigation Well No. 3 was constructed in 2016 and put into service as a supply well during the 2017 irrigation season. Manual water level measurements in Irrigation Well No. 3 were collected from January to April,

September, and November in 2018. Airline water level measurements were collected in every month except for December. The well consistently has a thick oil layer on top of the water in the casing, which can make manual water level measurements difficult and sometimes results in inconsistent readings. A new Solinst Edge water level transducer was installed in Irrigation Well No. 3 on December 29, 2017 to a depth of approximately 260 feet. During a monitoring event in January 2018, the transducer seemingly hung up roughly 5.35 feet higher than usual and it remained there until March 2018 when it was reinstalled to the original depth. Analysis of the transducer data shows a difference of at least 25 feet between the static and pumping water levels, but the maximum drawdown cannot be determined from the data because the hydrograph appears to show that the transducer hangs above the pumping water level for much of the irrigation season. Water levels in Irrigation Well No. 3 recovered to within approximately 2.5 feet of the pre-irrigation season water table by November 30, 2018.

#### **Irrigation Well No. 4**

Irrigation Well No. 4 was constructed in 2018 to a total depth of 555 feet with casing to 450 feet and stainless-steel screens from 450 to 530 feet. The well was first brought on line towards the end of the 2018 irrigation season. An airline has been installed in the well, although there is some uncertainty about its setting depth and the water level readings do not match anticipated groundwater levels. A sounder cannot be used to calibrate the airline because there is no access port in the well head. Airline water levels were recorded in September 2018, January 2019, and March 2019. Based on these measurements, water levels recovered roughly 9.5 feet from September 2018 to March 2019. More complete records of water level fluctuations in Irrigation Well No. 4 during the irrigation season will be available following the 2019 irrigation season.

**Monitoring Well.** An electric line well sounder was used to determine water levels in the Monitoring Well in January, March, and December 2018. Transducer data was also collected during these measuring events. Analysis of the logger data shows an approximate 7-foot water level fluctuation over the course of the irrigation season, with recovery to within 2.5 feet of the pre-pumping levels by December 21. During a site visit in January 2019, the water level transducer in the Monitoring Well failed and its data could not be recovered. The logger was replaced with a new Solinst Edge transducer on February 28, 2019. As a result, there are gaps in the Monitoring Well water level data from December 27, 2018 to January 28, 2019 and from January 30, 2019 to February 28, 2019.


**Drill Water Supply Well.** The Drill Water Supply Well is located approximately 100 feet southeast of Irrigation Well No. 1 and is a non-production well with no pump installed. Since the transducer in Irrigation Well No. 1 cannot be removed to download water level data, the Drill Water Supply Well was offered as a surrogate data collection point. As a result, a new Solinst Edge transducer was installed in the

Drill Water Supply Well on January 24, 2018. Manual water level measurements were collected in January, February, March, and November 2018. Transducer data indicate that groundwater levels in the Drill Water Supply Well fluctuate roughly 11 feet during the irrigation season. Water levels had recovered to within 3 feet of pre-irrigation levels by the November 2018 monitoring event.

**Plant Well No. 1.** Plant Well No. 1 was completed in 2015, but had not been used as a water supply until late spring of 2017 when the CS Beef Packers plant opened. A manual water level measurement was collected on August 30, 2017 using a well sounder, but subsequent water level measurements have been taken using an airline to minimize potential for contamination of this public drinking water system well. Airline measurements were taken in every month during 2018, with a minimum depth to water of 304.3 feet and a maximum depth to water of 311 feet.

**Plant Well No. 2.** Plant Well No. 2 was also completed in 2015 and first used in 2017. The well is equipped with an airline which is calibrated against a non-stretch well sounder. According to the airline measurements, there has been little fluctuation in water levels at this well, with a minimum depth to water of 289.5 feet and a maximum depth to water of 295 feet in 2018. A new Solinst Edge water level transducer was installed in this well on October 4, 2018 to meet the monitoring requirements of water permit 63-34221.

Water-level data through March 15, 2019 are provided electronically on a compact disk in Appendix D and summarized below in Figure 2. Manual water levels include calibrated airline measurements.



## 2.2. Flow Monitoring

All three of the irrigation wells are equipped with electromagnetic flow meters. Irrigation pumping occurred between March 15 and October 31 in 2018.

- The flow meters at Irrigation Well No. 1 and Irrigation Well No. 2 have complete totalizer readings for 2018. It does appear that the totalizer in Irrigation Well No. 1 rolled over at least once during the irrigation season.
- Irrigation Well No. 3 also has mostly complete flow readings for 2018 except for the March monitoring event where the readout screen was blank. The flow meter display was also broken out during the March, April, and June monitoring events, but was intact in May. Some odd instantaneous flow measurements were observed during this period, but had been corrected by June and a new display was installed in July. As a result, the totalizer data before July may not be entirely accurate.

- Table 2 summarizes the monthly instantaneous and totalized flow readings for the Irrigation Wells. Total volumes are based on acre-feet since previous reading.

Table 2. Irrigation Wells Monthly Flow Monitoring (through 11/30/2018)

Date	Well 1			Well 2			Well 3			Total		
	Flow (gpm)	Totalizer (af)	AF since previous reading	Flow (gpm)	Totalizer (af)	AF since previous reading	Flow (gpm)	Totalizer (af)	AF since previous reading	Flow (gpm)	Flow (cfs)	Volume (af)
4/23/2015	0	23.21		0	23.21		---	---	---	0	0.00	46.4
5/29/2015	0	23.21	0.00	1094	81.87	58.66	---	---	---	1094	2.44	105.1
6/29/2015	2393	211.38	188.17	2008	243.04	161.17	---	---	---	4401	9.81	454.4
7/31/2015	0	446.35	234.97	2326.5	373.97	130.93	---	---	---	2327	5.18	820.3
8/27/2015	2368	705.09	258.74	764.2	489.42	115.45	---	---	---	3132	6.98	1194.5
10/1/2015	0	752.77	47.68	0	529.20	39.78	---	---	---	0	0.00	1282.0
10/30/2015	0	752.77	0.00	0	542.96	13.76	---	---	---	0	0.00	1295.7
1/29/2016	0	752.77	0.00	0	542.96	0.00	---	---	---	0	0.00	1295.7
3/15/2016	0	752.77	0.00	0	542.96	0.00	---	---	---	0	0.00	1295.7
4/30/2016	0	843.96	91.19	1411.5	543.71	0.75	---	---	---	1412	3.14	1387.7
6/8/2016	0	876.21	32.25	2145.5	569.25	25.54	---	---	---	2146	4.78	1445.5
6/29/2016	2479	980.51	104.30	2393.7	614.01	44.76	---	---	---	4873	10.86	1594.5
7/28/2016	2372	1168.80	188.29	2676.3	681.90	67.89	---	---	---	5048	11.25	1850.7
9/2/2016	2342	1458.24	289.44	1176.4	818.84	136.94	---	---	---	3518	7.84	2277.1
10/3/2016	0	1576.30	118.06	0	863.25	44.41	---	---	---	0	0.00	2439.6
10/31/2016	0	1576.30	0.00	0	870.61	7.36	---	---	---	0	0.00	2446.9
11/29/2016	0	1576.30	0.00	0	870.61	0.00	---	---	---	0	0.00	2446.9
1/30/2017	0	1576.30	0.00	0	870.61	0.00	---	---	---	0	0.00	2446.9
3/15/2017	0	1576.30	0.00	0	870.61	0.00	---	---	---	0	0.00	2446.9
4/27/2017	0	1606.02	29.72	0	888.09	17.48	---	---	---	0	0.00	2494.1
5/31/2017	2278	1867.29	261.27	314.8	983.07	94.98	---	---	---	2593	5.78	2909.3
6/30/2017	(1)	(1)		0	1012.21	29.14	---	---	---	0	0.00	0.0
7/25/2017	(2)	(2)		1563.7	1032.15	19.94	---	321.88	262.99	5433	12.10	1352.0
8/30/2017	(1)	(1)		2519.3	1046.20	14.05	---	613.15	291.27	9988	22.25	1658.3
10/2/2017	0	3.08	3.22	0	1052.91	6.71	---	757.97	144.82	0	0.00	1814.0
11/17/2017	0	19.03	15.80	0	1052.91	0.00	---	758.23	0.26	0	0.00	1830.2
12/29/2017	0	19.03	0.00	0	1052.91	0.00	---	758.23	0.00	0	0.00	1830.2
1/24/2018	0	19.03	0.00	0	1052.91	0.00	0	760.25	2.03	0	0.00	1832.2
2/21/2018	0	19.03	0.00	0	1052.91	0.00	0	761.36	1.11	0	0.00	1833.3
3/22/2018	0	19.03	0.00	0	1052.91	0.00	0	-	-	0	0.00	1833.3
4/23/2018	0	19.64	0.61	0	1062.85	9.94	0	797.49	36.13	0	0.00	1880.0
5/15/2018	0	19.64	0.00	0	1078.58	15.73	(1)	1023.51	226.01	0	0.00	2121.7
6/29/2018	2345	107.69	88.05	2628	1284.30	205.72	2680	1295.02	271.51	7653	17.05	2687.0
7/31/2018	2209	146.51 (3)	38.82	2225	1532.19	247.89	2640	1619.82	324.81	7074	15.76	3298.5
8/31/2018	2188	101.67 (3)	262.05	0	1685.95	153.76	1850	1839.49	219.66	4038	9.00	3934.0
9/28/2018	0	26.05	231.27	0	1745.65	59.70	0	1956.45	116.96	0	0.00	4341.9
10/31/2018	0	26.05	0.00		1745.65	0.00	0	1956.45	0.00	0	0.00	4341.9
11/30/2018	0	26.05	0.00	0	1745.65	0.00	0	1956.45	0.00	0	0.00	4341.9

(1)- Flow Meter Inoperative, (2) – Flow Meter Missing,

(3) – Flow meter totalizing in gallons, appears to be rolling over at 100 million gallons

The two Plant Wells were put into service in 2017 and both are equipped with electromagnetic flow meters. These wells are used year-round to supply water to the CS Beef Packers plant. From December 29, 2017 to December 21, 2018, Plant Well

No. 1 provided 637.50 acre-feet to the plant and Plant Well No. 2 supplied 541.58 acre-feet for a combined volume of 1,179.08 acre-feet. Table 4 provides a summary of the recorded instantaneous and totalized flows from the Plant Wells.

Table 3. Plant Wells Monthly Flow Monitoring

Date	Plant Well #1		Plant Well #2	
	Flow (gpm)	Totalizer (af)	Flow (gpm)	Totalizer (af)
7/25/2017	1247	0	0	3.87
8/30/2017	1245	0	0	17.56
10/2/2017	1236	0	0	54.80
11/17/2017	1237	637.28	0	120.64
12/29/2017	1243	713.18	0	175.56
1/24/2018	1242	760.99	0	207.24
2/21/2018	1252	819.42	0	240.75
3/22/2018	1241	876.47	0	279.58
4/23/2018	1242	934.17	0	325.00
5/15/2018	1238	979.28	0	359.06
6/29/2018	1115	1061.74	0	440.39
7/31/2018	1113	1108.76	0	491.91
8/31/2018	1116	1158.01	0	547.46
9/28/2018	1112	1208.13	0	583.27
10/31/2018	1113	1262.36	0	633.11
11/30/2018	1113	1313.39	0	683.69
12/21/2018	1113	1350.68	0	717.14

### 3. SUMMARY

1. Monitoring was conducted in 2018 as required for permits 63-32680, 63-33296, 63-33207, 63-34038, 63-34202, and 63-34221.
2. Irrigation Well No. 1 has a pinched sounding tube; the transducer cannot fit down the tube but water levels can be measured. There is a large amount of oil in the well which makes water-level measurements with a sounder difficult. The transducer which was removed from the well in November 2016 has not been replaced. A new transducer was installed in the nearby Drill Water Supply Well during January 2018 to act as a replacement data collection location for Irrigation Well No. 1.
3. The Irrigation Well No. 2 pump seized up in August 2018 and was removed for repairs at that time. The monitoring tube and airline were also removed from the

well at this time. The airline was reinstalled with the pump in September, but the monitoring tube was not reinstalled until October. As a result, there is a transducer data gap from August to October 2018. There were no other issues with monitoring this well.

4. Irrigation Well No. 3 was utilized throughout the 2018 irrigation season. A new water level transducer was installed in December 2017. The transducer appeared to hang up just over 5 feet about its usual depth during the January 2018 monitoring event, but was returned to the usual hanging depth in March 2018. It is unlikely water level readings were affected since the transducer was still submerged even at the shorter set depth. There seems to be a thick layer of oil in the well based on attempts to use a sounder which makes manual water level measurement difficult.
5. Irrigation Well No. 4 was brought online towards the end of the 2018 irrigation season. An airline has been installed in the well, but no sounder access is available and the airline water level measurements are suspect. The first full irrigation season for this well will be in 2019.
6. Irrigation diversions in 2018 occurred from Irrigation Wells No. 1, No. 2, and No. 3. Total diversion volumes for the three wells was determined based on totalizer readings collected from each of the well sites. The combined total diversion volume was approximately 2,511.7 acre-feet in 2018 with 620.8 acre-feet from Well No. 1, 692.7 acre-feet from Well No. 2, and 1,198.22 acre-feet from Well No. 3.
7. The 2018 water-level fluctuation in the monitoring well was approximately 7 feet. There was an approximate 1-foot water level decrease between November 2017 and November 2018.
8. Plant Wells #1 (East) and #2 (West) were used throughout 2018 to supply industrial water for the CS Beef Packers plant. The wells are equipped with airlines for water level measurements and electromagnetic flow meters. Total combined diversion volume was approximately 1,179 acre-feet in 2018 based on readings from the flow meter totalizers.

**Appendix A**  
**Water Right Reports**

Close

IDAHO DEPARTMENT OF WATER RESOURCES  
Water Permit Report

2/5/2017

WATER RIGHT NO. 63-32680

<u>Owner Type</u>	<u>Name and Address</u>
Current Owner	CS PROPERTY DEVELOPMENT LLC PO BOX 27 BOISE, ID 83707 (208)336-2110
Original Owner	BOISE INVESTMENT GROUP LLC C/O NICK FERGIS 12515 COUNTY RD 22 CORTEZ, CO 81321 (602)980-8182
Original Owner	AZEL DEVELOPMENT GROUP LLC
Original Owner	KUNA COLE 880
Original Owner	NOELLE HOLDINGS LLC C/O NICK FERGIS BOISE INVESTMENT GROUP LLC 12515 COUNTY RD 22 CORTEZ, CO 81321 (602)980-8182
Security Interest	WELLS FARGO BANK FOOD & AGRIBUSINESS COMMERCIAL BANKING OFFICE 905 S FILLMORE STE 701 MAC T3005-072 AMARILLO, TX 79101 806-371-3769

Priority Date: 05/22/2007

Status: Active

<u>Source</u>	<u>Tributary</u>
GROUND WATER	

<u>Beneficial Use</u>	<u>From</u>	<u>To</u>	<u>Diversion Rate</u>	<u>Volume</u>
IRRIGATION	03/01	11/15	5.22 CFS	
Total Diversion			5.22 CFS	

Location of Point(s) of Diversion:

GROUND WATER	SWSE	Sec. 11	Township 01N	Range 01E	ADA County
GROUND WATER	SESE	Sec. 11	Township 01N	Range 01E	ADA County
GROUND WATER	NENE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWNE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	SWNE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	SENE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NESE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWSE	Sec. 14	Township 01N	Range 01E	ADA County

Place(s) of use:

Place of Use Legal Description: IRRIGATION ADA County

<u>Township</u>	<u>Range</u>	<u>Section</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>
01N	01E	11		SWSE	40		SESE	40						
		12		NENW	40		NWNW	40		SWNW	40		SENE	40
				NESW	40		NWSW	40		SWSW	40		SESW	40
				NWSE	40		SWSE	40		SESE	40			
		13		NENE	40		NWNE	40		SWNE	40		SENE	40
				NENW	40		NWNW	40						
				NESE	40									
		14		NENE	40		NWNE	40		SWNE	40		SENE	40
				SWNW	40		SENE	40						
				NESW	40		NWSW	40		SWSW	40		SESW	40
				NESE	40		NWSE	40		SWSE	40		SESE	40
		23		NENE	40		NWNE	40						
				NENW	40		NWNW	40						
		24		NENW	40		NWNW	40		SWNW	40		SENE	40

Total Acres: 1680

Conditions of Approval:

1. Rights 63-32680 and 63-33296, when combined, shall not exceed a total diversion rate of 11.76 cfs, a total annual maximum diversion volume of 3,528 af at the field headgate, and the irrigation of 784 acres.
2. This right is limited to the irrigation of 261 acres within the place of use described above in a single irrigation season.  
Diversion and use of water in connection with this right is subject to a Monitoring Plan approved by the Department. In the event of a failure to comply with any component of the Monitoring Plan, after actual notice and a reasonable opportunity to cure, the right holder shall cease further diversions under the right until such noncompliance is remedied. Failure to comply with any approval condition, including the Monitoring Plan, shall be cause for the Department to cancel or revoke this right, or for an administrative or judicial action enjoining use of the right after actual notice and a reasonable opportunity to cure.
3. Proof of application of water to beneficial use shall be submitted no sooner than July 1, 2017 and no later than July 1, 2018.
4. No less than four (4) years of ground water monitoring data shall be submitted in connection with filing proof of beneficial use for this right. The right holder shall also submit a report from a qualified professional engineer, hydrologist, or hydrogeologist summarizing hydrogeologic data collected to fulfill the approved Monitoring Plan and the conditions of approval of this right. Submittal of a proof of beneficial use statement without the required report will not be accepted by the Department and may result in lapsing or cancellation of the permit.
5. Prior to submitting proof of beneficial use, the right holder shall not assign ownership of the permit to another individual, corporation, partnership, or association without prior notification to the Department.
6. Project construction shall commence within one year from the date of permit issuance and shall proceed diligently to completion unless it can be shown to the satisfaction of the Director of the Department of Water Resources that delays were due to circumstances over which the permit holder had no control.
7. 26A Diversion and use of water with a temperature greater than 85 degrees Fahrenheit is not authorized under his right.
8. Right holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code and applicable Well Construction Rules of the Department.
9. 046 The Director retains jurisdiction to require the right holder to provide purchased or leased natural flow or stored water to offset depletion of Lower Snake River flows if needed for salmon migration purposes. The amount of water required to be released into the Snake River or a tributary, if needed for this purpose, will be determined by the Director based upon the reduction in flow caused by the use of water pursuant to this permit.
10. 121 This right does not grant any right-of-way or easement across the land of another.
11. 004 This right when combined with all other rights shall provide no more than 0.02 cfs per acre nor more than 4.5 afa per acre at the field headgate for irrigation of the place of use.
12. R65 This right authorizes the construction of 2 supply wells as points of diversion.
13. The Department shall be notified prior to the installation and calibration of flow meters on all supply wells.
- 14.

Dates:

Proof Due Date: 07/01/2018

Proof Made Date:

Approved Date: 07/17/2013

Moratorium Expiration Date:

Enlargement Use Priority Date:

Enlargement Statute Priority Date:

Application Received Date: 09/07/2016

Protest Deadline Date: 01/02/2017

Number of Protests: 0

Field Exam Date::

Date Sent to State Off:

Date Received at State Off:

Other Information:

State or Federal:

Owner Name Connector:

Water District Number:

Generic Max Rate per Acre: 0.02

Generic Max Volume per Acre: 4.5

Swan Falls Trust or Nontrust:

Swan Falls Dismissed:

DLE Act Number:

Cary Act Number:

Mitigation Plan: False

Close

IDAHO DEPARTMENT OF WATER RESOURCES  
Water Application Report

2/5/2017

WATER RIGHT NO. 63-33207

<u>Owner Type</u>	<u>Name and Address</u>
Current Owner	CS PROPERTY DEVELOPMENT LLC PO BOX 27 BOISE, ID 83707 (208)336-2110
Original Owner	JIM HUTCHINGS 13690 S CLOVERDALE RD KUNA, ID 83634 (208)362-2963
Security Interest	WELLS FARGO BANK FOOD & AGRIBUSINESS COMMERCIAL BANKING OFFICE 905 S FILLMORE STE 701 MAC T3005-072 AMARILLO, TX 79101 806-371-3769

Priority Date: 03/24/2010

Status: Active

<u>Source</u>	<u>Tributary</u>
GROUND WATER	

<u>Beneficial Use</u>	<u>From</u>	<u>To</u>	<u>Diversion Rate</u>	<u>Volume</u>
INDUSTRIAL	01/01	12/31	3 CFS	
Total Diversion			3 CFS	

Location of Point(s) of Diversion:

GROUND WATER	SWSE	Sec. 11	Township 01N	Range 01E	ADA County
GROUND WATER	SESE	Sec. 11	Township 01N	Range 01E	ADA County
GROUND WATER	SWNW	Sec. 12	Township 01N	Range 01E	ADA County
GROUND WATER	SENE	Sec. 12	Township 01N	Range 01E	ADA County
GROUND WATER	NWNE	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NWNW	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NESE	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NENE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWNE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	SWNE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	SENE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NESE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWSE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWSW Lt 6	Sec. 06	Township 01N	Range 02E	ADA County
GROUND WATER	NWSW Lt 6	Sec. 06	Township 01N	Range 02E	ADA County
GROUND WATER	SWSW Lt 7	Sec. 06	Township 01N	Range 02E	ADA County
GROUND WATER	SWSW Lt 7	Sec. 06	Township 01N	Range 02E	ADA County

Place(s) of use:

Place of Use Legal Description: INDUSTRIAL ADA County

<u>Township</u>	<u>Range</u>	<u>Section</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>
01N	01E	11		SWSE			SESE							
		12		NENW			NWNW			SWNW			SENE	
				NESW			NWSW			SWSW			SESW	
				NWSE			SWSE			SESE				
		13		NENE			NWNE			SWNE			SENE	
				NENW			NWNW							
				NESE										
		14		NENE			NWNE			SWNE			SENE	
				NESE			NWSE							
		23		NENE			NWNE							
				NENW			NWNW							
		24		NENW			NWNW			SWNW			SENE	
	02E	6		NESW		6	NWSW		7	SWSW			SESW	
				NWSE			SWSE							

Conditions of Approval:

1. 004 This right does not grant any right-of-way or easement across the land of another.  
The right holder shall install a measuring device acceptable to the Department at the points of diversion authorized under this right. The measuring device shall be capable of displaying diversion flow rate and totalized volume measurement. The right holder shall record the flow rate and volume measurements monthly for any calendar year in which water is diverted and used in connection with this right until notified by the Department. The records shall be made available to the Department upon request.
- 2.
3. 073 Diversion and use of water with a temperature greater than 85 degrees Fahrenheit is not authorized under this right.
4. Use of water under this permit shall not exceed an annual diversion volume of 700 acre-feet. If the Department determines, based on credible evidence, measurement reports, area data, or otherwise, there is a substantial likelihood that diversion and use of groundwater under this right is causing material injury to any senior water right(s), the Department may issue an order to the right holder to show cause why existing diversions should not be reduced under the permit, forego additional diversions, or provide adequate mitigation to remedy any such material injury. Any senior water user alleging material injury may petition the Department to commence a show cause hearing, and the Department shall conduct a hearing.
- 5.
6. 121 The Director retains jurisdiction to require the right holder to provide purchased or leased natural flow or stored water to offset depletion of Lower Snake River flows if needed for salmon migration purposes. The amount of water required to be released into the Snake River or a tributary, if needed for this purpose, will be determined by the Director based upon the reduction in flow caused by the use of water pursuant to this permit.
7. Industrial use is for a meat processing and packing facility.
8. One point of diversion (well) authorized for this right shall include a measuring device or other suitable method to allow measurement of the static water level in the well. Water level measurements shall be made monthly throughout the year from the beginning of the diversion and use of water in connection with this right until notified by the Department. The records shall be made available to the Department upon request.
9. 196 The right holder shall install or construct a straight length of conduit or ditch suitable for installation of a device for measuring the entire flow of water being diverted in connection with this right. If the right holder uses conduit, the straight length of conduit shall be at least fifteen times the diameter of the conduit and shall be above ground or otherwise easily accessible.
10. 046 Right holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code and applicable Well Construction Rules of the Department.
11. 069 Failure of the right holder to comply with any condition of approval is cause for the Director to cancel this permit.
12. 26A Project construction shall commence within one year from the date of permit issuance and shall proceed diligently to completion unless it can be shown to the satisfaction of the Director of the Department of Water Resources that delays were due to circumstances over which the permit holder had no control.
13. Proof of application of water to beneficial use shall be submitted no sooner than October 1, 2017, and no later than October 1, 2018. A report with no less than 4 years of diversion measurement and aquifer level water monitoring data shall be submitted in connection with filing proof of beneficial use. Submittal of a proof of beneficial use statement without the required report will not be accepted by the Department and may result in cancellation of the permit.

Dates:

Date Application Received: 09/07/2016

Date Application Denied:

Last Date of Beneficial Use:

Extension End Date:

Protest Deadline Date: 1/2/2017

Number of Protests: 0

Enlargement Use Priority Date:

Enlargement Statute Priority Date:

Other Information:

State or Federal:

Owner Name Connector:

Water District Number:

Generic Max Rate per Acre:

Generic Max Volume per Acre:

Application Type: Amendment

Applicant Remarks: The proposed change is to increase the size of the place of industrial use.

Other Water Rights:

Time to Complete Works:

Transfer Affected Description:

Transfer Affected Contracts:

Old Transfer Number:

Transfer Reason:

Transfer Return Flows:

Swan Falls Trust or Nontrust:

Swan Falls Dismissed:

DLE Act Number:

Cary Act Number:

Mitigation Plan: False

Close

Close

IDAHO DEPARTMENT OF WATER RESOURCES  
Water Permit Report

2/5/2017

WATER RIGHT NO. 63-33296

<u>Owner Type</u>	<u>Name and Address</u>
Current Owner	CS PROPERTY DEVELOPMENT LLC PO BOX 27 BOISE, ID 83707 (208)336-2110
Original Owner	BOISE INVESTMENT GROUP LLC C/O NICK FERGIS 12515 COUNTY RD 22 CORTEZ, CO 81321 (602)980-8182
Original Owner	KUNA COLE 880 LLC C/O NICK FERGIS BOISE INVESTMENT GROUP 12515 COUNTY RD 22 CORTEZ, CO 81321 (208)383-4140
Original Owner	AZEL DEVELOPMENT GROUP LLC
Original Owner	NOELLE HOLDINGS LLC C/O NICK FERGIS BOISE INVESTMENT GROUP LLC 12515 COUNTY RD 22 CORTEZ, CO 81321 (602)980-8182
Security Interest	WELLS FARGO BANK FOOD & AGRIBUSINESS COMMERCIAL BANKING OFFICE 905 S FILLMORE STE 701 MAC T3005-072 AMARILLO, TX 79101 806-371-3769

Priority Date: 11/06/2009

Status: Active

Source | Tributary  
 GROUND WATER |

<u>Beneficial Use</u>	<u>From</u>	<u>To</u>	<u>Diversion Rate</u>	<u>Volume</u>
IRRIGATION	03/01	11/15	10.46 CFS	
Total Diversion			10.46 CFS	

Location of Point(s) of Diversion:

GROUND WATER	SWNW	Sec. 12	Township 01N	Range 01E	ADA County
GROUND WATER	SENW	Sec. 12	Township 01N	Range 01E	ADA County
GROUND WATER	NWNE	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NWNW	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NESE	Sec. 13	Township 01N	Range 01E	ADA County

Place(s) of use:

Place of Use Legal Description: IRRIGATION ADA County

<u>Township</u>	<u>Range</u>	<u>Section</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>
01N	01E	11		SWSE	40		SESE	40						
		12		NENW	40		NWNW	40		SWNW	40		SENW	40
				NESW	40		NWSW	40		SWSW	40		SESW	40
				NWSE	40		SWSE	40		SESE	40			
		13		NENE	40		NWNE	40		SWNE	40		SENE	40
				NENW	40		NWNW	40						
				NESE	40									
		14		NENE	40		NWNE	40		SWNE	40		SENE	40
				SWNW	40		SENW	40						
				NESW	40		NWSW	40		SWSW	40		SESW	40
				NESE	40		NWSE	40		SWSE	40		SESE	40
		23		NENE	40		NWNE	40						
				NENW	40		NWNW	40						
		24		NENW	40		NWNW	40		SWNW	40		SENW	40

Total Acres: 1680

Conditions of Approval:

1. Rights 63-32680 and 63-33296, when combined, shall not exceed a total diversion rate of 11.76 cfs, a total annual maximum diversion volume of 3,528 af at the field headgate, and the irrigation of 784 acres.
2. This right is limited to the irrigation of 523 acres within the place of use described above in a single irrigation season.  
Diversion and use of water in connection with this right is subject to a Monitoring Plan approved by the Department. In the event of a failure to comply with any component of the Monitoring Plan, after actual notice and a reasonable opportunity to cure, the right holder shall cease further diversions under the right until such noncompliance is remedied. Failure to comply with any approval condition, including the Monitoring Plan, shall be cause for the Department to cancel or revoke this right, or for an administrative or judicial action enjoining use of the right after actual notice and a reasonable opportunity to cure.
3. Proof of application of water to beneficial use shall be submitted no sooner than July 1, 2017 and no later than July 1, 2018.  
No less than four (4) years of ground water monitoring data shall be submitted in connection with filing proof of beneficial use for this right. The right holder shall also submit a report from a qualified professional engineer, hydrologist, or hydrogeologist summarizing hydrogeologic data collected to fulfill the approved Monitoring Plan and the conditions of approval of this right. Submittal of a proof of beneficial use statement without the required report will not be accepted by the Department and may result in lapsing or cancellation of the permit.
4. Prior to submitting proof of beneficial use, the right holder shall not assign ownership of the permit to another individual, corporation, partnership, or association without prior notification to the Department.
5. Project construction shall commence within one year from the date of permit issuance and shall proceed diligently to completion unless it can be shown to the satisfaction of the Director of the Department of Water Resources that delays were due to circumstances over which the permit holder had no control.
6. 26A Diversion and use of water with a temperature greater than 85 degrees Fahrenheit is not authorized under his right.
7. 046 Right holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code and applicable Well Construction Rules of the Department.  
The Director retains jurisdiction to require the right holder to provide purchased or leased natural flow or stored water to offset depletion of Lower Snake River flows if needed for salmon migration purposes. The amount of water required to be released into the Snake River or a tributary, if needed for this purpose, will be determined by the Director based upon the reduction in flow caused by the use of water pursuant to this permit.
8. 121 This right does not grant any right-of-way or easement across the land of another.
9. 004 This right when combined with all other rights shall provide no more than 0.02 cfs per acre nor more than 4.5 afa per acre at the field headgate for irrigation of the place of use.
10. R65 This right authorizes the construction of 2 supply wells as points of diversion.
11. The Department shall be notified prior to the installation and calibration of flow meters on all supply wells.
12. 004
- 13.
- 14.

Dates:

Proof Due Date: 07/01/2018

Proof Made Date:

Approved Date: 07/17/2013

Moratorium Expiration Date:

Enlargement Use Priority Date:

Enlargement Statute Priority Date:

Application Received Date: 09/07/2016

Protest Deadline Date: 01/02/2017

Number of Protests: 0

Field Exam Date::

Date Sent to State Off:

Date Received at State Off:

Other Information:

State or Federal:

Owner Name Connector:

Water District Number:

Generic Max Rate per Acre: 0.02

Generic Max Volume per Acre: 4.5

Swan Falls Trust or Nontrust:

Swan Falls Dismissed:

DLE Act Number:

Cary Act Number:

Mitigation Plan: False

Close

Close

IDAHO DEPARTMENT OF WATER RESOURCES  
Water Permit Report

2/5/2017

WATER RIGHT NO. 63-34038

<u>Owner Type</u>	<u>Name and Address</u>
Current Owner	CS PROPERTY DEVELOPMENT LLC PO BOX 27 BOISE, ID 83707 (208)336-2110
Original Owner	J R SIMPLOT COMPANY PO BOX 27 BOISE, ID 83707 (208)336-2110
Security Interest	WELLS FARGO BANK FOOD & AGRIBUSINESS COMMERCIAL BANKING OFFICE 905 S FILLMORE STE 701 MAC T3005-072 AMARILLO, TX 79101 806-371-3769

Priority Date: 06/26/2015

Status: Active

<u>Source</u>	<u>Tributary</u>
GROUND WATER	

<u>Beneficial Use</u>	<u>From</u>	<u>To</u>	<u>Diversion Rate</u>	<u>Volume</u>
IRRIGATION	03/01	11/15	3.2 CFS	
INDUSTRIAL	01/01	12/31	4 CFS	
Total Diversion			4 CFS	

Location of Point(s) of Diversion:

GROUND WATER	SWSE	Sec. 11	Township 01N	Range 01E	ADA County
GROUND WATER	SESE	Sec. 11	Township 01N	Range 01E	ADA County
GROUND WATER	SWNW	Sec. 12	Township 01N	Range 01E	ADA County
GROUND WATER	SENE	Sec. 12	Township 01N	Range 01E	ADA County
GROUND WATER	NWNE	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NWNW	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NESE	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NENE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWNE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	SWNE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	SENE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NESE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWSE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWSW Lt 6	Sec. 06	Township 01N	Range 02E	ADA County
GROUND WATER	NWSW Lt 6	Sec. 06	Township 01N	Range 02E	ADA County
GROUND WATER	SWSW Lt 7	Sec. 06	Township 01N	Range 02E	ADA County
GROUND WATER	SWSW Lt 7	Sec. 06	Township 01N	Range 02E	ADA County

INDUSTRIAL Use:

Number of other uses: meat process & packing

Place(s) of use:

Place of Use Legal Description: IRRIGATION ADA County

<u>Township</u>	<u>Range</u>	<u>Section</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>
01N	01E	11		SWSE	40		SESE	40						
		12		NENW	40		NWNW	40		SWNW	40		SENE	40
				NESW	40		NWSW	40		SWSW	40		SESW	40
				NWSE	40		SWSE	40		SESE	40			
		13		NENE	40		NWNE	40		SWNE	40		SENE	40
				NENW	40		NWNW	40						
				NESE	40									
		14		NENE	40		NWNE	40		SWNE	40		SENE	40
				SWNW	40		SENE	40						
				NESW	40		NWSW	40		SWSW	40		SESW	40
				NESE	40		NWSE	40		SWSE	40		SESE	40
		23		NENE	40		NWNE	40						
				NENW	40		NWNW	40						
		24		NENW	40		NWNW	40		SWNW	40		SENE	40

Place of Use Legal Description: INDUSTRIAL ADA County

<u>Township</u>	<u>Range</u>	<u>Section</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>
01N	01E	11		SWSE			SESE							
		12		NENW			NWNW			SWNW			SENE	
				NESW			NWSW			SWSW			SESE	
				NWSE			SWSE			SESE				
		13		NENE			NWNE			SWNE			SENE	
				NENW			NWNW			SWNW			SENE	
				NESW			NWSW			SWSW			SESE	
				NESE			SWSE			SESE				
		14		NENE			NWNE			SWNE			SENE	
				NESE			NWSE							
		23		NENE			NWNE							
				NENW			NWNW							
		24		NENW			NWNW			SWNW			SENE	
	02E	6		NESW			SESW							
				NWSE			SWSE							

Total Acres: 1680

Conditions of Approval:

1. 26A Project construction shall commence within one year from the date of permit issuance and shall proceed diligently to completion unless it can be shown to the satisfaction of the Director of the Department of Water Resources that delays were due to circumstances over which the permit holder had no control.
2. Each point of diversion (well) authorized for this right shall include a measuring device or other suitable method to allow measurement of the static water level in the well. Water level measurements shall be made monthly throughout the year from the beginning of the diversion and use of water in connection with this right until notified by the Department. The records shall be made available to the Department upon request.
3. 196 The right holder shall install or construct a straight length of conduit or ditch suitable for installation of a device for measuring the entire flow of water being diverted in connection with this right. If the right holder uses conduit, the straight length of conduit shall be at least fifteen times the diameter of the conduit and shall be above ground or otherwise easily accessible.
4. The right holder shall install a measuring device acceptable to the Department at each point of diversion authorized under this right. The measuring device shall be capable of displaying diversion flow rate and totalized volume measurement. The right holder shall record the flow rate and volume measurements monthly for any calendar year in which water is diverted and used in connection with this right until notified by the Department. The records shall be made available to the Department upon request.

5. 073 Diversion and use of water with a temperature greater than 85 degrees Fahrenheit is not authorized under this right.
6. If the Department determines based on credible evidence, measurement reports, area data or otherwise that diversion and use of ground water under this right is causing material injury to any senior water right(s), the Department may order the diversion reduced, the diversion curtailed, or the right holder to provide adequate mitigation to remedy the injury.
7. Prior to submitting proof of beneficial use, the right holder shall not assign ownership of the permit to another individual, corporation, partnership, or association without prior approval of the Department.
8. Proof of beneficial use may not be submitted until one month prior to the deadline to submit proof of beneficial use set forth in these conditions; provided, however, if less than four (4) years of ground water monitoring data have been collected while beneficial use authorized under this permit has occurred, then an extension of time for up to five additional years shall be requested by the permit holder. The permit holder shall submit a report from a qualified professional engineer, hydrologist, or hydrogeologist summarizing hydrogeologic data collected to fulfill the conditions of approval of this permit. Submittal of a proof of beneficial use statement without the required data and report will not be accepted by the Department and may result in lapse of the permit.
9. 046 Right holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code and applicable Well Construction Rules of the Department.
10. R65 This right when combined with all other rights shall provide no more than 0.02 cfs per acre nor more than 4.5 afa per acre at the field headgate for irrigation of the place of use.
11. 121 The Director retains jurisdiction to require the right holder to provide purchased or leased natural flow or stored water to offset depletion of Lower Snake River flows if needed for salmon migration purposes. The amount of water required to be released into the Snake River or a tributary, if needed for this purpose, will be determined by the Director based upon the reduction in flow caused by the use of water pursuant to this permit.
12. 069 Failure of the right holder to comply with any condition of approval is cause for the Director to cancel this permit.

Dates:

Proof Due Date: 11/01/2020

Proof Made Date:

Approved Date: 10/26/2015

Moratorium Expiration Date:

Enlargement Use Priority Date:

Enlargement Statute Priority Date:

Application Received Date: 09/07/2016

Protest Deadline Date: 01/02/2017

Number of Protests: 0

Field Exam Date::

Date Sent to State Off:

Date Received at State Off:

Other Information:

State or Federal:

Owner Name Connector:  
Water District Number:  
Generic Max Rate per Acre: 0.02  
Generic Max Volume per Acre: 4.5  
Swan Falls Trust or Nontrust:  
Swan Falls Dismissed:  
DLE Act Number:  
Cary Act Number:  
Mitigation Plan: False

# WATER RIGHT REPORT

4/25/2019

IDAHO DEPARTMENT OF WATER RESOURCES

Water Permit Report

WATER RIGHT NO. 63-34202

<u>Owner Type</u>	<u>Name and Address</u>
Current Owner	CS PROPERTY DEVELOPMENT LLC PO BOX 27 BOISE, ID 83707 2083362110
Security Interest	WELLS FARGO BANK FOOD & AGR BUSINESS COMMERCIAL BANK NG OFF CE 905 S F LLMORE STE 701 MAC T3005-072 AMARILLO, TX 79101 8063713769

Priority Date: 02/29/2016

Status: Active

<u>Source</u>	<u>Tributary</u>
GROUND WATER	

<u>Beneficial Use</u>	<u>From</u>	<u>To</u>	<u>Diversion Rate</u>	<u>Volume</u>
IRRIGATION	03/01	11/01	4.96 CFS	
Total Diversion			4.96 CFS	

Location of Point(s) of Diversion:

GROUND WATER	SWSE	Sec. 11	Township 01N	Range 01E	ADA County
GROUND WATER	SESE	Sec. 11	Township 01N	Range 01E	ADA County
GROUND WATER	SWNW	Sec. 12	Township 01N	Range 01E	ADA County
GROUND WATER	SENW	Sec. 12	Township 01N	Range 01E	ADA County
GROUND WATER	NWNE	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NWNW	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NESE	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NENE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWNE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	SWNE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	SENE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NESE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWSE	Sec. 14	Township 01N	Range 01E	ADA County

Place(s) of use:

Place of Use Legal Description: IRRIGATION ADA County

Township	Range	Section	Lot	Tract	Acres	Lot	Tract	Acres	Lot	Tract	Acres	Lot	Tract	Acres
01N	01E	14		SWSE	31		SESE	31						
		23		NENE	31		NWNE	31						
		24		NENW	31		NWNW	31		SWNW	31		SENW	31

Total Acres: 248

Conditions of Approval:

1. Each point of diversion (well) authorized for this right shall include a measuring device or other suitable method to allow measurement of the static water level in the well. Water level measurements shall be made monthly throughout the year from the beginning of the diversion and use of water in connection with this right until notified by the Department. The records shall be made available to the Department upon request.
2. The right holder shall install a measuring device acceptable to the Department at each point of diversion authorized under this right. The measuring device shall be capable of displaying diversion flow rate and totalized volume measurement. The right holder shall record the flow rate and volume measurements monthly for any calendar year in which water is diverted and used in connection with this right until notified by the Department. The records shall be made available to the Department upon request.
3. 073 Diversion and use of water with a temperature greater than 85 degrees Fahrenheit is not authorized under this right.
4. Proof of beneficial use may not be submitted until one month prior to the deadline to submit proof of beneficial use set forth in these conditions; provided, however, if less than four (4) years of ground water monitoring data have been collected while beneficial use authorized under this permit has occurred, then an extension of time for up to five additional years shall be requested by the permit holder. The permit holder shall submit a report from a qualified professional engineer, hydrologist, or hydrogeologist summarizing hydrogeologic data collected to fulfill the conditions of approval of this permit. Submittal of a proof of beneficial use statement without the required data and report will not be accepted by the Department and may result in lapse of the permit.
5. R65 This right when combined with all other rights shall provide no more than 0.02 cfs per acre nor more than 4.5 afa per acre at the field headgate for irrigation of the place of use.
6. 004 This right does not grant any right-of-way or easement across the land of another.
7. 26A Project construction shall commence within one year from the date of permit issuance and shall proceed diligently to completion unless it can be shown to the satisfaction of the Director of the Department of Water Resources that delays were due to circumstances over which the permit holder had no control.
8. 121 The Director retains jurisdiction to require the right holder to provide purchased or leased natural flow or stored water to offset depletion of Lower Snake River flows if needed for salmon migration purposes. The amount of water required to be released into the Snake River or a tributary, if needed for this purpose, will be determined by the Director based upon the reduction in flow caused by the use of water pursuant to this permit.
9. 046 Right holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code and applicable Well Construction Rules of the Department.
10. 069 Failure of the right holder to comply with any condition of approval is cause for the Director to cancel this permit.

Dates:

Proof Due Date: 05/01/2022

Proof Made Date:

Approved Date: 04/21/2017  
Moratorium Expiration Date:  
Enlargement Use Priority Date:  
Enlargement Statute Priority Date:  
Application Received Date: 02/29/2016  
Protest Deadline Date: 02/20/2017  
Number of Protests: 1  
Field Exam Date::  
Date Sent to State Off:  
Date Received at State Off:

Other Information:

State or Federal:  
Owner Name Connector:  
Water District Number: TBD  
Generic Max Rate per Acre: 0.02  
Generic Max Volume per Acre: 4.5  
Swan Falls Trust or Nontrust:  
Swan Falls Dismissed:  
DLE Act Number:  
Cary Act Number:  
Mitigation Plan: False

# WATER RIGHT REPORT

4/25/2019  
 IDAHO DEPARTMENT OF WATER RESOURCES  
 Water Permit Report  
 WATER RIGHT NO. 63-34221

<u>Owner Type</u>	<u>Name and Address</u>
Current Owner	CS PROPERTY DEVELOPMENT LLC PO BOX 27 BOISE, ID 83707 2083362110
Security Interest	WELLS FARGO BANK FOOD & AGR BUSINESS COMMERCIAL BANK NG OFF CE 905 S F LLMORE STE 701 MAC T3005-072 AMARILLO, TX 79101 8063713769

Priority Date: 02/02/2015  
 Status: Active

<u>Source</u>	<u>Tributary</u>
GROUND WATER	

<u>Beneficial Use</u>	<u>From</u>	<u>To</u>	<u>Diversion Rate</u>	<u>Volume</u>
IRRIGATION	03/01	11/15	0.44 CFS	
Total Diversion			0.44 CFS	

Location of Point(s) of Diversion:

GROUND WATER	SWSW Lt 7	Sec. 06	Township 01N	Range 02E	ADA County
GROUND WATER	SWSW Lt 7	Sec. 06	Township 01N	Range 02E	ADA County
GROUND WATER	SESW	Sec. 06	Township 01N	Range 02E	ADA County

IRRIGATION Use:

Acre Limit: 22

Place(s) of use:

Place of Use Legal Description: IRRIGATION ADA County

<u>Township</u>	<u>Range</u>	<u>Section</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>
01N	02E	6		NESW	40		SESW	40						
				NWSE	34		SWSE	33						

Total Acres: 147

Conditions of Approval:

- X27 This right is limited to the irrigation of 22 acres within the authorized place of use in a single irrigation season.

2. R65 This right when combined with all other rights shall provide no more than 0.02 cfs per acre nor more than 4.5 afa per acre at the field headgate for irrigation of the place of use.
3. Each authorized point of diversion constructed after issuance of this permit shall contain a dedicated sounding tube extending from above ground level to near the top of the pump bowls to facilitate groundwater-level measurements.
4. The right holder shall install a measuring device acceptable to the Department at each point of diversion authorized under this right. The measuring device shall be capable of displaying diversion flow rate and totalized volume measurement. The right holder shall record the flow rate and volume measurements monthly for any calendar year in which water is diverted and used in connection with this right until notified otherwise by the Department. The records shall be made available to the Department upon request.
5. Each point of diversion (well) authorized for this right shall include a measuring device or other suitable method to allow measurement of the static water level in the well. Water level measurements shall be made approximately thirty (30) days before the start and approximately thirty (30) days following cessation of seasonal irrigation from the beginning of the diversion and use of water in connection with this right until notified by the Department. The records shall be made available to the Department upon request.
6. At least one production well shall be equipped with a non-vented submersible pressure transducer/digital data logger suspended by stainless steel cable of a known length and at a depth that will allow the pressure transducer to always remain submerged. The submersible pressure transducer(s) shall be housed in a sounding tube. The data logger shall be set to collect two (2) water level and temperature readings per day on a year-round basis.
7. 020 The diversion and use of water described in this right may be subject to additional conditions and limitations agreed to by the protestant and the right holder under a separate agreement to which the Department is not a party. Because the Department is not a party, the Department is not responsible for enforcement of any aspect of the agreement not specifically addressed in other conditions herein. Enforcement of those portions of the agreement not specifically addressed in other conditions shall be the responsibility of the protestant and the water right holder.
8. Proof of beneficial use may not be submitted until one month prior to the deadline to submit proof of beneficial use set forth in these conditions; provided, however, if less than four (4) years of ground water monitoring data have been collected while beneficial use authorized under this permit has occurred, then an extension of time for up to five additional years shall be requested by the permit holder. The permit holder shall submit a report from a qualified professional engineer, hydrologist, or hydrogeologist summarizing hydrogeologic data collected to fulfill the conditions of approval of this permit. The report shall include raw water level measurements, barometrically corrected water level data, and diversion data. Submittal of a proof of beneficial use statement without the required data and report will not be accepted by the Department and may result in lapse of the permit.
9. 069 Failure of the right holder to comply with any condition of approval is cause for the Director to cancel this permit.
10. 046 Right holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code and applicable Well Construction Rules of the Department.
11. 004 This right does not grant any right-of-way or easement across the land of another.

12. 26A Project construction shall commence within one year from the date of permit issuance and shall proceed diligently to completion unless it can be shown to the satisfaction of the Director of the Department of Water Resources that delays were due to circumstances over which the permit holder had no control.
13. 121 The Director retains jurisdiction to require the right holder to provide purchased or leased natural flow or stored water to offset depletion of Lower Snake River flows if needed for salmon migration purposes. The amount of water required to be released into the Snake River or a tributary, if needed for this purpose, will be determined by the Director based upon the reduction in flow caused by the use of water pursuant to this permit.

Dates:

Proof Due Date: 10/01/2021

Proof Made Date:

Approved Date: 09/20/2016

Moratorium Expiration Date:

Enlargement Use Priority Date:

Enlargement Statute Priority Date:

Application Received Date: 08/16/2017

Protest Deadline Date: 03/05/2018

Number of Protests: 0

Field Exam Date::

Date Sent to State Off:

Date Received at State Off:

Other Information:

State or Federal:

Owner Name Connector:

Water District Number: TBD

Generic Max Rate per Acre: 0.02

Generic Max Volume per Acre: 4.5

Swan Falls Trust or Nontrust:

Swan Falls Dismissed:

DLE Act Number:

Cary Act Number:

Mitigation Plan: False

**Appendix B**  
**Well Driller's Reports for Production and**  
**Monitoring Wells**

# Plant Well 1

RECEIVED

Form 238-7  
6/07

## IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

OCT 06 2015

WATER RESOURCES  
WESTERN REGION

CP3

**1. WELL TAG NO. D** 0069003

Drilling Permit No. 948768-874825

Water right or injection well # \_\_\_\_\_

**2. OWNER:** JR Simplot Co.

Name \_\_\_\_\_

Address P.O. Box 27

City Boise State Idaho Zip 83707

**3. WELL LOCATION:**

Twp 1 North  or South  Rge 2 East  or West

Sec 6 NW 1/4 SW 1/4 \_\_\_\_\_

Gov't Lot: \_\_\_\_\_ County ADA

Lat. 43 26.841 (Deg and Decimal minutes)

Long. 116 16.380 (Deg and Decimal minutes)

Address of Well Site S. Cole Rd. 1/4 mile North of Barker

City Kuna

Lot \_\_\_\_\_ Blk \_\_\_\_\_ Sub Name \_\_\_\_\_

**4. USE:**

Domestic  Municipal  Monitor  Irrigation  Thermal  Injection  
 Other \_\_\_\_\_

**5. TYPE OF WORK:**

New well  Replacement well  Modify existing well  
 Abandonment  Other \_\_\_\_\_

**6. DRILL METHOD:**

Air Rotary  Mud Rotary  Cable  Other \_\_\_\_\_

**7. SEALING PROCEDURES:**

Seal material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method/procedure
Neat cement	188ft	0	9 yd3	pumped
Neat cement	315ft	0	11 yd3	pumped

**8. CASING/LINER:**

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
20"	0	188	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
14"	+2	395	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Was drive shoe used?  Y  N Shoe Depth(s) \_\_\_\_\_

**9. PERFORATIONS/SCREENS:**

Perforations  Y  N Method \_\_\_\_\_

Manufactured screen  Y  N Type Joston

Method of installation set in

From (ft)	To (ft)	Size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
395	455	30	60ft	14"	ss	.375

Length of Headpipe \_\_\_\_\_ Length of Tailpipe \_\_\_\_\_

Packer  Y  N Type \_\_\_\_\_

**10. FILTER PACK:**

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method
6-9	315	455	9850lbs	trimmie

**11. FLOWING ARTESIAN:**

Flowing Artesian?  Y  N Artesian Pressure (PSIG) \_\_\_\_\_

Describe control device plat

**12. STATIC WATER LEVEL and WELL TESTS:**

Depth first water encountered (ft) 315 Static water level (ft) 294

Water temp (°F) 83 Bottom hole temp. (°F) 83

Describe access port \_\_\_\_\_

**Well test:**

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
43.1	1520	7.7 hrs	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: \_\_\_\_\_

**13. LITHOLOGIC LOG and/or repairs or abandonment:**

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
24	0	2	top soil		
24	2	8	sandy dirt and gravel		
24	8	30	hard black lava		
24	30	38	broken soft black lava		
24	38	44	hard black lava		
24	44	48	soft red lava		
24	48	55	hard black lava		
24	55	77	soft black lava		
24	77	95	hard black lava		
24	95	105	soft black lava		
24	105	135	hard black lava		
24	135	145	soft black lava		
24	145	155	red cinders		
24	155	162	hard black lava		
24	162	177	hard black lava		
19	177	312	large gravel and sand		
19	312	315	rock and clay		
19	315	320	sand and gravel		
19	320	325	rock and clay		
19	325	402	sand and gravel		
19	402	425	white clay		
19	425	448	sand and gravel		
19	448	460	brown clay with gravel		
19	460	465	sand and gravel		
19	465	471	brown clay and little rock		
19	471	477	sand and gravel		
19	477	490	brown clay and rock		
19	490	523	big gravel and sand		
19	523	531	sand and gravel		
19	531	543	gravel and sand with clay		
19	543	555	sandstone		
19	555	560	gravel and sand		

Completed Depth (Measurable) 455

Date Started: 6/1/2015 Date Completed: 9/16/2015

**14. DRILLER'S CERTIFICATION:**

I/We certify that all minimum well construction standards were complied with at the time the rig was removed

Company Name Treasure Valley Drilling Co No 560

\*Principal Driller: [Signature] Date 9-22-15

\*Driller \_\_\_\_\_ Date \_\_\_\_\_

\*Operator II \_\_\_\_\_ Date \_\_\_\_\_

Operator I \_\_\_\_\_ Date \_\_\_\_\_

\* Signature of Principal Driller and rig operator are required

## IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0069003

Drilling Permit No \_\_\_\_\_  
Water right or injection well # \_\_\_\_\_

2. OWNER: J R Simplot Co.

Name \_\_\_\_\_

Address P.O. Box 27

City Boise State ID Zip 83707

3. WELL LOCATION:

Twp. 1 North  or South  Rge. 2 East  or West

Sec. 6 NW 1/4 SW 1/4

Gov't Lot \_\_\_\_\_ County Ada

Lat. \_\_\_\_\_ (Deg and Decimal minutes)

Long. \_\_\_\_\_ (Deg and Decimal minutes)

Address of Well Site S Cole Rd 1/4 mile north of center

City Kuna

Lot \_\_\_\_\_ Blk \_\_\_\_\_ Sub Name \_\_\_\_\_

4. USE:

Domestic  Municipal  Monitor  Irrigation  Thermal  Injection  
 Other \_\_\_\_\_

5. TYPE OF WORK:

New well  Replacement well  Modify existing well  
 Abandonment  Other \_\_\_\_\_

6. DRILL METHOD:

Air Rotary  Mud Rotary  Cable  Other \_\_\_\_\_

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method/procedure
Neat cement	188	0	13 Yards	Pumped
Neat cement	315	0	10 1/4 Yards	Pumped

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing Liner	Threaded	Welded
20"	0	188	.375	Steel Casing	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
14"	188	395	.375	Steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used?  Y  N Shoe Depth(s) \_\_\_\_\_

9. PERFORATIONS/SCREENS:

Perforations  Y  N Method \_\_\_\_\_

Manufactured screen  Y  N Type Alloy Screen

Method of installation Set in

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
395	455		60'		Stainless	.375

Length of Headpipe \_\_\_\_\_ Length of Tailpipe \_\_\_\_\_

Packer  Y  N Type \_\_\_\_\_

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method
6-9	315	455	9850 lbs	Tremie

11. FLOWING ARTESIAN:

Flowing Artesian?  Y  N Artesian Pressure (PSIG) \_\_\_\_\_

Describe control device \_\_\_\_\_

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft): 315 Static water level (ft) 294

Water temp (°F) 83 Bottom hole temp. (°F) 83

Describe access port \_\_\_\_\_

Well test:	Discharge or yield (gpm)	Test duration (minutes)	Test method:			
			Pump	Bailer	Air	Flowing artesian
33	200	60	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: \_\_\_\_\_

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
24"	0	2	TOP SOIL		
"	2	8	Sandy dirt/Gravel		
14"	8	30	Hard black lava		
	30	38	Broken soft Black lava		
	38	44	Hard black lava		
	44	48	soft + red lava		
	48	55	Hard black lava		
	55	77	Soft black lava		
	77	95	Hard black lava		
	95	105	Soft black lava		
	105	135	Hard black lava		
	135	145	Soft + black lava		
	145	155	red cinders		
	155	160	Hard black lava		
	160	177	Hard black lava		
19"	177	312	Big Gravel + Sand		
"	312	315	Rock + Clay		
14"	315	320	Sand + Gravel		
	320	335	rock + clay		
	335	402	Sand + Gravel		
	402	425	White Clay		
	425	448	Sand + Gravel		
	448	460	brn clay with gravel		
	460	465	Sand + Gravel		
	465	471	Brn Clay + little rock		
	471	477	Sand + Gravel		
	477	490	Brn clay + rock		
	490	523	Big Gravel + Sand		
	523	531	Sand + Gravel		
	531	543	Gravel + little clay		
	543	555	sandstone		
	555	560	Gravel + Sand		

Completed Depth (Measurable): 455

Date Started: 7-1-15 Date Completed: 8-30-15

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling and Pump #560

\*Principal Driller Shawn Mikela Date 9-28-15

\*Driller Shawn Mikela Date 9-28-15

\*Operator II \_\_\_\_\_ Date \_\_\_\_\_

Operator I \_\_\_\_\_ Date \_\_\_\_\_

\* Signature of Principal Driller and rig operator are required

RECEIVED

OCT 02 2015

WATER RESOURCES  
WESTERN DISTRICT

# Plant Well 2

Form 238-7  
6/07

## IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

**1. WELL TAG NO. D 0070211**  
 Drilling Permit No. 970455-876512  
 Water right or injection well # 63-33207  
**2. OWNER: JR Simplot Company**

Name \_\_\_\_\_  
 Address PO Box 27  
 City Boise State Idaho Zip 83707

**3. WELL LOCATION:**  
 Twp. 1 North  or South  Rge. 2 East  or West   
 Sec. 6 1/4 SW 1/4 SW 1/4

Gov't Lot 7 County \_\_\_\_\_  
 Lat. 43 ° 26.845 (Deg. and Decimal minutes)  
 Long. -116 ° 16.419 (Deg. and Decimal minutes)  
 Address of Well Site 150' East of south cole rd  
1075' North of Barker Rd City Near Kuna  
(Use at least three of road - Distance to Road or Landmark)  
 Lot. \_\_\_\_\_ Blk. \_\_\_\_\_ Sub. Name \_\_\_\_\_

**4. USE:**  
 Domestic  Municipal  Monitor  Irrigation  Thermal  Injection  
 Other Industrial

**5. TYPE OF WORK:**  
 New well  Replacement well  Modify existing well  
 Abandonment  Other \_\_\_\_\_

**6. DRILL METHOD:**  
 Air Rotary  Mud Rotary  Cable  Other \_\_\_\_\_

**7. SEALING PROCEDURES:**

Seal material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method/procedure
Neat cement	188	0	9yd3	pumped
Neat cement	315	0	11yd3	pumped

**8. CASING/LINER:**

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
26	0	11	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
20	+1	176	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
14	+1	395	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used?  Y  N Shoe Depth(s) \_\_\_\_\_

**9. PERFORATIONS/SCREENS:**  
 Perforations  Y  N Method \_\_\_\_\_  
 Manufactured screen  Y  N Type \_\_\_\_\_  
 Method of installation \_\_\_\_\_

From (ft)	To (ft)	Slot size	Numberft	Diameter (nominal)	Material	Gauge or Schedule
395	455	40	60	14	ss	375

Length of Headpipe \_\_\_\_\_ Length of Tailpipe \_\_\_\_\_  
 Packer  Y  N Type \_\_\_\_\_

**10. FILTER PACK:**

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method
silica sand	320	455	8400lbs	trimmie

**11. FLOWING ARTESIAN:**  
 Flowing Artesian?  Y  N Artesian Pressure (PSIG) \_\_\_\_\_  
 Describe control device plat

**12. STATIC WATER LEVEL and WELL TESTS:**  
 Depth first water encountered (ft) 290 Static water level (ft) 289  
 Water temp. (°F) 82 Bottom hole temp. (°F) 82  
 Describe access port \_\_\_\_\_

**Well test:**

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Test method:			
			Pump	Bailer	Air	Flowing artesian
338	2190	4hrs	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: \_\_\_\_\_

**13. LITHOLOGIC LOG and/or repairs or abandonment:**

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
32	0	1	top soil		X
32	1	11	bleachy basalt		
26	11	93	weathered basalt		
26	93	97	red cinders		
26	97	124	black basalt		
26	124	128	red cinders		
26	128	176	hard black basalt		
20	176	186	sand and gravel		
20	186	211	gravel and basalt boulders		
20	211	255	sand and gravel boulders		
20	255	286	cemented gravel		
20	286	290	sand and gravel		X
20	290	367	clay		
20	367	376	sand		
20	376	460	pea gravel and silty sand		

Completed Depth (Measurable) 455  
 Date Started: 9/10/2015 Date Completed: 9/30/2015

**14. DRILLER'S CERTIFICATION:**  
 I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling Co. No. 560  
 \*Principal Driller: [Signature] Date 9-30-15  
 \*Driller \_\_\_\_\_ Date \_\_\_\_\_  
 \*Operator II \_\_\_\_\_ Date \_\_\_\_\_  
 Operator I \_\_\_\_\_ Date \_\_\_\_\_

\* Signature of Principal Driller and rig operator are required

# Drill Water Supply Well (Monitoring)

Form 238-7  
6/07

## IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

**1. WELL TAG NO. D 0066263**

Drilling Permit No. \_\_\_\_\_  
Water right or injection well # \_\_\_\_\_

**2. OWNER**

Name Ray Montierth  
Address 825 Hartland Dr  
City Nampa State ID Zip 83686

**3. WELL LOCATION:**

Twp. 1 North  or South  Rge. 1 East  or West   
Sec. 14 1/4 SE 1/4 NE 1/4  
10 acres 40 acres 160 acres  
Gov't Lot \_\_\_\_\_ County ADA

Lat. 34 ° 25.612 (Deg. and Decimal minutes)  
Long. 116 ° 17.845 (Deg. and Decimal minutes)

Address of Well Site Cross tracks on Cole heading south first right  
1 mile left 1/2 mile left 1/4 mile City Kuna

Lot \_\_\_\_\_ Blk. \_\_\_\_\_ Sub. Name \_\_\_\_\_

**4. USE:**

Domestic  Municipal  Monitor  Irrigation  Thermal  Injection  
 Other

**5. TYPE OF WORK** check all that apply (Replacement etc.)

New Well  Replacement well  Modify existing well  
 Abandonment  Other

**6. DRILL METHOD:**

Air Rotary  Mud Rotary  Cable  Other

**7. SEALING PROCEDURES**

Seal material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method/procedure
Bentonite	0	38	950lbs	Pour

**8. CASING/LINER:**

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
6	+2	38	.230	Steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used?  Y  N Shoe Depth(s) \_\_\_\_\_

**9. PERFORATIONS/SCREENS:**

Perforations  Y  N Method \_\_\_\_\_  
Manufactured screen  Y  N Type \_\_\_\_\_  
Method of installation \_\_\_\_\_

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule

Length of Headpipe \_\_\_\_\_ Length of Tailpipe \_\_\_\_\_

Packer  Y  N Type \_\_\_\_\_

**10. FILTER PACK:**

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method
na	na	na	na na	na

**11. FLOWING ARTESIAN:**

Flowing Artesian?  Y  N Artesian Pressure (PSIG) \_\_\_\_\_  
Describe control device \_\_\_\_\_

**12. STATIC WATER LEVEL and WELL TESTS:**

Depth first water encountered (ft) 265 Static water level (ft) 230  
Water temp. (°F) 56 Bottom hole temp. (°F) \_\_\_\_\_  
Describe access port Cap

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Test method:			
			Pump	Bailer	Air	Flowing artesian
35	20	1HR	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

**Water Quality test or comments:**

**13. LITHOLOGIC LOG and/or repairs or abandonment:**

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
10	0	2	Top Soil		X
10	2	8	Sandy Clay		X
10	8	15	Brown Clay		X
10	15	34	Brown Sandy Clay		X
10	34	38	Broken up Lava		X
6	38	54	Lava		X
6	54	57	Red Lava		X
6	57	81	Black Lava		X
6	81	83	Red Lava		X
6	83	101	Black Lava		X
6	101	104	Brown Lava		X
6	104	232	Brown Lava		X
6	232	245	Fractured Lava		X
6	245	258	Lava		X
6	258	265	Brown Lava		X
6	265	270	Coarse Sand	X	
6	270	280	Lava		X
6	280		Gravel	X	

Completed Depth (Measurable) 270  
Date: Started 04/17/2014 Completed 4/20/2014

**14. DRILLER'S CERTIFICATION**

(We certify that all minimum well construction standards were complied with at the time the rig was removed.)

Company Name Treasure Valley Drilling Co. No. 560

\*Principal Driller \_\_\_\_\_ Date \_\_\_\_\_

\*Driller \_\_\_\_\_ Date \_\_\_\_\_

\*Operator II \_\_\_\_\_ Date \_\_\_\_\_

Operator I \_\_\_\_\_ Date \_\_\_\_\_

\* Signature of Principal Driller and rig operator are required.

# Irrigation Well 1

## IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

### 1. WELL TAG NO. D 0066300

Drilling Permit No. 965586-871645  
Water right or injection well # 63-32680

### 2. OWNER

Name Ray Montierth  
Address 825 Heartland Dr.  
City Nampa State Id Zip 83686

### 3. WELL LOCATION:

Twp. 1 North  or South  Rge. 1 East  or West   
Sec. 14 sw 1/4 ne 1/4 ne 1/4  
10 acres 40 acres 160 acres

Gov't Lot \_\_\_\_\_ County Ada  
Lat. 43 ° 25.967 (Deg. and Decimal minutes)  
Long. 116 ° 16.803 (Deg. and Decimal minutes)  
Address of Well Site 1 mi. w. of S.Cole Rd 1 mi. S. of railroad ROW  
City Kuna

(Give at least name of road + Distance to Road or Landmark)  
Lot. \_\_\_\_\_ Blk. \_\_\_\_\_ Sub. Name \_\_\_\_\_

### 4. USE:

Domestic  Municipal  Monitor  Irrigation  Thermal  Injection  
 Other \_\_\_\_\_

### 5. TYPE OF WORK check all that apply (Replacement etc.)

New Well  Replacement well  Modify existing well  
 Abandonment  Other \_\_\_\_\_

### 6. DRILL METHOD:

Air Rotary  Mud Rotary  Cable  Other \_\_\_\_\_

### 7. SEALING PROCEDURES

Seal material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method/procedure
<u>3/4 bentonite</u>	<u>0</u>	<u>38</u>	<u>23000 lbs</u>	<u>pour</u>
<u>cement</u>	<u>150</u>	<u>300</u>	<u>43 ft 3</u>	<u>trimmed</u>

### 8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
<u>26</u>	<u>0</u>	<u>38</u>	<u>.375</u>	<u>steel</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<u>20</u>	<u>0</u>	<u>149</u>	<u>.375</u>	<u>steel</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<u>16</u>	<u>1</u>	<u>150</u>	<u>.250</u>	<u>steel</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used?  Y  N Shoe Depth(s) \_\_\_\_\_

### 9. PERFORATIONS/SCREENS:

Perforations  Y  N Method \_\_\_\_\_  
Manufactured screen  Y  N Type Johnson  
Method of installation set in

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
<u>330</u>	<u>430</u>	<u>.40</u>	<u>100</u>	<u>16</u>	<u>ss</u>	<u>.375</u>
<u>440</u>	<u>540</u>	<u>.40</u>	<u>100</u>	<u>16</u>	<u>ss</u>	<u>.375</u>

Length of Headpipe na Length of Tailpipe \_\_\_\_\_

Packer  Y  N Type \_\_\_\_\_

### 10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method
<u>silico sand</u>	<u>80</u>	<u>540</u>	<u>23000 lbs</u>	<u>pour</u>

### 11. FLOWING ARTESIAN:

Flowing Artesian?  Y  N Artesian Pressure (PSIG) \_\_\_\_\_  
Describe control device \_\_\_\_\_

### 12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) \_\_\_\_\_ Static water level (ft) \_\_\_\_\_  
Water temp. (°F) 70 Bottom hole temp. (°F) 70  
Describe access port flat plat

#### Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)
<u>23</u>	<u>3300</u>	<u>20 hr</u>

#### Test method:

Pump  Bailer  Air  Flowing artesian

#### Water Quality test or comments:

### 13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
30	0	2	top soil		X
30	2	8	sandy clay		X
30	8	17	brown clay		X
30	17	35	brown sandy clay		X
30	35	38	broken up lava		X
25	38	73	lava		X
25	73	85	brown lava		X
25	85	130	lava		X
25	130	140	brown lava		X
25	140	153	fractured lava		X
25	153	175	red lava		X
25	175	186	brown lava		X
25	186	200	fractured lava		X
25	200	255	lava		X
25	255	266	brown lava		X
25	266	270	sand	X	
25	270	273	brown clay		X
25	273	278	lava		X
25	278	284	gravel	X	
20	284	291	corse sand		X
20	291	305	brown clay		X
20	305	317	brown sand	X	
20	317	335	brown clay		X
20	335	356	gravel	X	
20	356	360	brown clay		X
20	360	368	corse sand	X	
20	368	373	medium sand	X	
20	373	378	brown clay		X
20	378	381	brown sand	X	
20	381	389	gravel	X	
20	389	410	corse sand and gravel	X	
20	410	430	medium sand	X	

Completed Depth (Measurable) \_\_\_\_\_  
Date: Started 4-16-14 Completed \_\_\_\_\_

### 14. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling Co. No. 560

\*Principal Driller Monte Post Date 6-27-14

\*Driller [Signature] Date 7-31-14

\*Operator II \_\_\_\_\_ Date \_\_\_\_\_

Operator I Jeremy Bulluck Date 6-27-14

\*Signature of Principal Driller and rig operator are required

JUL 03 2014



63

# Irrigation Well 2

1 of 2

Form 238-7  
6/07

## IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

### 1. WELL TAG NO. D 0067448

Drilling Permit No. 967343-873402  
Water right or injection well # \_\_\_\_\_

### 2. OWNER:

Name Ray Montierth  
Address 825 Hartland  
City Nampa State ID Zip 83686

### 3. WELL LOCATION:

Twp. 1 North  or South  Rge. 1 East  or West   
Sec. 13 1/4 1/4 1/4

Gov't Lot \_\_\_\_\_ County ADA  
Lat. 43 ° 25.608 (Deg. and Decimal minutes)  
Long. 116 ° 17.611 (Deg. and Decimal minutes)  
Address of Well Site S. Cole

Lot \_\_\_\_\_ Blk. \_\_\_\_\_ Sub. Name \_\_\_\_\_  
City Kuna

### 4. USE:

Domestic  Municipal  Monitor  Irrigation  Thermal  Injection  
 Other \_\_\_\_\_

### 5. TYPE OF WORK:

New well  Replacement well  Modify existing well  
 Abandonment  Other \_\_\_\_\_

### 6. DRILL METHOD:

Air Rotary  Mud Rotary  Cable  Other \_\_\_\_\_

### 7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method/procedure
3/4 bentonite	0	39	4000 lbs	pour
concrete	270	300	3 1/2 yd	pumped

### 8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
26	0	39	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
20	1	284	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
16	270	350	.250	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
16	510	535	.250	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used?  Y  N Shoe Depth(s) \_\_\_\_\_

### 9. PERFORATIONS/SCREENS:

Perforations  Y  N Method \_\_\_\_\_

Manufactured screen  Y  N Type Alloy

Method of installation set in

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
350	510	.35	160	16	ss	.98
535	575	.35	40	16	ss	.98

Length of Headpipe 80 Length of Tailpipe \_\_\_\_\_

Packer  Y  N Type double wing k-packer

### 10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method
6/9 silica sand	305	575	16500 lbs	pour

### 11. FLOWING ARTESIAN:

Flowing Artesian?  Y  N Artesian Pressure (PSIG) \_\_\_\_\_

Describe control device \_\_\_\_\_

### 12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 293 Static water level (ft) 236

Water temp. (°F) 70 Bottom hole temp. (°F) 70

Describe access port flat plate

#### Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)
22	2980	6 hr

#### Test method:

Pump	Bailer	Air	Flowing artesian
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: \_\_\_\_\_

### 13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
30	0	3	top soil		x
30	3	27	sandy clay		x
30	27	35	corse sand		x
30	35	39	red clay		x
24	39	65	hard lava		x
24	65	69	red cinders		x
24	69	82	gray lava		x
24	82	87	red broken up lava		x
24	87	99	black lava		x
24	99	101	broken up lava		x
24	101	107	gray lava		x
24	107	111	red lava		x
24	111	122	gray lava		x
24	122	151	gray broken up lava		x
24	151	158	black broken up lava		x
24	158	170	brown and red cinders		x
24	170	223	gray lava		x
24	223	230	broken up lava		x
24	230	258	black lava		x
24	258	267	corse sand		x
24	267	286	brown lava		x
24	286	293	broken up lava		x
24	293	305	red cinders	x	
20	305	320	brown clay and red cinders		x
20	320	335	brown clay		x
20	335	370	gravel	x	
20	370	373	brown clay		x
20	373	429	corse sand and gravel	x	
20	429	431	brown clay		x
20	431	435	corse sand	x	
20	435	438	brown clay		x
20	438	445	gravel	x	

RECEIVED

JAN 05 2015

WATER RESOURCES  
WESTERN REGION

Completed Depth (Measurable): 575

Date Started: 9-14-14

Date Completed: 11-21-14

### 14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling Co. No. 560

\*Principal Driller Monte Post Date 11-30-14

\*Driller Jeremy Bullack Date 11-30-14

\*Operator II \_\_\_\_\_ Date \_\_\_\_\_

Operator I \_\_\_\_\_ Date \_\_\_\_\_

\* Signature of Principal Driller and rig operator are required.

63

2 of 2

Form 238-7  
6/07

# IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

### 1. WELL TAG NO. D 0067448

Drilling Permit No. 9167343-873402  
Water right or injection well # \_\_\_\_\_

### 2. OWNER:

Name Ray Montierth  
Address 825 Hartland  
City Nampa State Id Zip 83686

### 3. WELL LOCATION:

Twp. 1 North  or South  Rge. 1 East  or West   
Sec. 13 10 acres 1/4 NW 1/4 NW 1/4

Gov't Lot \_\_\_\_\_ County ada  
Lat. 43 ° 25.608 (Deg. and Decimal minutes)  
Long. 116 ° 17.611 (Deg. and Decimal minutes)  
Address of Well Site S.Cole

(Give at least name of road - Distance to Road or Landmark) City Kuna  
Lot \_\_\_\_\_ Blk. \_\_\_\_\_ Sub. Name \_\_\_\_\_

### 4. USE:

Domestic  Municipal  Monitor  Irrigation  Thermal  Injection  
 Other \_\_\_\_\_

### 5. TYPE OF WORK:

New well  Replacement well  Modify existing well  
 Abandonment  Other \_\_\_\_\_

### 6. DRILL METHOD:

Air Rotary  Mud Rotary  Cable  Other \_\_\_\_\_

### 7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method/procedure
3/4 bentonite	270	250	750 lbs	pour

### 8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing Liner			
					Threaded	Welded		
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Was drive shoe used?  Y  N Shoe Depth(s) \_\_\_\_\_

### 9. PERFORATIONS/SCREENS:

Perforations  Y  N Method \_\_\_\_\_

Manufactured screen  Y  N Type \_\_\_\_\_

Method of installation \_\_\_\_\_

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule

Length of Headpipe \_\_\_\_\_ Length of Tailpipe \_\_\_\_\_

Packer  Y  N Type \_\_\_\_\_

### 10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method

### 11. FLOWING ARTESIAN:

Flowing Artesian?  Y  N Artesian Pressure (PSIG) \_\_\_\_\_

Describe control device \_\_\_\_\_

### 12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 293 Static water level (ft) 236

Water temp. (°F) 70 Bottom hole temp. (°F) 70

Describe access port flat plate

### Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Test method:			
			Pump	Bailer	Air	Flowing artesian
22	2980	6 hr	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: \_\_\_\_\_

### 13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (In)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
20	445	447	brown clay		x
20	447	496	gravel	x	
20	496	511	brown clay		x
20	511	513	gravel	x	
20	513	516	brown clay		x
20	516	519	gravel	x	
20	519	536	brown clay		x
20	536	540	gravel	x	
20	540	547	brown clay		x
20	547	549	gravel	x	
20	549	551	brown clay		x
20	551	569	gravel	x	
20	569	575	brown clay		x

RECEIVED

JAN 05 2015

WATER RESOURCES  
WESTERN REGION

Completed Depth (Measurable): 575

Date Started: 9-14-14

Date Completed: 11-21-14

### 14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling Co. No. 560

\*Principal Driller Monte Post Date 11-30-14

\*Driller Jeremy Balllock Date 11-30-14

\*Operator II \_\_\_\_\_ Date \_\_\_\_\_

Operator I \_\_\_\_\_ Date \_\_\_\_\_

\* Signature of Principal Driller and rig operator are required.

# Irrigation Well 3

Form 238-7  
6/07

## IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

**1. WELL TAG NO. D** D0071844

Drilling Permit No. \_\_\_\_\_  
Water right or injection well # 63-33207-3403863-32680

**2. OWNER:**  
Name JR Simplot Company  
Address PO box 27  
City Boise State Idaho Zip 83707

**3. WELL LOCATION:**  
Twp 1 North  or South  Rge 1 East  or West   
Sec 14 1/4 NE 1/4 SE 1/4

Gov't Lot \_\_\_\_\_ County Ada  
Lat. 43 25.154 (Deg. and Decimal minutes)  
Long 116 17.628 (Deg. and Decimal minutes)  
Address of Well Site West of S. Cole rd. south of train tracks  
City Kuna

Lot \_\_\_\_\_ Blk. \_\_\_\_\_ Sub. Name \_\_\_\_\_

**4. USE:**  
 Domestic  Municipal  Monitor  Irrigation  Thermal  Injection  
 Other \_\_\_\_\_

**5. TYPE OF WORK:**  
 New well  Replacement well  Modify existing well  
 Abandonment  Other \_\_\_\_\_

**6. DRILL METHOD:**  
 Air Rotary  Mud Rotary  Cable  Other \_\_\_\_\_

**7. SEALING PROCEDURES:**

Seal material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method/procedure
3/8 chip	0	53	15800	overbore
3/8 chip	280	265	500lbs	overbore

**8. CASING/LINER:**

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
26	0	53	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
20	+1	280	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
16	257	345	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used?  Y  N Shoe Depth(s) \_\_\_\_\_

**9. PERFORATIONS/SCREENS:**  
Perforations  Y  N Method \_\_\_\_\_  
Manufactured screen  Y  N Type Johnson S.S.  
Method of installation set in

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
545	345	.040		16"	S.S	250

Length of Headpipe \_\_\_\_\_ Length of Tailpipe \_\_\_\_\_  
Packer  Y  N Type Double k 257-255

**10. FILTER PACK:**

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method
6-9 silica	545	273	8700lbs	overbore

**11. FLOWING ARTESIAN:**  
Flowing Artesian?  Y  N Artesian Pressure (PSIG) \_\_\_\_\_  
Describe control device \_\_\_\_\_

**12. STATIC WATER LEVEL and WELL TESTS:**  
Depth first water encountered (ft) 280 Static water level (ft) 270  
Water temp. (°F) 74 Bottom hole temp. (°F) \_\_\_\_\_  
Describe access port flat plate

Well test:			Test method:			
Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
60'	3425		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: \_\_\_\_\_

**13. LITHOLOGIC LOG and/or repairs or abandonment:**

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
36	0	4	top soil		
36	4	12	sand		
36	42	53	brown clay		
25	53	78	black basalt		
25	78	86	red cinder		
25	86	192	black basalt		
25	192	204	brown clay		
25	204	227	sand and brown clay		
25	227	259	fractured basalt		
25	259	271	brown sand		
25	271	280	basalt		X
19	280	303	basalt		X
19	303	309	fractured basalt		X
19	309	318	baked brown clay		
19	318	324	sticky brown clay		
19	324	326	brown silt		X
19	326	329	sticky brown clay		
19	329	334	fine brown sand and silt		
19	334	347	sticky brown clay		
19	347	349	fine brown sand		X
19	349	357	sticky brown clay		
19	357	368	cemented sand		X
19	368	370	sticky brown clay		
19	370	394	brown sand and pea gravel		X
19	394	417	sticky brown clay		
19	417	436	brown sand		X
19	436	444	sticky brown clay		
19	444	529	brown sand with small clay seams		
19	529	555	sticky tan clay		

Completed Depth (Measurable): 545  
Date Started: 5-15-16 Date Completed: 6-30-16

**14. DRILLER'S CERTIFICATION:**  
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling Co. No. 560  
\*Principal Driller \_\_\_\_\_ Date Jul 26, 2016  
\*Driller [Signature] Date Jul 26, 2016  
\*Operator II [Signature] Date Jul 27, 2016  
Operator I \_\_\_\_\_ Date \_\_\_\_\_

\* Signature of Principal Driller and rig operator are required

63

# Irrigation Well 4

Form 238-7  
6/07

## IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 1077537

Drilling Permit No. 885283

Water right or injection well # \_\_\_\_\_

2. OWNER: Simplet hand & live stock

Name \_\_\_\_\_

Address 1301 Hwy 67

City Grain Valley State ID Zip 83624

3. WELL LOCATION:

Twp. 1 North  or South  Rge. 2 East  or West

Sec. 6 SE 1/4 5W 1/4 1/4

Gov't Lot \_\_\_\_\_ County Ada

Lat. 43 26.694 (Deg and Decimal minutes)

Long. 116 11.13 (Deg and Decimal minutes)

Address of Well Site South Lake & Barber Rd

City \_\_\_\_\_

Lot \_\_\_\_\_ Blk. \_\_\_\_\_ Sub. Name \_\_\_\_\_

4. USE:

Domestic  Municipal  Monitor  Irrigation  Thermal  Injection

Other \_\_\_\_\_

5. TYPE OF WORK:

New well  Replacement well  Modify existing well

Abandonment  Other \_\_\_\_\_

6. DRILL METHOD:

Air Rotary  Mud Rotary  Cable  Other \_\_\_\_\_

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method/procedure
Med. Chip	18	1600		Poured
Granular	0	173	7600	Poured

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Linear	Threaded	Welded
20"	+1	18	.250	Steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
16"	+1	193	.250	Steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
12"	+1	450	.250	Steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Was drive shoe used?  Y  N Shoe Depth(s) \_\_\_\_\_

9. PERFORATIONS/SCREENS:

Perforations  Y  N Method \_\_\_\_\_

Manufactured screen  Y  N Type Johnson

Method of installation Set in

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
450	530	.020		12"	S.S.	.250

Length of Headpipe \_\_\_\_\_ Length of Tailpipe \_\_\_\_\_

Packer  Y  N Type \_\_\_\_\_

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method
6-9 Sand	550	350	8400	Poured

11. FLOWING ARTESIAN:

Flowing Artesian?  Y  N Artesian Pressure (PSIG) \_\_\_\_\_

Describe control device \_\_\_\_\_

### 12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 301 Static water level (ft) 301

Water temp. (°F) 85.7 Bottom hole temp. (°F) 85.7

Describe access port \_\_\_\_\_

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Ball	Air	Flowing artesian
14'	1800	2 days	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: \_\_\_\_\_

### 13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water
				Y N
25	0	2	Top Soil	
25	2	6	Clay	
25	6	18	Weathered Basalt	
20	18	47	Weathered Basalt	
20	47	63	Red Cinder	
20	63	177	Solid Basalt	
20	177	183	Fractured Basalt	
20	183	193	Gravel and Sand	
16	193	496	Gravel and Sand	X
16	496	507	Silty Tan Clay	X
16	507	533	Sand and Gravel	
16	533	531	Tan Clay	
16	531	542	Fine to Med Sand	X
16	542	555	Sticky Tan Clay	

RECEIVED

JUN 07 2018

WATER RESOURCES  
WESTERN REGION

Completed Depth (Measurable): 550

Date Started: 5-1-18 Date Completed: 6-1-18

14. DRILLER'S CERTIFICATION:  
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling Co. No. 5600

\*Principal Driller [Signature] Date 6-7-18

\*Driller [Signature] Date 6-7-18

\*Operator II \_\_\_\_\_ Date \_\_\_\_\_

Operator I \_\_\_\_\_ Date \_\_\_\_\_

\* Signature of Principal Driller and rig operator are required.

# Monitoring Well

Form 238-7  
6/07

## IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

### 1. WELL TAG NO. D 0066301

Drilling Permit No. **965601-871660**  
Water right or injection well # \_\_\_\_\_

### 2. OWNER

Name **Ray Montierth**  
Address **825 Hearland Dr**  
City **Nampa** State **Id** Zip **83686**

### 3. WELL LOCATION:

Twp. **1** North  or South  Rge. **1** East  or West   
Sec. **12** NE 1/4 SW 1/4 SE 1/4  
Gov't Lot \_\_\_\_\_ County **Ada**

Lat. **43 ° 25.967** (Deg. and Decimal minutes)  
Long. **116 ° 16.803** (Deg. and Decimal minutes)  
Address of Well Site **1/4 mi.w.of Cole Rd 1/4 mi.s.of railroad ROW**  
City **Kuna**

Lot \_\_\_\_\_ Blk. \_\_\_\_\_ Sub. Name \_\_\_\_\_

### 4. USE:

Domestic  Municipal  Monitor  Irrigation  Thermal  Injection  
 Other

### 5. TYPE OF WORK check all that apply (Replacement etc.)

New Well  Replacement well  Modify existing well  
 Abandonment  Other

### 6. DRILL METHOD:

Air Rotary  Mud Rotary  Cable  Other

### 7. SEALING PROCEDURES

Seal material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method/procedure
gran/bentoni	0	80	3600/lbs	pour

### 8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
10	+3	4	.250	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
6	+2	378	.250	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
5	368	388	.250	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used?  Y  N Shoe Depth(s) **376**

### 9. PERFORATIONS/SCREENS:

Perforations  Y  N Method \_\_\_\_\_  
Manufactured screen  Y  N Type **johnson**  
Method of installation **set in**

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
388	398	.16	10 ft	5	ss	.250

Length of Headpipe **20** Length of Tailpipe \_\_\_\_\_

Packer  Y  N Type **neoprene**

### 10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method

### 11. FLOWING ARTESIAN:

Flowing Artesian?  Y  N Artesian Pressure (PSIG) \_\_\_\_\_  
Describe control device \_\_\_\_\_

### 12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) **280** Static water level (ft) **268**  
Water temp. (°F) **72** Bottom hole temp. (°F) \_\_\_\_\_  
Describe access port **cap**

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Test method:			
			Pump	Bailer	Air	Flowing artesian
<b>122</b>	<b>40</b>	<b>2hr</b>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Water Quality test or comments: **tested great, no smell, no sand**

### 13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
10	0	2	top soil		X
10	2	9	brokin up lava		X
10	9	37	black lava		X
10	37	40	soft		X
8	39	46	brown lava		X
8	46	68	black lava		X
8	68	70	brown lava		X
8	70	84	black lava		X
8	84	86	fractured lava		X
8	86	88	crack		X
8	88	127	lava		X
8	127	131	soft lava		X
8	131	162	lava		X
8	162	170	soft lava		X
8	170	230	lava		X
8	230	238	sinders		X
6	238	262	gravel	X	
6	262	268	clay		X
6	268	340	gravel sand	X	
6	340	343	clay		X
6	343	347	gravel	X	
6	347	351	clay		X
6	351	356	sand	X	
6	356	360	clay		X
6	360	367	sand	X	
6	367	370	clay		X
6	370	375	sand	X	
6	375	378	clay		X
6	378	385	gravel	X	
6	385	387	clay		X
6	387	404	corse sand	X	

Completed Depth (Measurable) **398**

Date: Started **July 8, 2014** Completed **July 20, 2014**

### 14. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name **Treasure Valley Drilling** Co. No. **560**

\*Principal Driller *Monte Post* Date **4-3-15**

\*Driller \_\_\_\_\_ Date \_\_\_\_\_

\*Operator II \_\_\_\_\_ Date \_\_\_\_\_

Operator I *Pike Langa* Date **4-3-15**


Signature of Principal Driller and rig operator are required.

RECEIVED

APR 03 2015

WATER RESOURCES  
WESTERN REGION

**Appendix C**  
**Totalizer Photos**




Irrigation Well No. 1 Totalizer (10/31/2019)




Irrigation Well No. 2 Totalizer (10/31/2019)



Irrigation Well No. 3 Totalizer (9/28/2018, no additional flow after this date)



Plant Well #1 (East) Totalizer (12/21/2018)



Plant Well #2 (West) Totalizer (12/21/2018)

**Appendix D**  
**Water Level Data**

