


STATE OF IDAHO
DEPARTMENT OF RECLAMATION
BOISE


REPORT OF ENGINEER

PERMIT NO. G-28839

REPORT ON PROOF OF Completion of Works & Beneficial Use

Herbert N. Williams, Weston, Idaho





STATE OF IDAHO
DEPARTMENT OF RECLAMATION
BOISE, IDAHO

REPORT OF ENGINEER

Permit No. G-28839

This proof is for Completion of Works & Beneficial Use In Water District No. _____

1. Name of applicant Herbert N. Williams

2. Source of water supply: 3 wells

3. Location of point of diversion: Is in the _____ of Section _____

T. 16 S. R. 38 EBM County of Franklin

4. Describe works as they exist, giving dimensions and capacities of same: 25 HP U.S. Holashof

Motor #3222893, F-M Panama Pump # P2D-1953. 6" discharge

to a 6" buried main line 1480' - 30- 7/32" nozzle. well 10' x 15'

157 x 10" csg. 6' 10' dd: 50' - 3E 3W Sec 5 - 10 HP Wisco Gas Engine

#204254 with a Pacific Centrifugal Pump #6P9255 Model 2C--6

3" suction x 2" discharge increased to 4" flexible hose to 4" aluminum line

5. Water is used for: irrigation

6. State whether or not water has been turned into works of diversion: yes

7. List legal subdivisions of lands to be irrigated. If proof is for beneficial use, give exact number of acres under cultivation in each forty-acre tract. (Describe manner and place of use if other than irrigation):

Fractions of NE 1/4, SE 1/4, Sec. 5., NE 1/4, SE 1/4, Sec. 8., Twp. 16 S., Rge. 38 E, B, M,

(Submit map on attached plat, showing location and details of above description.)

8. What large stream would the water here appropriated finally reach?

Remarks: Mrs. H. N. Williams along

Claims Jerry Schvaneveldts Well, located on west line of the
NW 1/4 Sec 8, interferes with his well.

Measured by taking pressure readings along laterals.

This examination was made on the 28th day of May, 1964

(Signed) Larry Johnson Examiner.

Exhibit 113

28839