

Miller, Nick

From: Terry Scanlan <TScanlan@spfwater.com>
Sent: Tuesday, May 22, 2018 12:03 PM
To: Miller, Nick
Cc: Kelly, Patrick
Subject: FW: Temperature Log for 63-34242
Attachments: 2018-5-22 Winsome Rd#2 Final Report.pdf

RECEIVED

MAY 22 2018

WATER RESOURCES
WESTERN REGION

Nick –

FYI.

Terry

From: Terry Scanlan
Sent: Tuesday, May 22, 2018 11:19 AM
To: 'Charles Honsinger' <honsingerlaw@gmail.com>; 'patrick.kelly@idwr.idaho.gov' <patrick.kelly@idwr.idaho.gov>
Cc: 'Zeke@rscigroup.com' <Zeke@rscigroup.com>
Subject: RE: Temperature Log for 63-34242

Charlie and Patrick –

Attached is a final report for the well. It includes test pumping data and post-construction temperature log. Let me know if anything else is needed in regard to this permit prior to submitting proof of beneficial use. Thanks.

Terry

From: Terry Scanlan
Sent: Thursday, May 3, 2018 12:46 PM
To: 'Charles Honsinger' <honsingerlaw@gmail.com>; 'patrick.kelly@idwr.idaho.gov' <patrick.kelly@idwr.idaho.gov>
Cc: 'Zeke@rscigroup.com' <Zeke@rscigroup.com>
Subject: RE: Temperature Log for 63-34242

Charlie and Patrick –

The well was successful and we are planning on test pumping at 9:00 next Wednesday (May 9).

Terry

From: Terry Scanlan
Sent: Tuesday, May 1, 2018 4:22 PM
To: 'Charles Honsinger' <honsingerlaw@gmail.com>
Cc: patrick.kelly@idwr.idaho.gov; Zeke@rscigroup.com
Subject: RE: Temperature Log for 63-34242

Charlie

The approximate GPS location is 43° 39' 10.65" N, 116° 12' 16.19" W. The well is approximately 265 feet to the northeast of Well #1. I have attached a map with approximate locations.

The well is under construction so I don't have a driller's report yet. Geophysical logs were not run on the well.

Assuming that the well is successful, we will notify you 48 hours before a pumping test.

Terry

From: Charles Honsinger <honsingerlaw@gmail.com>

Sent: Tuesday, May 1, 2018 2:25 PM

To: Terry Scanlan <TScanlan@spfwater.com>

Cc: patrick.kelly@idwr.idaho.gov; Zeke@rscigroup.com

Subject: Re: Temperature Log for 63-34242

Terry: Can you please provide us a gps location of the new well along with a map, geophysical logs and driller's report?

Thanks.

C.

Charles L. Honsinger
Honsinger Law, PLLC
P.O. Box 517
Boise, ID 83701
Phone: (208)863-6106
Fax: (208)908-6085
honsingerlaw@gmail.com

On Fri, Apr 27, 2018 at 10:56 AM, Terry Scanlan <TScanlan@spfwater.com> wrote:

Patrick and Charlie –

As required by permit 63-34342 condition No. 9 and the stipulation between Terteling Co and ZWJ Properties, attached please find a temperature log for the second borehole drilled for this permit. The log was performed using a solinst level logger with temperature sensor. Bottom hole (220 feet) temperature was 75F. The probe was left on bottom overnight before logging upward this morning.

The 75F bottom hole temperature is 2 degrees cooler than the water temperature produced from the first well that was drawing from deeper water-bearing zones (i.e., 227 to 600 feet).

Coonse Well Drilling proposes to construct the well with well screen from 210 to 220 feet. The surface seal will extend into a clay zone at 206 feet. Please contact me with any questions.

Please contact me with any questions.

Terry M. Scanlan, P.E., P.G. | Principal Engineer/Hydrogeologist
SPF Water Engineering, LLC

300 E Mallard Drive, Suite 350 | Boise, ID 83706

p. 208.383.4140 | **f.** 208.383.4156 | **d.** 208.489.2121

e. tscanlan@spfwater.com | **w.** www.spfwater.com