

Ident. No. 63-12397

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES

RECEIVED

JUL 22 1997

APPLICATION FOR PERMIT

Department of Water Resources

To appropriate the public waters of the State of Idaho

1. Name: MORES CREEK RIM RANCHES WATER DISTRICT
Address: HC 33 BOX 1940
BOISE ID 83706
208-336-4951
 2. Source: GROUNDWATER
Trib. to:
 3. Location of Point of Diversion: SWNW Sec. 27, Township 04N, Range 04E
NWSW Sec. 27, Township 04N, Range 04E
Lot 2(SENE), Sec. 28, Township 04N, Range 04E
BOISE County
 4. Water will be used for the following purposes:

Purpose	From	To	CFS	(or)	AF
DOMESTIC	01/01	12/31	0.500		
 5. Total quantity to be appropriated is:
0.500 CFS (and/or) AF
 6. Proposed diverting works:
 - a. Description of ditches, flumes, pumps, headgates, etc.
2 EXISTING WELLS (63-10797) & 3 PROPOSED WELLS, PUMP & PIPELINES
 - b. Height of storage dam feet; active reservoir capacity
acre-feet; total reservoir capacity acre-feet; period of
year when water will be diverted to storage: to inclusive.
 - c. Proposed well diameter is 6 inches; proposed depth of well is 500
feet.
 - d. Is groundwater with a temperature greater than 85F being sought? NO
 - e. If well is already drilled, when?
Drilling Firm SEE APPLICATION COMMENTS; ALSO FOUND 1977 WELL LOG
Well was drilled for MORES CREEK RIM RANCHES
 7. Time required for the completion of the works and application of
the water to the proposed beneficial use is 5 year(s).
 8. Place of Use: DOMESTIC
- TWN RGE SEC
04N 04E 27 SWNW NWSW
28 Lot 2(ENE) NESE

* SEE "Comments" 5/30/97 c # wells, possible sites.

72

9. a. Who owns the property at the point of diversion?
SUBD. LOT OWNERS
b. Who owns the land to be irrigated or place of use?
SUBD. LOT OWNERS
c. If the property is owned by a person other than the applicant,
describe the arrangement enabling the applicant to make this filing.
DISTRICT WITH ELECTED OFFICERS/DIRECTOR MANAGE THE SYSTEM FOR USERS

10. Remarks:
Water bearing zone to be appropriated via 2 existing wells and 3
proposed wells for 40 homes and yards is from 175 to 500 feet.

11. Map of proposed point of diversion and place of use attached? [X]

BE IT KNOWN that the undersigned hereby makes application for permit to
appropriate the public waters of the State of Idaho as herein set forth.

See original
Applicant

per file, SL for:

Received by MS Date 5/9/97 Time 2:30 Preliminary check by SL


Fee \$ 100.00 Receipted by MS #W022326 Date 5/ 9/1997

Publication prepared by AT Date 5-29 Published in Idaho World
6-4-97-1997

Publication approved AT Date 6-26-97

SCALE IN PFT

100 0 100 200



⊗ EXISTING WELLS ✕ proposed wells

Master Subdivision Plat

Ident. No. 63-1239

Comments: Date: 5/15/1997 User-ID: SLESTER

*Somewhat modified -
See 5/30 Comments*

Subject: ADDITIONAL INFORMATION

Subdivision has license 63-10797 for 50 homes from 2 wells in NSW S27. Now proposes to add 2 more wells, 1 in NSW S27 and the other in either Gov't Lot 2 (SENE) S28 or SWNW S27 for 40 more homes and yards. Yards for the added homes will not exceed 10 acres - the .20 cfs for expected 10 acres has been added to the allowable .30 cfs for in-house use for 40 homes to total .50 cfs for this new filing. Thus, .30 cfs is to be used throughout the year for homes while another .20 cfs is to be used within the irrigation season (4/15-10/15) for yards.

The estimated water bearing zone is taken from well log data on file at IDWR but applicant needs to confirm that estimate. One of the existing wells was deepened in 1992 to 505'. The other existing well will be deepened under recently issued drilling permit 63-97-W-0257-100 (proposed about 565' deep).


It cannot be determined from existing license file which 50 homes (can include homes or stubbed lots) are already covered, nor can it be determined from new application which 40 homes are now to be covered - applicant should provide a good plat map showing this information for the entire service area. Officers include Carl W. Hair (Chairman/Director), Bob Callahan, Larry Ludkcy, Bob Lambrou and Joe Haider. Subdivision, block and lot numbers can then be added to this application.

Comments: Date: 5/30/1997 User-ID: SLESTER

Subject: FINAL CLARIFICATION

Carl Hair for subd. water district visited office today to clear up this application. Up to 3 wells in 4 possible sites will be added to increase the community system by another 40 homes and yards. P/D will be: 2 existing & 1 proposed wells in NSW S27, 1 or 2 proposed wells in SWNW S27, &/or 1 proposed well in S28. Confirmed that water bearing zone proposed from 175-500'. Cannot definitely confirm subd. unit numbers at this time. Mr. Hair mentioned units 1-4 and said #2 is deleted (see north part of 8.5 x 11 plat), leaving #1, 3 & 4. However, he also submitted 3 oversized plats covering entire service area of license 63-10797 plus new application. Plats are labeled #3 and portion of amended #2. Recommend that actual unit numbers be identified in field exam for new right. Then, can list lots covered by older right plus newer right. For now, plats show all of the lots to be served under both filings.

Post-visit thought: assume all wells will be integrated into one delivery system. This would require a transfer to add P/D's to the license. Region will followup with Mr. Hair on that thought while new application is being processed.



T4N R4E

No govt lots S. 27

Govt lot 3

possible new well site

proposed site


X = existing wells
e = proposed new wells


(Existing wells = 63-10799)

A00 3 wells in 4 possible sites

Proposed + possible well site per plan

63-12899





Ident. No. 63-12397

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
APPLICATION FOR PERMIT

To appropriate the public waters of the State of Idaho

1. Name of Applicant Mores Creek Rim Ranch Water District Phone 336-4951
Mailing address HC 33 Box 1940, Boise ID 83706
2. Source of water supply Ground water which is a tributary of _____
3. Location of point of diversion is Township 4N Range 4E Sec. 27 in the _____ 1/4.
NW 1/4, SW 1/4, Govt. Lot _____, B.M., Boise County;
additional points of diversion if any: 4N, 4E, S28, SENE
4. Water will be used for the following purposes:
Amount .30 for Domestic purposes from 1-1 to 12-31 (both dates inclusive)
(cfs or acre-feet per annum)
Amount .20 for Irrigation purposes from 4-15 to 10-15 (both dates inclusive)
(cfs or acre-feet per annum)
Amount _____ for _____ purposes from _____ to _____ (both dates inclusive)
(cfs or acre-feet per annum)
Amount _____ for _____ purposes from _____ to _____ (both dates inclusive)
(cfs or acre-feet per annum)
Amount _____ for _____ purposes from _____ to _____ (both dates inclusive)
(cfs or acre-feet per annum)
Amount _____ for _____ purposes from _____ to _____ (both dates inclusive)
(cfs or acre-feet per annum)
5. Total quantity to be appropriated is (a) .50 cfs and/or (b) 59 AF
cubic feet per second acre feet per annum
6. Proposed diverting works:
 - a. Describe type and size of devices used to divert water from the source 2 existing wells and 2 new wells
 - b. Height of storage dam _____ feet; active reservoir capacity _____ acre-feet; total reservoir capacity _____ acre-feet
 - c. Proposed well diameter is 6" inches; proposed depth of well is 500' feet
 - d. Is ground water with a temperature of greater than 85°F being sought? No.
 - e. If well is already drilled, when? _____; Drilling firm _____
Well was drilled for (well owner) _____; Drilling Permit No. _____
7. Time required for completion of works and application of water to proposed beneficial use is 5 years (minimum 1 year)
8. Description of proposed uses (if irrigation only, go to item 9):
 - a. Hydropower; show total feet of head and proposed capacity in KW. _____
 - b. Stockwatering; list number and kind of livestock. _____
 - c. Municipal; show name of municipality. _____
 - d. Domestic; show number of households. 40 new lots in Mores Creek Rim Ranch
 - e. Other; describe fully. Irrigation of lots within Mores Creek Rim Ranch

9. Description of place of use:

- a. If water is for irrigation, indicate acreage in each subdivision in the tabulation below.
- b. If water is used for other purposes, place a symbol of the use (example: D for Domestic) in the corresponding place of use below. See instructions for standard symbols.

TWP	RGE	SEC	N E				N W				S W				S E				TOTALS
			NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
4N	4E	27							2.5				2.5						5
		28				D 2.5 4.2									D 2.5				5

Total number of acres to be irrigated 10

10. Describe any other water rights used for the same purposes as described above. 63-10797

11. a. Who owns the property at the point of diversion? Subdivision lot owners.
- b. Who owns the land to be irrigated or place of use? " " "
- c. If the property is owned by a person other than the applicant, describe the arrangement enabling the applicant to make this filing:

12. Remarks: This application proposes to add a third well in the NWSW, S27T4N, R4E and a new well in the SENE, S28, T4N, R4E. Also, 10 acres of irrigation and 40 additional lots not covered by 63-10797 are part of this application. OFFICERS: Carl Hays, Bob Callahan, Harry Ludkey, Bob Lambrou, Joe Haider.

13. MAP OF PROPOSED PROJECT REQUIRED - Attach an 8½"x11" map clearly identifying the proposed point of diversion, place of use, section #, township & range. (A photocopy of a USGS 7.5 minute topographic quadrangle map is preferred.)

BE IT KNOWN that the undersigned hereby makes this application for permit to appropriate the public waters of the State of Idaho as herein set forth.

Mores Creek Rim Ranch Water District

by Carl W Hays Chairman/Director
Signature of Applicant (and title, if applicable)

Received by MS Date 5-9-1997 Time 2:30 Preliminary check by
Fee \$ 100 Received by MS # W022326 Date 5/9/1997
Publication prepared by Date Published in
Publication approved Date

100-100
AUG 14 1967

SUBDIVISION PLAT

**OVERSIZED
DRAWINGS
SEE FILE**

State of Idaho
Department of Water Resources
Permit To Appropriate Water
NO. 63-12397

Proposed Priority: May 9, 1997

Maximum Diversion Rate:

0.50 CFS

This is to certify, that MORES CREEK RIM RANCHES WATER DISTRICT
HC 33 BOX 1940
BOISE ID 83706
has applied for a permit to appropriate water from: GROUNDWATER
and a permit is APPROVED for development of water as follows:

<u>BENEFICIAL USE</u>	<u>PERIOD OF USE</u>	<u>RATE OF DIVERSION</u>
-----------------------	----------------------	--------------------------

DOMESTIC	01/01 to 12/31	0.50 CFS
----------	----------------	----------

LOCATION OF POINT(S) OF DIVERSION:

SWNW , Sec. 27, Township 04N, Range 04E
NWSW , Sec. 27, Township 04N, Range 04E
Lot 2(SENE), Sec. 28, Township 04N, Range 04E
BOISE County

PLACE OF USE: DOMESTIC

TWN RGE SEC

04N 04E 27
28 Lot 2(SENE)

NWSW
NESE

CONDITIONS OF APPROVAL AND REMARKS

1. Proof of construction of works and application of water to beneficial use shall be submitted on or before August 1, 2002.
2. Subject to all prior water rights.
3. Project construction shall commence within one year from the date of permit issuance and shall proceed diligently to completion unless it can be shown to the satisfaction of the Director of the Department of Water Resources that delays were due to circumstances over which permit holder had no control.
4. After specific notification by the department, the right holder shall install a suitable measuring device or shall enter into an agreement with the department to determine the amount of water diverted from power records and shall annually report the information to the department.
5. Right holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code.
6. The right holder shall comply with Idaho well construction standards when constructing a well pursuant to this right.
7. The irrigation occurring under this domestic use shall not exceed 1/2 acre within each platted subdivision lot upon which a home has been constructed.
8. The domestic use authorized under this right shall not exceed 13,000 gallons per day per home.
9. The issuance of this right does not grant any right-of-way or easement across the land of another.

State of Idaho
Department of Water Resources

Permit To Appropriate Water


NO. 63-12397

CONDITIONS OF APPROVAL AND REMARKS

10. Three points of diversion are located within NWSW, S27, T04N, R04E.
11. Points of diversion are located within Lots 4, 10, 34, 52, & 76, Mores Creek Rim Ranches.
12. Places of use are located within Mores Creek Rim Ranches.
13. Domestic use is for 34 homes.
14. Water bearing zone to be appropriated via 2 existing wells and 3 proposed wells is from 175 to 500 feet.

This permit is issued pursuant to the provisions of Section 42-204, Idaho Code.
Witness the signature of the Director, affixed at Boise, this

11th day of August, 1997.


Karl J. Dreher, Director
for



State Idaho
DEPARTMENT OF WATER RESOURCES

Western Region, 2735 Airport Way, Boise, Idaho 83705-5082 - (208) 334-2190
FAX (208) 334-2348

May 15, 1997

PHILIP E. BATT
GOVERNOR

KARL J. DREHER
DIRECTOR

CARL W HAIR DIRECTOR
MORES CK RIM RANCHES WATER DIST
HC 33 BOX 1940
BOISE ID 83706

RE: APPLICATION FOR PERMIT NO. 63-12397

Dear Mr. Hair:

Enclosed is a copy of your recent application to provide more wells for more homes and yards within the development. Please review the application and note the highlighted items in particular.

In order to process the filing, please confirm the proposed water bearing zone to be appropriated. Also, a plat map for the entire service area showing which lots are served under your older right and which lots are proposed in this newer right will be needed. The map should be legible enough to allow lot sizes to be determined (any irrigation cannot exceed one-half acre per home).

Note that "possible well site #3" has been added to the point of diversion list to fully cover the possibilities.

Your reply within 30 days will be helpful. Please let me know if you need more information.

Sincerely,

Steve Lester
Water Rights Supervisor

Enclosure: Application copy

State law requires that this report be filed with the Director, Department of Water Resources within 30 days after the completion or abandonment of the well.

[illegible]

USE ADDITIONAL SHEETS IF NECESSARY - FORWARD THE WHITE COPY TO THE DEPARTMENT

WELL DRILLER'S REPORT.

State law requires that this report be filed with the Director, Department of Water Resources within 30 days after the completion or abandonment of the well.

[illegible]

CONVERSATION MEMORANDUM

DATE 5/30/97

FILE 63-12397

NAME OF PARTY CARL HAIR

EMPLOYEE STEVE LESTER

RE: Office Visit Response to 5/15/97 Letter

① provided good plot maps.

② difficult to say exactly which lots covered by
which right as sales cont. etc. since all lots
have lines in place -
between 2 rights will cover everything.

③ OK water bearing zone 175' - 510'.

④ clarified 3 possible new wells in combo of
4 " " well locations.

⑤ Irrig. limited to 1/2 acre per home actually
built in new proposal.

Fax To: Sue Taylor

Id. Dept of Water Resources
208-334-2348

From: Idaho World
Newspaper
Fax# ~~208~~ 208-462-3325

Subject: Legal notice for
Mores Creek Rim Ranches
Water District - 63-12397

Our Fax machine ran out of
paper & we did not get all of
this notice - please resend -

Thank You -

Wayne Hart

Permits will be subject to all prior water rights. Protests may be submitted based on the criteria of Sec. 42-203A, Idaho Code. Any protest against the approval of this application must be filed with the Director, Dept. of Water Resources, Western Region, 2735 Airport Way, Boise, Idaho 83705 together with a protest fee of \$25.00 on or before JUNE 23, 1997. The protestant must also send a copy of the protest to the applicant.

KARL J. DREHER, Director

Published: 5/ 4/1997 & 5/11/1997

63-12397

MOORES CREEK RIM RANCHES WATER DISTRICT
HC 33 BOX 1940
BOISE, ID 83706

Source: GROUNDWATER

Diversion Pt: SWNW Sec 27 T 04N R 04E in BOISE County.
 NWSW Sec 27 T 04N R 04E in BOISE County.
 LOT 2 (SENE) Sec 28 T 04N R 04E in BOISE County.

Use: DOMESTIC (0.500 CFS)
 Total Diversion: (0.500 CFS)

Date Filed: 5/ 9/1997

In: BOISE County
 T04N R04E S27 SWNW NWSW
 S28 Lot 2 (SENE) NESE

Water bearing zone to be appropriated via 2 existing wells and 3
proposed wells for 40 homes and yards is from 175 to 500 feet.

NOTICE OF APPLICATION FOR WATER RIGHT

The Following application(s) have been filed to appropriate the public waters of the State of Idaho:



State of Idaho

DEPARTMENT OF WATER RESOURCES

Western Region, 2735 Airport Way, Boise, Idaho 83705-5082 - (208) 334-2190

FAX (208) 334-2348

PHILIP E. BATT
GOVERNOR

KARL J. DREHER
DIRECTOR

MAY 30, 1997

Legal Notices Department
The Idaho World
PO Box 99
Garden Valley, ID 83622

Dear Legal Dept.:

Enclosed you will find a legal notice which we wish to have published on the dates indicated (once a week for two consecutive weekly issues) in your newspaper. If you cannot publish the notice on the proposed dates, please contact us immediately.

An affidavit of publication must be submitted to the Department along with the publication bill. Your cooperation is appreciated.

Please send the affidavit of publication and publication billing to this office before JUNE 23, 1997.

Yours truly,

SUE TAYLOR
Secretary/Office Coordinator

Encl.



State of Idaho
DEPARTMENT OF WATER RESOURCES

Western Region, 2735 Airport Way, Boise, Idaho 83705-5082 - (208) 334-2190
FAX (208) 334-2348

June 2, 1997

PHILIP E. BATT
GOVERNOR

KARL J. DREHER
DIRECTOR

MR CARL HAIR DIRECTOR
MORES CK RIM RANCHES WATER DIST
HC 33 BOX 1940
BOISE ID 83706

RE: ADDITIONAL WELLS FOR SUBDIVISION SYSTEM

Dear Carl:

I overlooked an item related to adding wells to your community system as proposed in the pending new water right application (no. 63-12397). The integration of new wells into a common system means that the older right must be changed to add diversion points to that right.

The older right is license no. 63-10797. Enclosed please find an "application for transfer" to add new wells to that right. The only other steps to complete the transfer application are as follows:

1. review the application form and attachments;
2. answer the highlighted items on pages 2 and 3;
3. a notarized signature is needed on page 2; and
4. a \$100 transfer filing fee is necessary.

The transfer application will be published in the local legal notices once you return the completed filing to this office. The transfer can be processed while your new water right application (63-12397) is being processed.

Once both filings have been approved, your water right coverage for an expanded system will be complete. You can obtain well drilling permits once either one of the filings is approved - it is not necessary to wait for both applications to be approved before receiving approved drilling permits. In this manner, the transfer application will not delay your well drilling plans.

Please let me know if you have any questions regarding the transfer. I apologize for not remembering to include this step in our previous discussions.

Sincerely,

Steve Lester
Water Rights Supervisor

Enclosure



State of Idaho
DEPARTMENT OF WATER RESOURCES

Western Region, 2735 Airport Way, Boise, Idaho 83705-5082 - (208) 334-2190
FAX (208) 334-2348

PHILIP E. BATT
GOVERNOR

KARL J. DREHER
DIRECTOR

June 6, 1997

ID DEPT OF HEALTH & WELFARE
DIV OF ENV QUALITY
SWIRO
PO BOX 83720
BOISE ID 83706

Re: Application for Permit No. 63-12397 in the Name of Mores Creek
Ranches Water District

Dear Sir:

Enclosed is a copy of the above-referenced application for permit which may be of interest to your agency. Please review the application and submit any comments you may have.

This office normally completes the processing of an application within a six-week period and is required to take final action shortly thereafter, however, if your agency desires to file a formal protest against the approval of this application(s), your written protest along with the \$25.00 protest fee must be received in this office by June 23, 1997.

If you have any questions regarding the application, please contact this office.

Sincerely,


Gary Spackman

GS:st

Enclosure(s):

The Idaho World

P O Box 99
Garden Valley, ID 83622
208 462-3487

RECEIVED

JUN 23 1997

WATER RESOURCES
WESTERN REGION

State of Idaho >
>
County of Boise >

Deanna Stevenson, being duly sworn, deposes and says: that she is the Editor of THE IDAHO WORLD, a weekly newspaper published at Idaho City, in the County of Boise and the State of Idaho; the said paper has been and is in general circulation in the county aforesaid, and in the vicinity of Idaho City; that the advertisement, a copy of which is hereto attached, was published in said newspaper once a week for two (2) consecutive weeks in the entire and regular issue of every number of said paper during the period and time of publication and was published in the newspaper and not a supplement; that said paper has been established and regularly and continuously published for more than seventy eight weeks past previous to the first publication of this notice. Such notice was published with the issue beginning with June 4, 1997 and ending with the issue of June 11, 1997.

Deanna Stevenson

State of Idaho >
>
County of Boise >

On this 19th day of June in the year 1997, before me, a notary public, personally appeared Deanna Stevenson known or identified to me, to be the person whose name subscribed to the within instrument, and being by me first duly sworn, declared that the statements therein are true, and acknowledged to me that she executed the same.

Diane E. Caughlin
Notary Public for Idaho
Residing at Garden Valley, Idaho

My commission expires 6/26/2001

NOTICE OF APPLICATION FOR WATER RIGHT

The Following application(s) have been filed to appropriate the public waters of the State of Idaho:

63-12397 *st*

MORES CREEK RIM RANCHES WATER DISTRICT
HC 33 BOX 1940
BOISE, ID 83706

Source: GROUNDWATER

Diversion Pt:	SWNW	Sec 27 T 04N R 04E in BOISE County.
	NWSW	Sec 27 T 04N R 04E in BOISE County.
LOT 2	(SENE)	Sec 28 T 04N R 04E in BOISE County.

Use: DOMESTIC	(	0.500 CFS)
Total Diversion:	(	0.500 CFS)

Date Filed: 5/ 9/1997

In: BOISE County		
T04N R04E S27	SWNW	NWSW
S28	Lot 2 (SENE)	NFSE

Water bearing zone to be appropriated via 2 existing wells and 3 proposed wells for 40 homes and yards is from 175 to 500 feet.

Permits will be subject to all prior water rights. Protests may be submitted based on the criteria of Sec. 42-203A, Idaho Code. Any protest against the approval of this application must be filed with the Director, Dept. of Water Resources, Western Region, 2735 Airport Way, Boise, Idaho 83705 together with a protest fee of \$25.00 on or before JUNE 23, 1997. The protestant must also send a copy of the protest to the applicant.

KARL J. DREHER, Director

Published in The Idaho World June 4 and 11, 1997



State of Idaho

DEPARTMENT OF WATER RESOURCES

1301 North Orchard Street, P.O. BOX 83720, Boise, Idaho 83720-0098
Phone: (208) 327-7900 FAX: (208) 327-7866

PHILIP E. BATT
GOVERNOR

KARL J. DREHER
DIRECTOR

August 11, 1997

MORES CREEK RIM RANCHES WATER DISTRICT
HC 33 BOX 1940
BOISE ID 83706

PERMIT APPROVAL NOTICE

RE: PERMIT NO. 63-12397

Dear Permit Holder:

The Department of Water Resources (IDWR) has issued the enclosed permit authorizing you to establish a new water right. Please be sure to thoroughly review the conditions of approval and remarks listed on your permit.

The permit is a preliminary order issued by IDWR pursuant to section 67-5243, Idaho Code. It can and will become a final order without further action by IDWR unless a party petitions for reconsideration or files an exception and/or brief as described in the enclosed information sheet.

As a permit owner you must commence the excavation or construction of the diverting works within one year of the date the permit was issued, and you must proceed diligently until the project is completed. The date shown under condition no. 1 is the date when the project must be completed.

The Department will send you a "Proof Due Notice" approximately 60 days prior to the above referenced date requesting you to file either a Proof of Beneficial Use form or a Request for Extension of Time form.

If a well has not already been constructed you are required to obtain a "drilling permit" from the department. The right to drill a well is not a part of this permit to appropriate water.

Please note this water right limits irrigation occurring under the domestic use to one-half acre within each platted subdivision lot upon which a home has been constructed. This permit does not provide for irrigation of common areas or for irrigation of lots with no homes.

Also, please note that as of July 1, 1996, water right owners are required to report any change of water right ownership and any change of mailing address to the department. If you have acquired

a water right or have changed your mailing address PRIOR TO July 1, 1996, you have until July 30, 1998, to notify the department. If you acquire a water right or change your mailing address AFTER July 1, 1996, you must notify the department within 120 days of the change.

Failure to report these changes could result in a \$100 late filing fee. Contact any office of the department to obtain the proper reporting form.

Sincerely,

A handwritten signature in cursive script, reading "Shelley W. Keen". The signature is written in dark ink and is positioned above the typed name and title.

Shelley W. Keen
Water Rights Supervisor

SK:klt

Enclosures

CERTIFICATE OF MAILING

I hereby certify that on the 11th day of August, 1997, I mailed a true and correct copy, postage prepaid, of the foregoing PRELIMINARY ORDER (Approved Permit) to the person(s) listed below:

Water Right No. 63-12397

MORES CREEK RIM RANCHES WATER DISTRICT
HC 33 BOX 1940
BOISE ID 83706


Kari Lynn Townsend
Secretary

FORWARD WHITE COPY TO WATER RESOURCES

Ident. No. 63-97-C-0526-000
Water Right No. 63-12397
D147

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
APPLICATION FOR DRILLING PERMIT

1. Name: MORES CREEK RIM RANCH WATER DISTRICT O 208-336-4951
Address: C/O CARL HAIR, CHAIRMAN
HC33 BOX 1143
BOISE ID 83706

2. Proposed Well Location: Township 04N, Range 04E, Sec. 27, SWNW
BOISE County

Street Address of Well Site: LOT 33, MORES CREEK RIM RANCH
IDAHO CITY ID

Lot, Block, and Subdivision: Lt 33
Blk
MORES CREEK RIM RANCH

3. Proposed Use of Well: Other
SUBDIVISION WELL

4. Well Construction Information:

- A. NEW WELL
B. Proposed Surface Diameter 8 In. Proposed Maximum Depth 600 Ft.
C. Anticipated Bottom Hole Temperature: 85 F or less (Cold water well)
(NOTE: Construction diagrams and/or other information may be requested for
monitor, low temperature geothermal, municipal and artesian wells.)

5. Construction Start Date: 9/15/1997

6. Anticipated Well Driller: (No. 9999)
NOTE: The actual well driller must be identified to IDWR prior to drilling
commencement.

7. Applicant's Signature _____ Date _____

Title _____
(Owner, Firm Representative, Other)

Fee \$ 200.00 Received by _____ No. C039880 Date 8/18/1997

(Continued)

ACTION OF THE DEPARTMENT OF WATER RESOURCES

This permit is Approved.Date: 9-22-97

If approved, this permit authorizes the construction or modification of a well subject to the following conditions. READ CAREFULLY!

CONDITIONS OF APPROVAL:

1. This drilling permit is valid for two (2) months from the approval date for the start of construction and is valid for one (1) year from the approval date for completion of the well unless an extension has been granted.
2. This permit does not constitute an approval of the District Health Department or the Idaho Department of Health and Welfare which may be required prior to construction of this well. The local Health Department should be contacted for septic tank/drainfield locations. Domestic wells must not be drilled closer than 100' from any drainfield and 50' from any septic tank. Public Water Supply wells must not be drilled closer than 100' from any drainfield or septic tank.
3. The well shall be constructed by a driller currently licensed in the state of Idaho who must maintain a copy of the drilling permit at the drilling site.
4. Approval of this drilling permit does not authorize trespass on the land of another party.
5. This permit does not constitute other local, county, state or federal approvals which may be required for construction of a well.
6. This drilling permit does not represent a right to divert and use the water of the State of Idaho.
7. If the bottom hole temperature of 85 Degrees F (29.44 oC) or greater is encountered, well construction shall cease and the well driller and the well owner shall contact the Department immediately.
8. Idaho Code, S 55-2201 - 55-2210 requires the applicant and/or his contractors to contact "Digline" (DigLine is a one-call center for utility notification) not less than 2 working days prior to the start of any excavation for this project. The "Dig Line " Number for your area is 1-800-342-1585.
9. Failure to construct the well in accordance with these conditions may result in the revocation of the drilling permit and constitute a violation of Idaho Law.
10. The uppermost unconfined aquifer shall be cased and sealed to exclude water from this zone from entering the well. All seals will be placed from the bottom up.
11. If an annular slurry seal of bentonite is to be utilized, a high (>30%) solids bentonite shall be pumped from the bottom up to land surface. The bentonite shall not contain chemical polymers which effect long term stability of the seal (and are often found in drilling fluid grade bentonites) but shall be a bentonite which has been specifically recommended by the manufacturer for use as a seal material in water wells.

(Continued)


CONDITIONS OF APPROVAL:

12. A 50% excess of seal material shall be on hand in the event of lost circulation. If the seal material does not make it back to the surface, tremieing or perforation and squeezing is to commence at the top of the tagged seal position and will continue until returns reach the surface or the department is satisfied that aquifers are sufficiently isolated and/or protected from waste and contamination.
13. If an annular space of at least 4 inches greater than the outside diameter of the casing is provided a granular bentonite or bentonite chips may be poured at the manufacturer's recommended rate or no greater than 50 pounds in five minutes. The pour shall also be presifted through 1/4 inch mesh screen to reduce the introduction of fines unless the annular space is free of water, ie. (above the water table and there is no cascading water). The top of the seal shall be tagged at regular intervals, ie. (30' intervals) during placement with a sinker bar or other appropriate device to ensure the seal is reaching the intended depth. If bridging occurs, the seal shall be tamped to its intended position or the Department will be contacted for evaluation.
14. The project engineer or geologist will be on site during seal placement should any peculiarities arise which require further evaluation. Any alteration of the proposed or herein modified well construction procedure shall be approved by the Department before they are undertaken.
15. If after the commencement of drilling a construction problem develops, another means of seal placement or seal material may be approved after the Department has had an opportunity to review proposed changes. A 24 hour review period will be provided for department personnel should said changes become necessary.
16. Drilling fluids shall be mixed with water which meets or exceeds drinking water standards.
17. The screened, perforated, filterpacked or otherwise open and commingled strata which are to be produced from, shall be of similiar hydraulic head, temperature and quality. If there are notable variations encountered as the well is drilled and/or developed, the Department will be notified for evaluation.
18. If the supply line is connected to the pump column below ground level, a pitless device will be utilized which provides a water tight seal through the casing. The pitless will be tested according to the means described by the U.S.EPA manual EPA-430/9-74-007. The test will be run in the presence of the engineer designing the surface distribution of the system.
19. Reference drilling specifications of the American Water Works Association Standard for Water Wells (ANSI/AWWA A100-90) and the Recommended Standards For Water Works (Greater Lakes Upper Missississippi River Board of States Public Health & Environmental Manager 1992).
20. The construction location of this well will be at a site approved by the Division of Environmental Quality.
21. Centralizers shall be located no more than 60' apart the entire length of all strings of casing placed in the well, excepting those <60' in length.

(Continued)

CONDITIONS OF APPROVAL:

22. The well schematic and bid specifications describe the following:
Construct a well utilizing 12" casing to 50' for surface seal; 8" casing to seal undesirable zones; 6" casing extend to the total depth of well perforated in water bearing strata, All casing thicknesses will be .375" wall with full penetrating welds;
The seal materials will be a high solids bentonite (>30%) or a granular bentonite;
Disinfection of the well will be through 1 of 2 means with a residual of 50 mg/L with surging applied;
Well developement will be through air-lift, surging, overpumping depending on drilling technique, of rates up to 500 gpm;
Test pumping will utilize a step drawdown method
The 12" casing will be sealed its entire length.
23. The 8" casing will be sealed to a depth required to exclude any water of undesirable quality or to a depth between 50' and 130' where an aquitard with a minimum thickness of 4' is encountered.
24. Depending on the drilling technique utilized, the annular space shall remain open until the seal is placed. If at any time during or prior to placement the bore collapses, all tubular goods will be removed from the bore and another means of construction will be approved prior to redrilling the same bore.
25. Fifteen minutes into any pumping sequence after developement has occurred, the sand content shall be measured by an approved method or sent to an approved lab. If sand production exceeds 5 ppm., the department shall be notified.



Signature of Authorized Dept. Representative



Title

EXTENSION OF DRILLING PERMIT

Extension Approved by: _____

Approval Date: _____
Expires On: _____

Ident. No. 63-97-C-0527-000
Water Right No. 63-12397
0148

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
APPLICATION FOR DRILLING PERMIT

1. Name: MORES CREEK RIM RANCH WATER DISTRICT O 208-336-4951
Address: C/O CARL HAIR, CHAIRMAN
HC33 BOX 1143
BOISE ID 83706

2. Proposed Well Location: Township 04N, Range 04E, Sec. 27, NWSW
BOISE County

Street Address of Well Site: LOT 10, MORES CREEK RIM RANCH
IDAHO CITY ID

Lot, Block, and Subdivision: Lt 10
Blk
MORES CREEK RIM RANCH

3. Proposed Use of Well: Other
SUBDIVISION WELL

4. Well Construction Information:

- A. NEW WELL
 - B. Proposed Surface Diameter 8 In. Proposed Maximum Depth 600 Ft.
 - C. Anticipated Bottom Hole Temperature: 85 F or less (Cold water well)
- (NOTE: Construction diagrams and/or other information may be requested for monitor, low temperature geothermal, municipal and artesian wells.)

5. Construction Start Date: 9/15/1997

6. Anticipated Well Driller: (No. 9999)

NOTE: The actual well driller must be identified to IDWR prior to drilling commencement.

7. Applicant's Signature _____ Date _____

Title _____
(Owner, Firm Representative, Other)

Fee \$ 200.00 Received by _____ No. W022226 Date 5/ 2/1997

(Continued)

ACTION OF THE DEPARTMENT OF WATER RESOURCES

This permit is

Approved

Date:

9-22-97

If approved, this permit authorizes the construction or modification of a well subject to the following conditions. READ CAREFULLY!

CONDITIONS OF APPROVAL:

1. This drilling permit is valid for two (2) months from the approval date for the start of construction and is valid for one (1) year from the approval date for completion of the well unless an extension has been granted.
2. This permit does not constitute an approval of the District Health Department or the Idaho Department of Health and Welfare which may be required prior to construction of this well. The local Health Department should be contacted for septic tank/drainfield locations. Domestic wells must not be drilled closer than 100' from any drainfield and 50' from any septic tank. Public Water Supply wells must not be drilled closer than 100' from any drainfield or septic tank.
3. The well shall be constructed by a driller currently licensed in the state of Idaho who must maintain a copy of the drilling permit at the drilling site.
4. Approval of this drilling permit does not authorize trespass on the land of another party.
5. This permit does not constitute other local, county, state or federal approvals which may be required for construction of a well.
6. This drilling permit does not represent a right to divert and use the water of the State of Idaho.
7. If the bottom hole temperature of 85 Degrees F (29.44 oC) or greater is encountered, well construction shall cease and the well driller and the well owner shall contact the Department immediately.
8. Idaho Code, S 55-2201 - 55-2210 requires the applicant and/or his contractors to contact "Digline" (DigLine is a one-call center for utility notification) not less than 2 working days prior to the start of any excavation for this project. The "Dig Line " Number for your area is 1-800-342-1585.
9. Failure to construct the well in accordance with these conditions may result in the revocation of the drilling permit and constitute a violation of Idaho Law.
10. The uppermost unconfined aquifer shall be cased and sealed to exclude water from this zone from entering the well. All seals will be placed from the bottom up.
11. If an annular slurry seal of bentonite is to be utilized, a high (>30%) solids bentonite shall be pumped from the bottom up to land surface. The bentonite shall not contain chemical polymers which effect long term stability of the seal (and are often found in drilling fluid grade bentonites) but shall be a bentonite which has been specifically recommended by the manufacturer for use as a seal material in water wells.

(Continued)


CONDITIONS OF APPROVAL:

12. A 50% excess of seal material shall be on hand in the event of lost circulation. If the seal material does not make it back to the surface, tremieing or perforation and squeezing is to commence at the top of the tagged seal position and will continue until returns reach the surface or the department is satisfied that aquifers are sufficiently isolated and/or protected from waste and contamination.
13. If an annular space of at least 4 inches greater than the outside diameter of the casing is provided a granular bentonite or bentonite chips may be poured at the manufacturer's recommended rate or no greater than 50 pounds in five minutes. The pour shall also be presifted through 1/4 inch mesh screen to reduce the introduction of fines unless the annular space is free of water, ie. (above the water table and there is no cascading water). The top of the seal shall be tagged at regular intervals, ie. (30' intervals) during placement with a sinker bar or other appropriate device to ensure the seal is reaching the intended depth. If bridging occurs, the seal shall be tamped to its intended position or the Department will be contacted for evaluation.
14. The project engineer or geologist will be on site during seal placement should any peculiarities arise which require further evaluation. Any alteration of the proposed or herein modified well construction procedure shall be approved by the Department before they are undertaken.
15. If after the commencement of drilling a construction problem develops, another means of seal placement or seal material may be approved after the Department has had an opportunity to review proposed changes. A 24 hour review period will be provided for department personnel should said changes become necessary.
16. Drilling fluids shall be mixed with water which meets or exceeds drinking water standards.
17. The screened, perforated, filterpacked or otherwise open and commingled strata which are to be produced from, shall be of similiar hydraulic head, temperature and quality. If there are notable variations encountered as the well is drilled and/or developed, the Department will be notified for evaluation.
18. If the supply line is connected to the pump column below ground level, a pitless device will be utilized which provides a water tight seal through the casing. The pitless will be tested according to the means described by the U.S.EPA manual EPA-430/9-74-007. The test will be run in the presence of the engineer designing the surface distribution of the system.
19. Reference drilling specifications of the American Water Works Association Standard for Water Wells (ANSI/AWWA A100-90) and the Recommended Standards For Water Works (Greater Lakes Upper Mississippi River Board of States Public Health & Environmental Manager 1992).
20. The construction location of this well will be at a site approved by the Division of Environmental Quality.
21. Centralizers shall be located no more than 60' apart the entire length of all strings of casing placed in the well, excepting those <60' in length.

(Continued)

CONDITIONS OF APPROVAL:

22. The well schematic and bid specifications describe the following:
Construct a well utilizing 12" casing to 50' for surface seal; 8" casing to seal undesirable zones; 6" casing extend to the total depth of well perforated in water bearing strata. All casing thicknesses will be .375" wall with full penetrating welds;
The seal materials will be a high solids bentonite (>30%) or a granular bentonite;
Disinfection of the well will be through 1 of 2 means with a residual of 50 mg/L with surging applied;
Well development will be through air-lift, surging, overpumping depending on drilling technique, of rates up to 500 gpm;
Test pumping will utilize a step drawdown method
The 12" casing will be sealed its entire length.
23. The 8" casing will be sealed to a depth required to exclude any water of undesirable quality or to a depth between 50' and 130' where an aquitard with a minimum thickness of 4' is encountered.
24. Depending on the drilling technique utilized, the annular space shall remain open until the seal is placed. If at any time during or prior to placement the bore collapses, all tubular goods will be removed from the bore and another means of construction will be approved prior to redrilling the same bore.
25. Fifteen minutes into any pumping sequence after development has occurred, the sand content shall be measured by an approved method or sent to an approved lab. If sand production exceeds 5 ppm., the department shall be notified.


Signature of Authorized Dept. Representative


Title

EXTENSION OF DRILLING PERMIT

Extension Approved by: _____

Approval Date: _____

Expires On: _____

May 31, 2002

MORES CREEK RIM RANCHES WATER DISTRICT
HC 33 BOX 1940
BOISE, ID 83706

PROOF DUE NOTICE

RE: PERMIT NO. 63-12397

Dear Permit Holder:

One of the conditions of approval of the above referenced water permit was that proof of the extent of your beneficial use must be submitted to this office on or before August 01, 2002. (See last page of your approval permit or your last approved extension request.) Enclosed is a form which when accompanied by the license examination fee or a completed field examination report prepared by a certified water right examiner may be used to submit the required proof.


If you have not fully completed your project, and you or a previous owner of this permit have not received a prior extension of time, you may request an extension of time if the delay is for reasonable cause as provided in Section 42-204, Idaho Code. If you have been prevented from proceeding by a governmental agency or by litigation which might bring title to the water in question, more than one extension of time can be granted. An extension of time request form is enclosed for your convenience.

Either an acceptable proof of beneficial use submittal or an acceptable request for an extension of time must be received by this department on or before the above described proof due date. If neither is received, the department will send you a lapse notice. Within sixty (60) days of the mailing of the lapse notice, the permit will no longer be of any force nor effect.

Sincerely,

Deborah J. Gibson, Admin. Assistant
Water Allocation Bureau

Enclosures




STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
1 North Orchard Street, P.O. Box 83720
Boise, Idaho 83720-0098

Return Service Requested

CERTIFIED MAIL



7099 3220 0005 5178 3915



MORES CREEK RIM RANCHES WATER DIS
HC 33 BOX 1940
BOISE, ID 83706

NSW RECEIVED
JUN 4 2002
Department of Water Resources

83720-0098



August 6, 2002

MORES CREEK RIM RANCHES WATER DIST
C/O CARL HAIR
HC 33 BOX 1940
BOISE, ID 83706

LAPSE NOTICE

RE: PERMIT NO. 63-12397

Dear Permit Holder:

You are hereby notified that under the provisions of Section 42-218A, Idaho Code, the above referenced permit has lapsed and is of no further force nor effect. The department provided the proper forms to you in the proof due notice dated May 31, 2002. No further construction or additional development is authorized under this permit unless it is reinstated.

The permit can only be reinstated if you submit an acceptable proof of beneficial use or an acceptable request for extension of time to the department within sixty (60) days of the mailing of this lapse notice. An acceptable proof of beneficial use submittal must include the examination fee or a completed field examination report. A request for extension of time must be accompanied by a fifty dollar (\$50.00) fee.

Enclosed again for your use are a proof of beneficial use form and a request for extension of time form. Please note that only one extension of time can be granted unless the project has not been completed because of lack of a necessary approval by a government agency or by litigation which may bring title to the water in question.

Sincerely,

L. Glen Saxton, Chief
Water Allocation Bureau

Enclosures

CERTIFICATION OF MAILING
I hereby certify that on 8/6/02
~~a copy~~ a copy of this document was
deposited in the United States mail,
postage prepaid addressed to the
individual(s) named above.



STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES

North Orchard Street, P.O. Box 83720
Boise, Idaho 83720-0098

Return Service Requested


63-12397

POSTAL
ADDRESS

MORES CREEK RIM RANCHES WATER DIS
C/O CARL HAIR
HC 33 BOX 1940
BOISE, ID 83706

83720-0098/98

PRESORTED
FIRST CLASS



I certify that file No. 63 -12397

has been reviewed and is ready to be

MICROFILMED and DESTROYED.

Kari Lynn J.
Reviewer

11.8.02
Date