

RECEIVED

JUL 30 2018

RECEIVED

AUG 20 2018

82643

FORM 202 Rev. 09/16

STATE OF IDAHO

DEPARTMENT OF
WATER RESOURCES

Ident. No. 95-17621

RECEIVED

IDWR / NORTH

DEPARTMENT OF WATER RESOURCES

AUG 02 2018

APPLICATION FOR PERMIT

To appropriate the public waters of the State of Idaho

IDWR / NORTH

1. Name of applicant(s) Essential Oil Research Farm, LLC Phone (801) 221-6160
 Name connector (check one): ☐ and ☐ or ☐ and/or
 Mailing address 3125 W. Executive Parkway City Lehi
 State UT ZIP 84043 Email _____
2. Name of representative, if any Roxanne Brown, SPF Water Engineering, LLC Phone (208) 859-8428
 Mailing address 300 E. Mallard Dr., Suite 350 City Boise
 State ID ZIP 83706 Email rbrown@spfwater.com
- a. ☐ Send all correspondence for this application to the representative and not to the applicant OR
☒ Send original correspondence to the applicant and copies to the representative.
- b. ☒ The representative may submit information for the applicant but is not authorized to sign for the applicant OR
☐ The representative is authorized to sign for the applicant. Attach a Power of Attorney or other documentation.
3. Source of water supply groundwater which is a tributary of _____
4. Location of point(s) of diversion:

Twp	Rge	Sec	Govt Lot	1/4	1/4	1/4	County	Source	Local name or tag #
46N	3W	28			SW	NW	Benewah	groundwater	
46N	3W	28			SW	NW	Benewah	groundwater	

5. Water will be used for the following purposes:
- Amount 0.04 for commercial purposes from 3/1 to 6/15 (both dates inclusive)
 (cfs or acre-feet per year)
- Amount 0.04 for domestic purposes from 1/1 to 12/31 (both dates inclusive)
 (cfs or acre-feet per year)
- Amount _____ for _____ purposes from _____ to _____ (both dates inclusive)
 (cfs or acre-feet per year)
- Amount _____ for _____ purposes from _____ to _____ (both dates inclusive)
 (cfs or acre-feet per year)
6. Total quantity to be appropriated is (a) 0.04 cubic feet per second (cfs) and/or (b) _____ acre-feet per year (af).
7. Proposed diverting works:
- a. Describe type and size of devices used to divert water from the source. up to two wells
- b. Height of storage dam _____ feet; active reservoir capacity _____ acre-feet; total reservoir capacity _____ acre-feet. If the reservoir will be filled more than once each year, describe the refill plan in item 12. For dams 10 feet or more in height AND having a storage capacity of 50 acre-feet or more, submit a separate [Application for Construction or Enlargement of a New or Existing Dam](#). Application required? ☐ Yes ☐ No
- c. Proposed well diameter is _____ inches; proposed depth of well is _____ feet.
- d. Is ground water with a temperature of greater than 85°F being sought? ☐ Yes ☒ No
- e. If well is already drilled, when? _____; drilling firm _____;
 well was drilled for (well owner) _____; Drilling Permit No. _____

For Department Use

Received by AV Date 7/30/18 Time 11:30 Preliminary check by _____
 Fee \$ 100 Received by AV Receipt No. C105445 Date 7/30/18

8. Description of proposed uses (if irrigation only, go to item 9):
- Hydropower; show total feet of head and proposed capacity in kW. _____
 - Stockwatering; list number and kind of livestock. _____
 - Municipal; must complete and attach the Municipal Water Right Application Checklist.
 - Domestic; show number of households lodge kitchen, showers, and laundry for seasonal workers; 15 RV sites
 - Other; describe fully. Commercial water use in a 3,500 sq. ft. greenhouse for plant development prior to planting in fields for harvesting and processing as essential oils
9. Description of place of use:
- If water is for irrigation, indicate acreage in each subdivision in the tabulation below.
 - If water is used for other purposes, place a symbol of the use (example: D for Domestic) in the corresponding place of use below. See instructions for standard symbols.

TWP	RGE	SEC	NE				NW				SW				SE				TOTALS
			NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
46N	3W	28							D	D,C									

Total number of acres to be irrigated: _____

10. Describe any other water rights used for the same purposes as described above. Include water delivered by a municipality, canal company, or irrigation district. If this application is for domestic purposes, do you intend to use this water, water from another source, or both, to irrigate your lawn, garden, and/or landscaping? None.
11. a. Who owns the property at the point of diversion? applicant
- b. Who owns the land to be irrigated or place of use? applicant
- c. If the property is owned by a person other than the applicant, describe the arrangement enabling the applicant to make this filing: _____
12. Describe your proposal in narrative form, and provide additional explanation for any of the items above. Attach additional pages if necessary. Applicant proposes construction/use of up to two wells for use in a commercial greenhouse, and kitchen, shower rooms, and laundry for up to 25 seasonal workers.
13. Time required for completion of works and application of water to proposed beneficial use is 5 years (minimum 1 year).
14. **MAP OF PROPOSED PROJECT REQUIRED** - Attach an 8½" x 11" map or maps clearly identifying the proposed point of diversion, place of use, section #, township & range. The map scale shall not be less than two (2) inches equal to one (1) mile.


The information contained in this application is true to the best of my knowledge. I understand that any willful misrepresentations made in this application may result in rejection of the application or cancellation of an approval.

Signature of Applicant

Nick Walker
Print Name (and title, if applicable)

Signature of Applicant

Print Name (and title, if applicable)



● Proposed Point of Diversion (general location)

▨ Proposed Place of Use

Application for Permit



500

Feet



State of Idaho

Office of the Secretary of State

I, LAWERENCE DENNEY, Secretary of State of the State of Idaho, hereby certify that I am the custodian of the limited liability company records of this State.

I FURTHER CERTIFY That the annexed is a full, true and complete duplicate of the application for registration of foreign limited liability company of **ESSENTIAL OIL RESEARCH FARM, LLC**, a UTAH limited liability company, received and filed in this office on 3 June 2005 under the file number W 40009 , including any amendments filed thereto, as appears of record in this office as of this date.

Dated: February 22, 2018



Lawrence Denney
SECRETARY OF STATE

By

Spit Keel

FILED EFFECTIVE

253



APPLICATION FOR REGISTRATION OF FOREIGN LIMITED LIABILITY COMPANY

(Instructions on back of application)

2005 JUN -3 AM 10:10

SECRETARY OF STATE
STATE OF IDAHO

1. The name of the limited liability company is:

Essential Oil Research Farm, LLC

2. If the name of the limited liability company is not permissible or is not available in Idaho, the name the foreign limited liability company will use in Idaho is:

3. The jurisdiction under whose laws the limited liability company is organized is:
- Utah
-
- and the date of its formation was:
- 2/29/2000

4. The name and address of the registered agent in Idaho is:

Marcella King 701 N. Fork Coon Creek St. Maries, Idaho 83861

5. The address of the limited liability company's office in the jurisdiction under whose laws it is organized is:

3125 West Executive Parkway Lehi, Utah 84043

6. The address of the limited liability company's principal office, if other than the address in #5 above, is:

7. The address to which correspondence should be addressed is:

3125 West Executive Parkway

Lehi, Utah 84043

8. Signature of a manager, if any, or a member
-
- if there are no managers.

Signature

Typed Name

D. Gary Young

Manager ☒ Member ☐

Secretary of State use only

g:\corp\Norman\LLC form\app\form\reg\idapp66

Revised 06/2002

Webb Form

 IDAHO SECRETARY OF STATE
 06/03/2005 05:00
 CK: 546376 CT: 172899 DH: 814142
 1 @ 100.00 = 100.00 REGFORLLC W 2

60 4000 9



Utah Department of Commerce
Division of Corporations & Commercial Code
160 East 300 South, 2nd Floor, PO Box 146705
Salt Lake City, UT 84114-6705
Service Center: (801) 530-4949
Toll Free: (877) 526-3994 Utah Residents
Fax: (801) 530-6438
Web Site: <http://www.commerce.utah.gov>

05/17/2005
4726318-016005172005-452461

CERTIFICATE OF EXISTENCE

Registration Number:	4726318-0160
Business Name:	ESSENTIAL OIL RESEARCH FARM, LLC
Registered Date:	February 29, 2000
Entity Type:	Limited Liability Company
Current Status:	Good Standing

The Division of Corporations and Commercial Code of the State of Utah, custodian of the records of business registrations, certifies that the business entity on this certificate is authorized to transact business and was duly registered under the laws of the State of Utah. The Division also certifies that this entity has paid all fees and penalties owed to this state; its most recent annual report has been filed by the Division; and, that Articles of Dissolution have not been filed.



Kathy Berg

Kathy Berg
Director
Division of Corporations and Commercial Code

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

1. WELL TAG NO. D 59435

Drilling Permit No. 861829
Water right or injection well # _____

2. OWNER:

Name Young Living
Address 701 N. Fork Coon Creek Rd
City St. Maries State ID Zip 83861

3. WELL LOCATION:

Twp. 46 North ☒ or South ☐ Rge. 3 East ☐ or West ☒
Sec. 28 1/4 SW 1/4 NW 1/4

Gov't Lot _____ County Benewah
Lat. 47 ° 18:326N (Deg. and Decimal minutes)
Long. 116 ° 44:068W (Deg. and Decimal minutes)
Address of Well Site 701 N. Fork Coon Creek Rd/ benewah rd to mm then 2 miles up coon ck City St. Maries
(Give at least name of road - Distance to Road or Landmark)

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation ☐ Thermal ☐ Injection
☐ Other _____

5. TYPE OF WORK:

☒ New well ☐ Replacement well ☐ Modify existing well
☐ Abandonment ☐ Other _____

6. DRILL METHOD:

☒ Air Rotary ☐ Mud Rotary ☐ Cable ☐ Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft³)	Placement method/procedure
bentonite	0	58	1250 lbs	pour around pipe

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
6"	+2	-58	2.50	steel	☒	☐	☐	☐
4"	-8	295	200psi	pvc	☐	☒	☐	☐

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 58ft standard shoe

9. PERFORATIONS/SCREENS:

Perforations ☒ Y ☐ N Method skill saw
Manufactured screen ☐ Y ☐ N Type _____
Method of installation _____

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
-55	295	1/4x5	150	4"	pvc	200 psi

Length of Headpipe _____ Length of Tailpipe _____

Packer ☐ Y ☒ N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft³)	Placement method
none				

11. FLOWING ARTESIAN:

Flowing Artesian? ☐ Y ☒ N Artesian Pressure (PSIG) _____
Describe control device well cap

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 40 Static water level (ft) 28
Water temp. (°F) 48 Bottom hole temp. (°F) _____
Describe access port well cap

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)
50 gpm	airlift at 380ft	for 3.5hrs

Test method:

Pump ☐ Bailer ☐ Air ☒ Flowing artesian ☐
☐ ☐ ☐ ☐

Water quality test or comments: cold and cloudy

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
10	0	15	clay-red		
	15	40	clay-white		
	40	115	basalt-broken w/water 1/2 gpm	x	
6	115	135	basalt-hard w/water 3 1/2 gpm	x	
	135	210	basalt-soft w/water 6gpm	x	
	210	215	clay-tan		
	215	225	basalt-soft		
	225	265	clay-tan		
	265	380	shale-soft w/water 50gpm total at 380 ft	x	
			25 gpm total at 270 ft	x	
			50 gpm total at 280 ft	x	
			50 gpm total at 380 ft	x	
			liner stopped at 295 ft		

RECEIVED

SEP 07 2011

IDWR / NORTH

Completed Depth (Measurable): 295 ft

Date Started: 8-25-11 Date Completed: 8-30-11

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Interstate Drilling LLC Co. No. 689

*Principal Driller Ryan Suchak Date 8-30-11

*Driller Ryan Suchak Date 8-30-11

*Operator II Ryan Suchak Date 8-30-11

Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.

46N 03W 28

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Location Corrected by IDWR To:

T46N R03W Sec. 28 SWSNW

By: mciscell 2013-10-17

1. WELL TAG NO. D 59576

Drilling Permit No. 862502

Water right or injection well # _____

2. OWNER:

Name Young Living FarmsAddress P.O. Box 246City St. Maries State ID Zip 83861

3. WELL LOCATION:

Twp. 46 North ☒ or South ☐ Rge. 3 East ☐ or West ☒Sec. 28 1/4 SW 1/4 NW 1/4Gov't Lot _____ County BenewahLat. 47 18:33N (Deg. and Decimal minutes)Long. 116 43:786W (Deg. and Decimal minutes)Address of Well Site 701 N. Fork Coon Creek Rd/ benewah ck tomm 5 then 2 miles up coon c City St. Maries

(Give at least name of road + distance to road or landmark)

Lot. _____ Blk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation ☐ Thermal ☐ Injection☐ Other _____

5. TYPE OF WORK:

☒ New well ☐ Replacement well ☐ Modify existing well☐ Abandonment ☐ Other _____

6. DRILL METHOD:

☒ Air Rotary ☐ Mud Rotary ☐ Cable ☐ Other _____

7. SEALING PROCEDURES:

Seal material From (ft) To (ft) Quantity (lbs or ft³) Placement method/procedure

bentonite 0 98 1800 lbs pour around pipe

8. CASING/LINER:

Diameter (nominal) From (ft) To (ft) Gauge/Schedule Material Casing Liner Threaded Welded

6" +2 98 2.50 steel ☒ ☐ ☐ ☒4" -18 186 200psi pvc ☐ ☒ ☐ ☐☐ ☐ ☐ ☐☐ ☐ ☐ ☐☐ ☐ ☐ ☐Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 98 ft geo rockfor shoe

9. PERFORATIONS/SCREENS:

Perforations ☒ Y ☐ N Method skill sawManufactured screen ☐ Y ☐ N Type _____

Method of installation _____

From (ft) To (ft) Slot size (inches) Diameter (nominal) Material Gauge or Schedule

38 186 1/4x5 140 4" pvc 200 psi

☐ ☐ ☐ ☐ ☐ ☐

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 110 ft Static water level (ft) 65 ftWater temp. (°F) 47 Bottom hole temp. (°F) _____Describe access port well cap

Well test: Drawdown (feet) Discharge or yield (gpm) Test duration (minutes) Pump Bailer Air Flowing artesian

50+ gpm airlift at 280ft for 3 hrs ☐ ☐ ☒ ☐☐ ☐ ☐ ☐☐ ☐ ☐ ☐Water quality test or comments: cold and cloudy

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in) From (ft) To (ft) Remarks, lithology or description of repairs or abandonment, water temp. Water Y N

10 0 3 clay-brown ☐ ☐3 12 clay-tan ☐ ☐12 28 clay-brown ☐ ☐28 82 clay-tan ☐ ☐6 82 165 basalt-broken w/water 30 gpm ☒165 195 granite-red-broken/wquarts ☒w/water 20+ gpm ☐195 280 granite multi-color soft ☒total gpm 50+ at 280ft ☐☐ ☐Completed Depth (Measurable): 186 ftDate Started: 11-7-11 Date Completed: 11-8-11

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Interstate Drilling LLC Co. No. 689*Principal Driller Ryan Suchak Date 11-10-11*Driller Ryan Suchak Date 11-10-11*Operator II Ryan Suchak Date 11-10-11

Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.

46N 03W 28



State of Idaho

DEPARTMENT OF WATER RESOURCES

Northern Region • 7600 N. Mineral Drive, Suite 100 • Coeur d'Alene, Idaho 83815-7763
Phone: (208) 762-2800 • Fax: (208) 762-2819 • Website: www.idwr.idaho.gov

C.L. "BUTCH" OTTER
Governor

GARY SPACKMAN
Director

August 29, 2018

ESSENTIAL OIL RESEARCH FARM LLC
3125 W EXECUTIVE PARKWAY
LEHI, UT 84043

Application For Permit No. 95-17621

Dear Applicant(s):

The Department of Water Resources has received your water right application. Please refer to the number referenced above in all future correspondence regarding this application.

A legal notice of the application has been prepared and is scheduled for publication in the ST MARIES GAZETTE RECORD on 9/5/2018 and 9/12/2018. Protests to this application may be submitted for a period ending ten (10) days after the second publication.

If the application is protested, you will be sent a copy of each protest. All protests must be resolved before the application can be considered for approval. If the protest(s) cannot be resolved voluntarily, the Department will conduct a conference and/or hearing on the matter.

If the application is not protested, the Department will process your application and notify you of any action taken on the application. If your application is approved, the Department will send you a copy of the permit.

Please contact this office if you have any questions regarding the application.

Sincerely,

Tammy Alleman
Administrative Assistant

CC:

SPF WATER ENGINEERING LLC
C/O ROXANNE BROWN
300 E MALLARD DR STE 350
BOISE, ID 83706

Alleman, Tammy

From: Alleman, Tammy
Sent: Wednesday, August 29, 2018 9:10 AM
To: 'bri@smgazette.com'
Subject: Legal Notice for WR#95-17621
Attachments: 95-17621 Legal Notice.doc

Please publish the enclosed legal notice in the **St. Maries Gazette Record** on the dates indicated September 5th and September 12th (once a week for two consecutive weekly issues). If you cannot publish the notice on the proposed dates, please contact us immediately. Please send a proof once you have the article ready for print for our review.

An affidavit of publication must be submitted to the Department along with the publication bill. Please send the affidavit and bill to this office before 9/24/2018. Your cooperation is appreciated.

Thank you,

Tammy

*Tammy Alleman
Administrative Assistant
Idaho Department of Water Resources
7600 North Mineral Drive, Suite 100
Coeur d'Alene, ID 83815
Tammy.Alleman@idwr.idaho.gov
208-762-2800 Phone
208-762-2819 Fax*

The following application(s) have been filed to appropriate the public waters of the State of Idaho:

95-17621

ESSENTIAL OIL RESEARCH FARM LLC

3125 W EXECUTIVE PARKWAY

LEHI, UT 84043

Point of Diversion SWNW

S28 T46N R03W

BENEWAH County

Source GROUND WATER

Point of Diversion SWNW

S28 T46N R03W

BENEWAH County

Source GROUND WATER

Use: COMMERCIAL

03/01 to 06/15 0.04 CFS

Use: DOMESTIC

01/01 to 12/31 0.04 CFS

Total Diversion: 0.04 CFS

Date Filed: 7/30/2018

Place Of Use: COMMERCIAL

T46N R03W S28 SENW

Place Of Use: DOMESTIC

T46N R03W S28 SWNW SENW

Permits will be subject to all prior water rights. For additional information concerning the property location, contact Northern Region office at (208) 762-2800. Protests may be submitted based on the criteria of Idaho Code § 42-203A. Any protest against the approval of this application must be filed with the Director, Dept. of Water Resources, Northern Region, 7600 N MINERAL DR STE 100, COEUR D'ALENE ID 83815-7763 together with a protest fee of \$25.00 for each application on or before 9/24/2018. The protestant must also send a copy of the protest to the applicant.

GARY SPACKMAN, Director

Published on 9/5/2018 and 9/12/2018

Alleman, Tammy

From: Alleman, Tammy
Sent: Wednesday, August 29, 2018 9:12 AM
To: June.Bergquist@deq.idaho.gov
Cc: 'Anna.Moody@deq.idaho.gov'
Subject: Request for Comments on WR# 95-17621
Attachments: 95-17621 Application for Permit.pdf

Dear Department of Environmental Quality:

The Department of Water Resources is seeking written comment and/or recommendations from your agency regarding the above referenced water right applications. You can find copies of the applications attached to the email and also at: <http://www.idwr.idaho.gov/apps/ExtSearch/WRAJSearch/WRADJSearch.aspx>.

This office can publish notice of the applications as soon as the initial review is completed; therefore, your prompt response to this request is appreciated. If your agency desires to formally protest the approval of the application(s), you may do so after the notice is published by filing a written protest along with a \$25.00 filing fee within 10 days after final publication. The deadline for comments on the applications is September 24, 2018.

Please contact the Northern Region Office at (208) 772-2800 if you have any questions regarding the applications.

Thank you,

Tammy

*Tammy Alleman
Administrative Assistant
Idaho Department of Water Resources
7600 North Mineral Drive, Suite 100
Coeur d'Alene, ID 83815
Tammy.Alleman@idwr.idaho.gov
208-762-2800 Phone
208-762-2819 Fax*

MEMORANDUM

Date: August 29, 2018
To: Water Right File 96-17621
From: smaxey
Re: APPLICATION DATE STAMPS

APPLICATION 95-17621 HAS THREE DATE STAMPS.

THE FIRST (7/30/2018) DATE STAMP (BLUE INK) IS FROM THE IDWR STATE OFFICE. APPLICATION WAS FORWARDED TO IDWR NORTHERN AND RECEIVED A DATE STAMP OF 8/2/2018.

THE SECOND IDWR NORTHERN DATE STAMP (8/20/2018) IS WHEN THE APPLICATION WAS RE-RECEIVED AT IDWR NORTHERN. THE APPLICATION WAS RETURNED, IN ERROR, TO THE APPLICANT DUE TO QUESTIONS EXPLAINED IN IDWR'S 8/4/2018 LETTER. QUESTIONS WERE SATISFACTORILY ANSWERED BY THE APPLICANT'S REPRESENTATIVE IN A PHONE CALL AND IN THE SPF ENGINEERING LETTER DATED 8/15/2018.

DATE OF APPLICATION RECEIPT AT IDWR STATE OFFICE (7/30/2018) REMAINS IN EFFECT AS PRIORITY DATE.



RECEIVED

AUG 20 2018

IDWR / NORTH

August 15, 2018

Shaun Maxey
IDWR Northern Region
7600 N. Mineral Drive, Suite 100
Coeur d'Alene, Idaho 83815-7763

Delivered via Email: shaun.maxey@idwr.idaho.gov

Re: Application for Permit – Essential Oil Research Farm, LLC; SPF Job No. 775.0030

Dear Mr. Maxey,

After our telephone conversation today, the following information is provided in response to your letter dated August 4, 2018. Our response is organized to correspond with the bullet points in your letter.

In response to your first point, we agreed the map labels are sufficient, given the existing wells may or may not be used for the purpose proposed by the application and it is anticipated the well or wells will be located in the general area indicated on the map.

In response to your second point, Item 5 and Item 8(d) are correct as written.

In response to your third point, the total quantity to be appropriated listed at Item 6(a) is correct as written.

In response to your fourth point, the description of the delivery system shown at Item 7(a) is correct as written. Obviously, the groundwater will be delivered from the well or wells through a water distribution system.

In response to your fifth point, a well upgrade fee will be submitted if the applicant chooses to use an existing well previously permitted for domestic use. This can be determined at the time a beneficial use field exam is conducted.

In response to your sixth point, RV sites are for domestic use, not commercial use, as indicated on the application.

In response to your seventh point, the map is correctly labeled as to the proposed place of use when Item 9 is also considered.

In response to your eighth point, the proposed use does not meet criteria for public water system (PWS) permitting by Idaho Department of Environmental Quality. A PWS number is not required.

We understand the original application was returned to the applicant. The application will be returned to IDWR separately. Please contact SPF with any additional questions.

Best Regards,

A handwritten signature in blue ink that reads "Roxanne Brown". The signature is fluid and cursive, with the first name and last name clearly distinguishable.

Roxanne Brown
Sr. Water Rights Specialist

CC: Linda Jones, Holland & Hart via email



State of Idaho

DEPARTMENT OF WATER RESOURCES

Northern Region • 7600 N. Mineral Drive, Suite 100 • Coeur d'Alene, Idaho 83815-7763
Phone: (208) 762-2800 • Fax: (208) 762-2819 • Website: www.idwr.idaho.gov

C.L. "BUTCH" OTTER
Governor

GARY SPACKMAN
Director

August 4, 2018

****Time Sensitive Response Required****

Essential Oil Research Farm LLC
3125 W Executive Parkway
Lehi, UT 84043

Re: Application for Permit (parcel RP46N03W284700A) (Rule 35 Application Requirements)

Dear Applicant:

Idaho Department of Water Resources (IDWR) received your Application for Permit on July 30, 2018, at our State Office, to divert water from two Benewah County wells (groundwater). The Application is unacceptable for filing because it was not accompanied by a map showing all well locations and because it lacks sufficient well information to determine if existing wells, or new wells, will be used. One existing well on the property has a different legal description than shown on the Application. Your Application with map, and IDWR well reports, are enclosed.

Please review the Application and phone me at (208) 762.2816 for assistance to correct your Application and complete the following steps:

- Finish map well labels, Line 4 Legal Description & (Existing Wells) Tag Number.
- Review line 5 and line 8 (d) for lodge, number of Domestic hookups, & CFS quantity.
- Review Line 6 (a) Total CFS quantity.
- Complete description of water system line 7(a).
- Review if well upgrade fees are required and complete Line 7(c) and 7(e).
- Review Line 8 (d) RV site use (rental and / or employee).
- Review map labeling for Domestic & Commercial uses.
- Determine if a Public Water Supply (PWS) number has been assigned or is required.

Please telephone me about your Application. Your **corrections must be received no later than September 10, 2018**. IDWR will take steps to terminate your Application, if no response is received, pursuant to Idaho Code § 42-204.

Respectfully,

Shaun M. Maxey
Sr. Water Resource Agent
Idaho Department of Water Resources, Northern Region

Maxey, Shaun

From: Jamie Barton <JBarton@phd1.idaho.gov>
Sent: Friday, August 03, 2018 3:06 PM
To: Maxey, Shaun
Cc: Jason Peppin
Subject: RE: New RV park or seasonal employee RV sites

Shaun,

Thank you for checking. They should contact myself for the regulatory requirements for a PWS; I don't believe it currently has a PWS number. They also need to get in touch with Jason Peppin in our office who oversees Benewah county for septic permitting but I can give them that direction when they contact me.

Thanks,

Jamie

From: Maxey, Shaun <Shaun.Maxey@idwr.idaho.gov>
Sent: Friday, August 03, 2018 2:52 PM
To: Jamie Barton <JBarton@phd1.idaho.gov>
Subject: New RV park or seasonal employee RV sites

Jamie:

IDWR has received an incomplete Application for Permit for a new Water Right on a lavender farm off Benewah Creek in Benewah County (T46N R03W S. 28). The Application is unclear if existing wells or new wells will be used. It indicates 15 RV sites and facilities for a kitchen, laundry, and shower rooms for up to 25 workers. It is not clear if all the RV sites are for workers, rentals, etc.

Should the Applicant's representative be contacting a Panhandle Health office in Saint Maries or you about their water system and a PWS number?

I'm unsure if this proposal requires a well site approval.

Thanks,

Shaun

Shaun M. Maxey
Sr. Water Resource Agent
Idaho Department of Water Resources, Northern Region
7600 N Mineral DR Suite 100
Coeur d'Alene, ID 83815-7763
Phone (208) 762.2816 /2800
Fax (208) 762.2819
www.idwr.idaho.gov