

Nelson, Dan

From: Nelson, Dan
Sent: Wednesday, December 27, 2017 10:10 AM
To: sking@spfwater.com
Subject: Permit 25-14425

Hello Scott,

I called earlier today, and left a message for you to call me back. Since I wasn't able to contact you by telephone, I thought it would be best if I send this email to explain what I need. I could also give you the links to the measurement requirements as needed. I am working through the second field report for permit 25-14425, and I found the church plans to use a rated section to address the measurement requirement for Sellars Creek. Using a rated section is acceptable as long as there is a plan and a rating curve already established. I didn't see the plan or the rating curve for the rated section in your field report.

Please review the "Minimum Acceptable Standards and Requirements for Open Channel and Closed Conduit Measuring Devices," Section 1B. You can find the Minimum Acceptable Standards at <http://www.idwr.idaho.gov/files/water-measurement/Measuring-Devices-Minimum-Acceptable-Standards.pdf>.

Also review the "State of Idaho Department of Water Resources Water Measurement Guidelines," Section 10. You can find the Measurement Guidelines at <http://www.idwr.idaho.gov/files/water-measurement/IDWR-Water-Measurement-Reporting-Guidelines.pdf>.

We will need the measurement plan with the established rating curve to move forward with licensing. This should have been done prior to diversion, so the rating curve should already be available to the permit holder.

Thank you.

Daniel Nelson
Water Right Analyst 3
Idaho Department of Water Resources
Telephone (208) 287-4856
Fax (208) 287-6700 (attn: Dan Nelson)