

~~DRAFT~~ AGENDA

Meeting - Stipulations: City of Boise Permit 63-34326; License Application/Permits 63-9138 & 63-9139

March 6, 2018 @ 1:30 p.m.

IDWR Room 602 B

1. Introductions
2. Permit 63-34326 Stipulation 2018 annual meeting:
 - a. Section II.C.4 to II.C.6 review and criteria
 - b. Review Boise Low Temperature Geothermal Monitoring Data for Water Year 2017 (Ken Neely WY 2017 Report)
 - c. Review WY 2016 and WY 2017 actual production as adjusted for heating degree days (City 1-30-2018 report)
 - d. Projected WY 2018 production (City)
 - e. Production limit review
3. 63-9139 draft license and Permits 63-9138/63-9139 Stipulation annual meeting:
 - a. Draft license and proposed conditions review and discussion
 - b. Next steps for license and stipulation/petition proceeding
4. Wrap up discussion

Mike McVay, Bob Maynard, Jon Gunnerson, Charlie Honsinger, John Roldan, Emmi Blades, Chris Cook, Dana Hofstetter, Angela Kaufmann, Erik Boe, Ken Neeley, Lyndon Nguyen, Bruce Smith, Ali Breshears

Bob outlined the purpose of the meeting was to discuss annual review of aquifer production and condition, discuss production limits under new permit, and review draft license for 63-9139.

Ken discussed condition of aquifer – steady conditions for well-head pressures, water levels and temperatures in Boise Front system. Introduced Mike McVay as new watermaster for Stewart Gulch.

Jon discussed city production for 2018 – 185 mg to date and 300 mg projected for the year. Four new buildings on line this year and a couple new ones anticipated for next year. Jon discussed current production well temperatures have been steady at 177 degrees F, but addition of a third authorized well into production (as a backup) could change temperature in future years because the third well tested at 162 degrees F. Seems the further west results in lower temperatures for wells at nearly the same depth.

Bob confirmed no request by city to increase production limit for this year. No need for IDWR to issue an order.

License review – Erik will address application date listed on the draft; Bob confirmed that the POU description was accurate; Jon clarified that the new permit will describe additional areas; and Erik will address the injection well number. Dana suggested adding the injection well to the POD section of the license; Jeff clarified that the injection well was not part of the diversion system; Dana pointed out a need to authorize acceptable injection wells, so the condition should include language suggesting that the injection well is an approved well; IDWR can add some language addressing the issue. Dana suggested language be added that permit 63-9138 be relinquished; Jeff said 63-9138 will be addressed separately because the license for 63-9139 is not contingent on relinquishing 63-9138.

There was a lot of discussion about the need to reference the stipulated agreement in the license. Bob will try to draft some language to incorporate some or all of the agreement into the license in some way, at least to allow the license to be issued and then address the issue down the road to decide if and how certain components of the agreement can be continued or terminated as necessary.

Bob will share draft language with IDWR and parties by March 21 and allow a couple of weeks for comments and then IDWR can proceed with licensing if acceptable.