



RECEIVED

JAN 19 2018

DEPARTMENT OF
WATER RESOURCES

January 19, 2018

Shelley Keen
Idaho Department of Water Resources
P.O. Box 83720
Boise, ID 83720-0098

Subject: Annual Monitoring Report for Permits 63-32680, 63-33207, 63-33296, and 63-34038

Dear Shelley:

Enclosed please find one copy of the 2017 monitoring report for permits 63-32680, 63-33207, 63-33296, and 63-34038.

This report presents the fourth year of monitoring under permits 63-32680 and 63-33296 and the second year of monitoring under permits 63-33207 and 63-34038. These permits share some of the same diversion points as permits 63-32680 and 63-33296, so it made sense to combine the monitoring data into a single comprehensive report.

Please contact me with any questions.

Sincerely,

A handwritten signature in blue ink, appearing to read "Terry M. Scanlan", is written over a horizontal line.

Terry M. Scanlan, P.E., P.G.

Enclosure

Cc: Steve Meyer – CS Beef Packers
Vic Conrad – JR Simplot Company
Ann Vonde, Deputy Attorney General – Attorney for Idaho Department of Corrections
Michael Lawrence, Givens Pursley – Attorney for Suez

**2017 MONITORING REPORT FOR WATER RIGHT
PERMIT NOS. 63-32680, 63-33207, 63-33296, AND
63-34038**


Prepared for

**CS Beef Packers, LLC
17365 South Cole Road
Kuna, ID 83634**

Prepared by

**SPF Water Engineering, LLC
300 East Mallard, Suite 350
Boise, Idaho 83706
(208) 383-4140**

January 2018



**SPF WATER
ENGINEERING**

Executive Summary

This report is the fourth annual report prepared as required by the monitoring plan for water right permits 63-32680 and 63-33296 and the second annual report prepared for permits 63-34038 and 63-33207.

Permits

1. Water right permits 63-32680 and 63-33296 authorize irrigation of up to 784 acres, with a combined maximum diversion rate of 11.76 cfs (5,278 gpm) and a maximum annual diversion volume of 3,528 acre feet (4.5 acre feet per acre).
 - a. A condition of water right permits 63-32680 and 63-33296 is compliance with an approved monitoring plan. The monitoring plan requires monitoring of water levels and pumping volumes, and includes specific requirements for monitoring equipment at a dedicated monitoring well and at each supply well.
2. Water right permit 63-33207 authorizes diversion of 3.0 cfs for industrial purposes.
 - a. The permit requires measurement of water levels in one well authorized under the permit on a monthly basis and monthly measurements of flow rate and diversion volume.
3. Water right permit 63-34038 authorizes diversion of 3.2 cfs for irrigation of 160 acres and 4.0 cfs for industrial purposes, with a maximum diversion rate of 4.0 cfs.
 - a. The permit requires measurement of water levels in each well authorized under the permit shall on a monthly basis and monthly measurements of flow rate and diversion volume.

2017 Permit Activities

4. One irrigation supply well (Irrigation Well No. 3) was put into service for the first time and monitored throughout the 2017 irrigation season.
5. Two industrial supply wells (Plant Wells 1 and 2) were put into service for the new CS Beef packing plant. These wells were monitored in 2017.
6. The sounding tube in Irrigation Well No. 1 is pinched, preventing reinstallation of a transducer. Water levels can now be measured, but the presence of pump oil in the well makes water level readings difficult. The airline water level gauge was recalibrated in December 2017. The transducer will be installed in the adjacent Drill Water Supply Well as a surrogate for Well No. 1.
7. The pump, sounding tube, airline gage, and transducer in Irrigation Well No. 2 were reinstalled, and the pump was used during the irrigation season.

8. A transducer was installed in Irrigation Well No. 3 during March 2017. The transducer became lodged in the sounding tube during the irrigation season, but was freed and retrieved in November 2017. At the time of retrieval, the transducer cable was heavily corroded so the transducer and cable were temporarily removed. The transducer was reinstalled with a new stainless-steel cable in December 2017.
9. Work items to be completed in 2018 include (1) installing a water-level transducer in the Drill Supply Well and (2) repairing or re-calibrating flow meters in all three irrigation wells.
10. Based on the surveyed measuring point elevation at the monitoring well, static water level elevations at the monitoring well ranged from approximately 2590 to 2596 feet. Water levels in November 2017 were roughly 1 foot higher compared to November 2016.
11. The flow totalizer on Irrigation Well No. 1 stopped working sometime in June so an accurate totalizer reading was not available. Totalizing flow meter measurements from Irrigation Well No. 2 indicate a total diversion volume of 182.3 acre-feet, but these measurements showed very little change after June and are therefore suspect. The flow meter at Irrigation Well No. 3 indicated diversions of 758.23 acre-feet in 2017. Instantaneous readings from this flow meter showed wide fluctuations, which made the totalizer readings also suspect. Due to these flow meter problems, power records for each of the irrigation wells were obtained from Idaho Power and used to estimate approximate total diversion volumes for 2017. Based on this analysis, roughly 1,102 acre-feet were diverted from Irrigation Well No. 1, 873 acre-feet from Irrigation Well No. 2, and 786 acre-feet from Irrigation Well No. 3, for total estimated irrigation diversion of approximately 2,761 acre-feet. These diversions are authorized under permits 63-32680, 63-33296, 63-33207 and 63-34038.
12. Total diversion volume in 2017 for the Plant wells was 888.74 acre-feet, with 713.18 acre-feet from Plant Well #1 (East) and 175.56 acre-feet from Plant Well #2 (West). These diversions are covered by permits 63-33207 and 63-34038.

Table of Contents

1. Background.....	1
1.1. Applicable Water Right Permits.....	1
1.1.1. Permits 63-32680 and 63-33296	1
1.1.2. Permit 63-33207.....	2
1.1.3. Permit 63-34038.....	2
1.2. Project Site.....	2
2. 2017 Activities.....	5
2.1. Water Level Monitoring	5
2.2. Flow Monitoring.....	7
3. Summary	10

List of Figures

Figure 1. Project Location Map	4
Figure 2. Water Level Hydrograph through 12/29/2017.....	7

List of Tables

Table 1. Authorized Points of Diversion and Well Locations.....	3
Table 2. Irrigation Wells Monthly Flow Monitoring	8
Table 3. Irrigation Well Volume Estimates Based on Power Consumption.....	9
Table 4. Plant Wells Monthly Flow Monitoring.....	9
Table 5. Plant Water Use	10

Appendices

Appendix A: Water Right Reports

Appendix B: Well Driller's Reports for Production and Monitoring Wells

Appendix C: Totalizer Photos

Appendix D: Water Level Data

1. BACKGROUND

1.1. Applicable Water Right Permits

Four water right permits utilize wells monitored as part of this monitoring program. Water right permit reports are provided as Appendix A and the permits are described below.

1.1.1. Permits 63-32680 and 63-33296

Kuna Cole-880, LLC, Azel Development Group, LLC, Boise Investment Group, LLC, Noelle Holdings, LLC, as tenants in common, applied for water right 63-32680 on May 22, 2007. The water right application sought 7.0 cfs for municipal use by 2250 homes as part of a proposed planned community. The application was amended on September 1, 2009 to seek 5.22 cfs for irrigation of 261 acres, and was subsequently assigned to Kirkwood Bank & Trust Company on September 22, 2011.

Kuna Cole-880, LLC, Azel Development Group, LLC, Boise Investment Group, LLC, Noelle Holdings, LLC, as tenants in common, applied for water rights 63-33296 on November 6, 2009. The water right application sought 15.22 cfs for irrigation of 761 acres. The application was assigned to Kirkwood Bank & Trust Company on September 22, 2011 and was subsequently amended to seek 10.46 cfs for irrigation of 521 acres on January 12, 2012.

Both water right permit applications were protested by United Water Idaho and the Idaho Department of Corrections. A stipulation was entered between the protestants and the applicant to settle the protests. The stipulation included combined limits on diversion rates and irrigated acres, and the requirement for compliance with an approved monitoring plan.

The permits were approved by the Idaho Department of Water Resources (IDWR) on July 17, 2013. The two permits authorize irrigation of up to 784 acres within the property, with a combined maximum diversion rate of 11.76 cfs (5,278 gpm) and a maximum annual diversion volume of 3,528 acre-feet (4.5 acre feet per acre).

- Permit 63-32680 authorizes diversion of up to 5.22 cfs for irrigation of up to 261 acres within a 360-acre permissible located in Sections 11 and 14. The right authorizes construction of up to 2 wells located in Sections 11 and 14. Priority date is May 22, 2007.
- Permit 63-33296 authorizes diversion of up to 10.46 cfs for irrigation of up to 523 acres located within a 1022-acre permissible place of use that covers the entire property. The right authorizes construction of up to 2 wells located in Sections 12 and 13. Priority date is November 6, 2009.

Kirkwood Bank assigned the permits to Ray and Susan Montierth on March 14th, 2014. Ray and Susan Montierth assigned the permits to J.R. Simplot Company on January

6, 2015. J.R. Simplot Company assigned the permits to CS Property Development LLC on April 6, 2016.

1.1.2. Permit 63-33207

Jim Hutchings applied for water right 63-33207 on May 15, 2009 and amended the permit on March 24, 2010. The permit application sought 3.0 cfs for irrigation of 200 acres. The permit was approved on September 25, 2013, and assigned to J.R. Simplot Company on March 26, 2015. The application was amended to change the use to industrial purposes, and was subsequently assigned to CS Property Development, LLC on April 6, 2016. There is a 700-acre-foot annual diversion limit associated with this permit. The permit requires monthly measurement of flow rate and volume, and requires monthly water level measurements from one point of diversion authorized for this right.

1.1.3. Permit 63-34038

J.R. Simplot Company applied for water right 63-34038 on February 6, 2015 and amended the application on June 26, 2015. The amended permit application sought 3.2 cfs for irrigation of 160 acres and 4.0 cfs for industrial use, with a total diversion rate of 4.0 cfs. The permit was approved on October 26, 2015, and assigned to CS Property Development LLC on April 6, 2016. The permit requires monthly measurement of flow rate and volume, and requires monthly water level measurements from all points of diversion authorized for this right.

1.2. Project Site

The project area is located approximately 7 miles southeast of Kuna, Idaho, in portions of Sections 11, 12, 13, 14, 23, and 24 of Township 1 North, Range 1 East, and Section 6 of Township 1 North, Range 2 East, Ada County, Idaho (Figure 1). Total area is approximately 1900 acres.

The project site is accessed from Cole Road. The northern portion of the property is bisected by the Union Pacific Railroad.

Two irrigation wells (Irrigation Wells 1 & 2), a monitoring well, and a drill water supply well were constructed in 2014. Two plant industrial water supply wells were constructed in 2015. One irrigation well (Irrigation Well 3) was constructed in 2016. Well locations and authorized diversion points are summarized in Table 1 and driller's reports for each listed well are provided in Appendix B.

Center pivot sprinklers were installed in the winter of 2014-15, and irrigation began in 2015.

Table 1. Authorized Points of Diversion and Well Locations

Township	Range	Section	1/4-1/4	Well	Authorized Point of Diversion			
					63-34038	63-33207	63-32680	63-33296
1N	1E	11	SWSE		X	X	X	
1N	1E	11	SESE		X	X	X	
1N	1E	12	SWNW		X	X		X
1N	1E	12	SESW		X	X		X
1N	1E	13	NWNE		X	X		X
1N	1E	13	NWNW	Irrigation Well 2	X	X		X
1N	1E	13	NESE		X	X		X
1N	1E	14	NENE	Irrigation Well 1	X	X	X	
1N	1E	14	NWNE		X	X	X	
1N	1E	14	SWNE		X	X	X	
1N	1E	14	SENE		X	X	X	
1N	1E	14	NESE	Irrigation Well 3	X	X	X	
1N	1E	14	NWSE		X	X	X	
1N	2E	6	NWSW Lt 6		X	X		
1N	2E	6	NWSW Lt 6		X	X		
1N	2E	6	SWSW Lt 7	Plant Well 1	X	X		
1N	2E	6	SWSW Lt 7	Plant Well 2	X	X		




Figure 1. Project Location Map

2. 2017 ACTIVITIES

2.1. Water Level Monitoring

Water level data from electronic transducers in the irrigation wells and Monitoring Well are required to be collected at a minimum of 3 times per year. The current schedule specifies that these events should occur between November 15 and November 30, between January 15 and January 30, and between March 1 and March 15 of each year. At the time of collection, manual groundwater level measurements are to be taken at each well with a non-stretch electric well sounder, and flow meter readings should also be recorded. Monthly airline water-level measurements and flow-meter readings are also scheduled for each of the three irrigation wells and both of the plant wells.

Monitoring details for each well during the 2017 monitoring period are provided below.

Irrigation Well No. 1. The transducer for Irrigation Well No. 1 was removed on November 29, 2016 and its data was downloaded at that time. However, the transducer was unable to be reinstalled due to the pinched sounding tube. This resulted in the no data being available to estimate the drawdown during the irrigation season. In 2017, manual water level measurements were collected from Irrigation Well No. 1 using an electric well sounder on November 17 and December 29. Manual measurements were not taken with the sounder earlier in the year because the sounding tube was pinched. Airline water level measurements were consistently logged from July to December, but the airline could not be calibrated until October.

Because of the inability to install a transducer in Well No. 1, SPF proposes that the Well No. 1 water-level transducer be installed in the Drilling Supply Well which is located 100 feet southeast of Irrigation Well No. 1.

Irrigation Well No. 2. The pump in Irrigation Well No. 2 was replaced in March 2017. Water levels in Irrigation Well No. 2 were measured using an electric line well sounder on January 30, March 3, October 2, and November 17, 2017. A transducer was reinstalled in the well following pump replacement in March and its data was then downloaded during the November event. The transducer data indicate that water levels fluctuated approximately 25 feet during the irrigation season. Based on the compiled hydrograph, the transducer may have been above the water level at certain times during pumping. Groundwater levels had recovered to within 3 feet of pre-irrigation season levels by November 17. A new airline gage was installed at the well in September and airline measurements were taken monthly from October to December.

Irrigation Well No. 3. Irrigation Well No. 3 was constructed in 2016 and put into service as a supply well during the 2017 irrigation season. The first manual measurement with a well sounder was collected on March 3 and a second was taken on December 29 in 2017. An attempt to measure water level was also made on

November 17, 2017 but there was an excess of oil in the well which prevented accurate measurement. A transducer was installed in the well during the measurement in March and data was collected on November 17. Analysis of the water level data show a difference of at least 18 feet between the static and pumping water levels, but a maximum depth-to-water is not available because the hydrograph suggests the transducer was not submerged for an extended period during the irrigation season. Following cessation of pumping for the year, groundwater levels have recovered to within 3 feet of the pre-pumping depths-to-water. When the transducer was retrieved from the well, its cable was heavily corroded and unsuitable for use, so the transducer was removed. A new stainless-steel wire was rigged to the transducer and it was reinstalled in the well during the December measurement. Airline water level measurements began in July and were taken monthly through December.

Monitoring Well. An electric line well sounder was used to determine water levels in the Monitoring Well in January, March, and November 2017. Transducer data was also collected during these measuring events. Analysis of the logger data shows a 6-foot water level fluctuation over the course of the irrigation season, with recovery to within 2.5 feet of the pre-pumping levels by November 17.

Plant Well No. 1. Plant Well No. 1 was completed in 2015, but had not been used as a water supply until late spring of 2017 when the CS Beef Packers plant opened. A manual water level measurement was collected on August 30, 2017 using a well sounder, but subsequent water level measurements were taken using an airline to minimize potential for contamination of this public drinking water system well. The airline was calibrated on the same date that the manual measurement was taken and water levels have been determined monthly since that time. Airline water levels have consistently held between 310 and 305 feet below the measuring point.

Plant Well No. 2. Plant Well No. 2 was also completed in 2015 and first used in 2017. On July 25, an electric sounder was used to calibrate the airline. The airline has been used to take monthly water level measurements through December 29. According to the airline measurements, there has been little fluctuation in water levels at this well. The maximum depth to water measured was 294 feet on October 2 and the minimum was 292 feet on December 29.

Water-level data through December 29, 2017 are provided electronically on a compact disk in Appendix D and summarized below in Figure 2. Manual water levels include calibrated airline measurements.




Figure 2. Water Level Hydrograph through 12/29/2017

2.2. Flow Monitoring

All three of the irrigation wells are equipped with electromagnetic flow meters. Irrigation pumping occurred between March 15 and October 31 in 2017.

- The flow meter at Irrigation Well No. 1 stopped working sometime in June and was inoperative until a replacement was installed in September or October.
- Irrigation Wells No. 2 and No. 3 have more complete totalizer records and pumped total volumes of 182.3 acre-feet and 758.23 acre-feet of groundwater in 2017, respectively. Readings from Well 2 are suspect, however, because the meter indicated low diversion volumes in June, July, and August. Readings from the flow meter at Well No. 3 are also suspect because the instantaneous readings fluctuate widely and short-term averaged readings far exceed the capacity of the pump and motor.

- Table 2 summarizes the monthly instantaneous and totalized flow readings for the Irrigation Wells.

Table 2. Irrigation Wells Monthly Flow Monitoring

Date	Well 1		Well 2		Well 3		Total		
	Flow (gpm)	Totalizer (af)	Flow (gpm)	Totalizer (af)	Flow (gpm)	Totalizer (af)	Flow (gpm)	Flow (cfs)	(af)
4/23/2015	0	23.21	0	23.21	---	---	0	0.00	46.4
5/29/2015	0	23.21	1094	81.87	---	---	1094	2.44	105.1
6/29/2015	2393	211.38	2008	243.04	---	---	4401	9.81	454.4
7/31/2015	0	446.35	2326.5	373.97	---	---	2327	5.18	820.3
8/27/2015	2368	705.09	764.2	489.42	---	---	3132	6.98	1194.5
10/1/2015	0	752.77	0	529.20	---	---	0	0.00	1282.0
10/30/2015	0	752.77	0	542.96	---	---	0	0.00	1295.7
1/29/2016	0	752.77	0	542.96	---	---	0	0.00	1295.7
3/15/2016	0	752.77	0	542.96	---	---	0	0.00	1295.7
4/30/2016	0	843.96	1411.5	543.71	---	---	1412	3.14	1387.7
6/8/2016	0	876.21	2145.5	569.25	---	---	2146	4.78	1445.5
6/29/2016	2479	980.51	2393.7	614.01	---	---	4873	10.86	1594.5
7/28/2016	2372	1168.8	2676.3	681.90	---	---	5048	11.25	1850.7
9/2/2016	2342	1458.24	1176.4	818.84	---	---	3518	7.84	2277.1
10/3/2016	0	1576.3	0	863.25	---	---	0	0.00	2439.6
10/31/2016	0	1576.3	0	870.61	---	---	0	0.00	2446.9
11/29/2016	0	1576.3	0	870.61	---	---	0	0.00	2446.9
1/30/2017	0	1576.3	0	870.61	---	---	0	0.00	2446.9
3/15/2017	0	1576.3	0	870.61	---	---	0	0.00	2446.9
4/27/2017	0	1606.02	0	888.09	---	---	0	0.00	2494.1
5/31/2017	2278	1867.29	314.8	983.07	---	---	2593	5.78	2909.3
6/30/2017	(1)	(1)	0	1012.21	---	---	0	0.00	0.0
7/25/2017	(2)	(2)	1563.7	1032.15	---	321.8837	5433	12.10	1352.0
8/30/2017	(1)	(1)	2519.3	1046.20	---	613.149	9988	22.25	1658.3
10/2/2017	0	3.083615	0	1052.91	---	757.9713	0	0.00	1814.0
11/17/2017	0	19.03451	0	1052.91	---	758.2286	0	0.00	1830.2
12/29/2017	0	19.03451	0	1052.91	---	758.2286	0	0.00	1830.2

(1) - Flow Meter Inoperative, (2) - Flow Meter Missing

Due to problems with the flow meters on the three wells, an estimate of pumping volume was prepared using power data. Records obtained from Idaho Power for each of the irrigation wells provide monthly power usage at each well site in kilowatt-hours (kWh). A standardized table was used to convert the power consumption to pumped volume based on pump system efficiency and total pump lift. Assumed pump efficiencies of approximately 72% and motor efficiencies around 92% give a wire-to-water efficiency of 66%, and the total pump lift for each well was determined using

pumping water levels and discharge pressures. These values were used to estimate total volume pumped at each well as a function of kWh totals. Power data and estimated diversion volumes are summarized in Table 3. These estimates are believed to be more accurate than 2017 flow meter records.

Table 3. Irrigation Well Volume Estimates Based on Power Consumption

MONTH	IRRIGATION WELL NO. 1		IRRIGATION WELL NO. 2		IRRIGATION WELL NO. 3		TOTAL	
	POWER USAGE (KWH)	ACRE-FEET	POWER USAGE (KWH)	ACRE-FEET	POWER USAGE (KWH)	ACRE-FEET	POWER USAGE (KWH)	ACRE-FEET
April	7,200.00	10.91	9,440.00	13.51	0.00	0.00	16,640.00	24.42
May	120,880.00	183.14	89,600.00	128.21	12,721.00	16.38	223,201.00	327.74
June	95,280.00	144.36	82,400.00	117.91	39,120.00	50.38	216,800.00	312.65
July	193,760.00	293.56	190,000.00	271.88	198,640.00	255.81	582,400.00	821.25
August	172,000.00	260.60	123,760.00	177.09	125,360.00	161.44	421,120.00	599.13
September	137,440.00	208.23	113,520.00	162.44	126,320.00	162.68	377,280.00	533.35
October	0.00	0.00	160.00	0.23	480.00	0.62	640.00	0.85
November	320.00	0.48	400.00	0.57	560.00	0.72	1,280.00	1.78
December	720.00	1.09	1,120.00	1.60	560.00	0.72	2,400.00	3.41
SUM	727,600.00	1,102.38	610,400.00	873.43	503,761.00	648.76	1,841,761.00	2,624.58

The two plant wells were put into service in 2017 and both are equipped with electromagnetic flow meters. These wells are used year-round to supply water to the CS Beef Packers plant. Assuming the flow meters on both wells were at zero when installed, Plant Well No. 1 provided 713.18 acre-feet to the plant through December 29, and Plant Well No. 2 supplied 175.56 acre-feet through the same date for a combined volume of 888.74 acre-feet. Table 4 provides a summary of the recorded instantaneous and totalized flows from the Plant Wells.

Table 4. Plant Wells Monthly Flow Monitoring

Date	Plant Well #1		Plant Well #2	
	Flow (gpm)	Totalizer (af)	Flow (gpm)	Totalizer (af)
7/25/2017	1247		0	3.87
8/30/2017	1245		0	17.56
10/2/2017	1236		0	54.80
11/17/2017	1237	637.28	0	120.64
12/29/2017	1243	713.18	0	175.56

Plant personnel record monthly water use by the plant. These volumes are listed in Table 5. The total volume is 367 acre-feet less than the totals for the two well flow meters. This discrepancy is assume to be because flow monitoring at the plant did not begin until June.

Table 5. Plant Water Use

Month	Gallons	AF
June	15,034,575	46.1
July	27,629,130	84.8
Aug	26,980,736	82.8
Sept	20,698,975	63.5
Oct	30,682,149	94.2
Nov	28,338,900	87.0
Dec	20,976,843	64.4
Total	170,341,308	522.8

3. SUMMARY

1. Monitoring was conducted in 2017 as required for permits 63-32680, 63-33296, 63-33207, and 63-34038.
2. Irrigation Well No. 1 has a pinched sounding tube; the transducer cannot fit down the tube but water levels can be measured. There is a large amount of oil in the well which makes water-level measurements with a sounder difficult. The transducer which was removed from the well in November 2016 has not been replaced. It is recommended that a transducer instead be installed in the nearby Drilling Supply Well for 2018 monitoring.
3. The Irrigation Well No. 2 sounding tube and water-level transducer were replaced in March 2017. There are currently no issues with monitoring this well.
4. Irrigation Well No. 3 was utilized for the first time during the 2017 irrigation season. A water level datalogger was installed, removed, and reinstalled in the well over the course of the year. There seems to be a thick layer of oil in the well based on attempts to use a sounder.
5. Irrigation diversions in 2017 occurred from Irrigation Wells No. 1, No. 2, and No. 3. Total diversion volumes for the three wells was estimated from power usage records at each well site. The combined total diversion volume was approximately 2,624 acre-feet in 2017 with 1,102 acre-feet from No. 1, 873 acre-feet from No. 2, and 649 acre-feet from No. 3.
6. The 2017 water-level fluctuation in the monitoring well was approximately 6 feet. There was an approximate 1-foot water level increase between November 2016 and November 2017.

7. Plant Wells #1 (East) and #2 (West) were used for the first time in 2017 to supply industrial water for the CS Beef Packers plant. The wells are equipped with airlines for water level measurements and electromagnetic flow meters. Total combined diversion volume was approximately 889 acre-feet in 2017 based on readings from the flow meter totalizers. According to monthly water usage data provided by plant personnel, the total volume diverted from June through December was 522.8 acre-feet.

Appendix A
Water Right Reports

Close

IDAHO DEPARTMENT OF WATER RESOURCES
Water Permit Report

2/5/2017

WATER RIGHT NO. 63-32680

<u>Owner Type</u>	<u>Name and Address</u>
Current Owner	CS PROPERTY DEVELOPMENT LLC PO BOX 27 BOISE, ID 83707 (208)336-2110
Original Owner	BOISE INVESTMENT GROUP LLC C/O NICK FERGIS 12515 COUNTY RD 22 CORTEZ, CO 81321 (602)980-8182
Original Owner	AZEL DEVELOPMENT GROUP LLC
Original Owner	KUNA COLE 880
Original Owner	NOELLE HOLDINGS LLC C/O NICK FERGIS BOISE INVESTMENT GROUP LLC 12515 COUNTY RD 22 CORTEZ, CO 81321 (602)980-8182
Security Interest	WELLS FARGO BANK FOOD & AGRIBUSINESS COMMERCIAL BANKING OFFICE 905 S FILLMORE STE 701 MAC T3005-072 AMARILLO, TX 79101 806-371-3769

Priority Date: 05/22/2007

Status: Active

<u>Source</u>	<u>Tributary</u>
GROUND WATER	

<u>Beneficial Use</u>	<u>From</u>	<u>To</u>	<u>Diversion Rate</u>	<u>Volume</u>
IRRIGATION	03/01	11/15	5.22 CFS	
Total Diversion			5.22 CFS	

Location of Point(s) of Diversion:

GROUND WATER	SWSE	Sec. 11	Township 01N	Range 01E	ADA County
GROUND WATER	SESE	Sec. 11	Township 01N	Range 01E	ADA County
GROUND WATER	NENE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWNE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	SWNE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	SENE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NESE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWSE	Sec. 14	Township 01N	Range 01E	ADA County

Place(s) of use:

Place of Use Legal Description: IRRIGATION ADA County

<u>Township</u>	<u>Range</u>	<u>Section</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>
01N	01E	11		SWSE	40		SESE	40						
		12		NENW	40		NWNW	40		SWNW	40		SENE	40
				NESW	40		NWSW	40		SWSW	40		SESW	40
				NWSE	40		SWSE	40		SESE	40			
		13		NENE	40		NWNE	40		SWNE	40		SENE	40
				NENW	40		NWNW	40						
				NESE	40									
		14		NENE	40		NWNE	40		SWNE	40		SENE	40
				SWNW	40		SENE	40						
				NESW	40		NWSW	40		SWSW	40		SESW	40
				NESE	40		NWSE	40		SWSE	40		SESE	40
		23		NENE	40		NWNE	40						
				NENW	40		NWNW	40						
		24		NENW	40		NWNW	40		SWNW	40		SENE	40

Total Acres: 1680

Conditions of Approval:

1. Rights 63-32680 and 63-33296, when combined, shall not exceed a total diversion rate of 11.76 cfs, a total annual maximum diversion volume of 3,528 af at the field headgate, and the irrigation of 784 acres.
2. This right is limited to the irrigation of 261 acres within the place of use described above in a single irrigation season.
3. Diversion and use of water in connection with this right is subject to a Monitoring Plan approved by the Department. In the event of a failure to comply with any component of the Monitoring Plan, after actual notice and a reasonable opportunity to cure, the right holder shall cease further diversions under the right until such noncompliance is remedied. Failure to comply with any approval condition, including the Monitoring Plan, shall be cause for the Department to cancel or revoke this right, or for an administrative or judicial action enjoining use of the right after actual notice and a reasonable opportunity to cure.
4. Proof of application of water to beneficial use shall be submitted no sooner than July 1, 2017 and no later than July 1, 2018.
5. No less than four (4) years of ground water monitoring data shall be submitted in connection with filing proof of beneficial use for this right. The right holder shall also submit a report from a qualified professional engineer, hydrologist, or hydrogeologist summarizing hydrogeologic data collected to fulfill the approved Monitoring Plan and the conditions of approval of this right. Submittal of a proof of beneficial use statement without the required report will not be accepted by the Department and may result in lapsing or cancellation of the permit.
6. Prior to submitting proof of beneficial use, the right holder shall not assign ownership of the permit to another individual, corporation, partnership, or association without prior notification to the Department.
7. 26A Project construction shall commence within one year from the date of permit issuance and shall proceed diligently to completion unless it can be shown to the satisfaction of the Director of the Department of Water Resources that delays were due to circumstances over which the permit holder had no control.
8. Diversion and use of water with a temperature greater than 85 degrees Fahrenheit is not authorized under his right.
9. 046 Right holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code and applicable Well Construction Rules of the Department.
10. 121 The Director retains jurisdiction to require the right holder to provide purchased or leased natural flow or stored water to offset depletion of Lower Snake River flows if needed for salmon migration purposes. The amount of water required to be released into the Snake River or a tributary, if needed for this purpose, will be determined by the Director based upon the reduction in flow caused by the use of water pursuant to this permit.
11. 004 This right does not grant any right-of-way or easement across the land of another.
12. R65 This right when combined with all other rights shall provide no more than 0.02 cfs per acre nor more than 4.5 afa per acre at the field headgate for irrigation of the place of use.
13. This right authorizes the construction of 2 supply wells as points of diversion.
14. The Department shall be notified prior to the installation and calibration of flow meters on all supply wells.

Dates:

Proof Due Date: 07/01/2018

Proof Made Date:

Approved Date: 07/17/2013

Moratorium Expiration Date:

Enlargement Use Priority Date:

Enlargement Statute Priority Date:

Application Received Date: 09/07/2016

Protest Deadline Date: 01/02/2017

Number of Protests: 0

Field Exam Date::

Date Sent to State Off:

Date Received at State Off:

Other Information:

State or Federal:

Owner Name Connector:

Water District Number:

Generic Max Rate per Acre: 0.02

Generic Max Volume per Acre: 4.5

Swan Falls Trust or Nontrust:

Swan Falls Dismissed:

DLE Act Number:

Cary Act Number:

Mitigation Plan: False

Close

Close

IDAHO DEPARTMENT OF WATER RESOURCES
Water Application Report

2/5/2017

WATER RIGHT NO. 63-33207

<u>Owner Type</u>	<u>Name and Address</u>
Current Owner	CS PROPERTY DEVELOPMENT LLC PO BOX 27 BOISE, ID 83707 (208)336-2110
Original Owner	JIM HUTCHINGS 13690 S CLOVERDALE RD KUNA, ID 83634 (208)362-2963
Security Interest	WELLS FARGO BANK FOOD & AGRIBUSINESS COMMERCIAL BANKING OFFICE 905 S FILLMORE STE 701 MAC T3005-072 AMARILLO, TX 79101 806-371-3769

Priority Date: 03/24/2010

Status: Active

<u>Source</u>	<u>Tributary</u>
GROUND WATER	

<u>Beneficial Use</u>	<u>From</u>	<u>To</u>	<u>Diversion Rate</u>	<u>Volume</u>
INDUSTRIAL	01/01	12/31	3 CFS	
Total Diversion			3 CFS	

Location of Point(s) of Diversion:

GROUND WATER	SWSE	Sec. 11	Township 01N	Range 01E	ADA County
GROUND WATER	SESE	Sec. 11	Township 01N	Range 01E	ADA County
GROUND WATER	SWNW	Sec. 12	Township 01N	Range 01E	ADA County
GROUND WATER	SENE	Sec. 12	Township 01N	Range 01E	ADA County
GROUND WATER	NWNE	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NWNW	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NESE	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NENE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWNE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	SWNE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	SENE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NESE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWSE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWSW Lt 6	Sec. 06	Township 01N	Range 02E	ADA County
GROUND WATER	NWSW Lt 6	Sec. 06	Township 01N	Range 02E	ADA County
GROUND WATER	SWSW Lt 7	Sec. 06	Township 01N	Range 02E	ADA County
GROUND WATER	SWSW Lt 7	Sec. 06	Township 01N	Range 02E	ADA County

Place(s) of use:

Place of Use Legal Description: INDUSTRIAL ADA County

<u>Township</u>	<u>Range</u>	<u>Section</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>
01N	01E	11		SWSE			SESE							
		12		NENW			NWNW			SWNW			SENE	
				NESW			NWSW			SWSW			SESW	
				NWSE			SWSE			SESE				
		13		NENE			NWNE			SWNE			SENE	
				NENW			NWNW							
				NESE										
		14		NENE			NWNE			SWNE			SENE	
				NESE			NWSE							
		23		NENE			NWNE							
				NENW			NWNW							
		24		NENW			NWNW			SWNW			SENE	
	02E	6		NESW		6	NWSW		7	SWSW			SESW	
				NWSE			SWSE							

Conditions of Approval:

1. 004 This right does not grant any right-of-way or easement across the land of another.
The right holder shall install a measuring device acceptable to the Department at the points of diversion authorized under this right. The measuring device shall be capable of displaying diversion flow rate and totalized volume measurement. The right holder shall record the flow rate and volume measurements monthly for any calendar year in which water is diverted and used in connection with this right until notified by the Department. The records shall be made available to the Department upon request.
- 2.
3. 073 Diversion and use of water with a temperature greater than 85 degrees Fahrenheit is not authorized under this right.
4. Use of water under this permit shall not exceed an annual diversion volume of 700 acre-feet. If the Department determines, based on credible evidence, measurement reports, area data, or otherwise, there is a substantial likelihood that diversion and use of groundwater under this right is causing material injury to any senior water right(s), the Department may issue an order to the right holder to show cause why existing diversions should not be reduced under the permit, forego additional diversions, or provide adequate mitigation to remedy any such material injury. Any senior water user alleging material injury may petition the Department to commence a show cause hearing, and the Department shall conduct a hearing.
- 5.
6. 121 The Director retains jurisdiction to require the right holder to provide purchased or leased natural flow or stored water to offset depletion of Lower Snake River flows if needed for salmon migration purposes. The amount of water required to be released into the Snake River or a tributary, if needed for this purpose, will be determined by the Director based upon the reduction in flow caused by the use of water pursuant to this permit.
7. Industrial use is for a meat processing and packing facility.
8. One point of diversion (well) authorized for this right shall include a measuring device or other suitable method to allow measurement of the static water level in the well. Water level measurements shall be made monthly throughout the year from the beginning of the diversion and use of water in connection with this right until notified by the Department. The records shall be made available to the Department upon request.
9. 196 The right holder shall install or construct a straight length of conduit or ditch suitable for installation of a device for measuring the entire flow of water being diverted in connection with this right. If the right holder uses conduit, the straight length of conduit shall be at least fifteen times the diameter of the conduit and shall be above ground or otherwise easily accessible.
10. 046 Right holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code and applicable Well Construction Rules of the Department.
11. 069 Failure of the right holder to comply with any condition of approval is cause for the Director to cancel this permit.
12. 26A Project construction shall commence within one year from the date of permit issuance and shall proceed diligently to completion unless it can be shown to the satisfaction of the Director of the Department of Water Resources that delays were due to circumstances over which the permit holder had no control.
13. Proof of application of water to beneficial use shall be submitted no sooner than October 1, 2017, and no later than October 1, 2018. A report with no less than 4 years of diversion measurement and aquifer level water monitoring data shall be submitted in connection with filing proof of beneficial use. Submittal of a proof of beneficial use statement without the required report will not be accepted by the Department and may result in cancellation of the permit.

Dates:

Date Application Received: 09/07/2016

Date Application Denied:

Last Date of Beneficial Use:

Extension End Date:

Protest Deadline Date: 1/2/2017

Number of Protests: 0

Enlargement Use Priority Date:

Enlargement Statute Priority Date:

Other Information:

State or Federal:

Owner Name Connector:

Water District Number:

Generic Max Rate per Acre:

Generic Max Volume per Acre:

Application Type: Amendment

Applicant Remarks: The proposed change is to increase the size of the place of industrial use.

Other Water Rights:

Time to Complete Works:

Transfer Affected Description:

Transfer Affected Contracts:

Old Transfer Number:

Transfer Reason:

Transfer Return Flows:

Swan Falls Trust or Nontrust:

Swan Falls Dismissed:

DLE Act Number:

Cary Act Number:

Mitigation Plan: False

Close

Close

IDAHO DEPARTMENT OF WATER RESOURCES
Water Permit Report

2/5/2017

WATER RIGHT NO. 63-33296

<u>Owner Type</u>	<u>Name and Address</u>
Current Owner	CS PROPERTY DEVELOPMENT LLC PO BOX 27 BOISE, ID 83707 (208)336-2110
Original Owner	BOISE INVESTMENT GROUP LLC C/O NICK FERGIS 12515 COUNTY RD 22 CORTEZ, CO 81321 (602)980-8182
Original Owner	KUNA COLE 880 LLC C/O NICK FERGIS BOISE INVESTMENT GROUP 12515 COUNTY RD 22 CORTEZ, CO 81321 (208)383-4140
Original Owner	AZEL DEVELOPMENT GROUP LLC
Original Owner	NOELLE HOLDINGS LLC C/O NICK FERGIS BOISE INVESTMENT GROUP LLC 12515 COUNTY RD 22 CORTEZ, CO 81321 (602)980-8182
Security Interest	WELLS FARGO BANK FOOD & AGRIBUSINESS COMMERCIAL BANKING OFFICE 905 S FILLMORE STE 701 MAC T3005-072 AMARILLO, TX 79101 806-371-3769

Priority Date: 11/06/2009

Status: Active

Source | Tributary
 GROUND WATER |

<u>Beneficial Use</u>	<u>From</u>	<u>To</u>	<u>Diversion Rate</u>	<u>Volume</u>
IRRIGATION	03/01	11/15	10.46 CFS	
Total Diversion			10.46 CFS	

Location of Point(s) of Diversion:

GROUND WATER	SWNW	Sec. 12	Township 01N	Range 01E	ADA County
GROUND WATER	SENE	Sec. 12	Township 01N	Range 01E	ADA County
GROUND WATER	NWNE	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NWNW	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NESE	Sec. 13	Township 01N	Range 01E	ADA County

Place(s) of use:

Place of Use Legal Description: IRRIGATION ADA County

<u>Township</u>	<u>Range</u>	<u>Section</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>
01N	01E	11		SWSE	40		SESE	40						
		12		NENW	40		NWNW	40		SWNW	40		SENE	40
				NESW	40		NWSW	40		SWSW	40		SESW	40
				NWSE	40		SWSE	40		SESE	40			
		13		NENE	40		NWNE	40		SWNE	40		SENE	40
				NENW	40		NWNW	40						
				NESE	40									
		14		NENE	40		NWNE	40		SWNE	40		SENE	40
				SWNW	40		SENE	40						
				NESW	40		NWSW	40		SWSW	40		SESW	40
				NESE	40		NWSE	40		SWSE	40		SESE	40
		23		NENE	40		NWNE	40						
				NENW	40		NWNW	40						
		24		NENW	40		NWNW	40		SWNW	40		SENE	40

Total Acres: 1680

Conditions of Approval:

1. Rights 63-32680 and 63-33296, when combined, shall not exceed a total diversion rate of 11.76 cfs, a total annual maximum diversion volume of 3,528 af at the field headgate, and the irrigation of 784 acres.
2. This right is limited to the irrigation of 523 acres within the place of use described above in a single irrigation season.
Diversion and use of water in connection with this right is subject to a Monitoring Plan approved by the Department. In the event of a failure to comply with any component of the Monitoring Plan, after actual notice and a reasonable opportunity to cure, the right holder shall cease further diversions under the right until such noncompliance is remedied. Failure to comply with any approval condition, including the Monitoring Plan, shall be cause for the Department to cancel or revoke this right, or for an administrative or judicial action enjoining use of the right after actual notice and a reasonable opportunity to cure.
3. Proof of application of water to beneficial use shall be submitted no sooner than July 1, 2017 and no later than July 1, 2018.
4. No less than four (4) years of ground water monitoring data shall be submitted in connection with filing proof of beneficial use for this right. The right holder shall also submit a report from a qualified professional engineer, hydrologist, or hydrogeologist summarizing hydrogeologic data collected to fulfill the approved Monitoring Plan and the conditions of approval of this right. Submittal of a proof of beneficial use statement without the required report will not be accepted by the Department and may result in lapsing or cancellation of the permit.
5. Prior to submitting proof of beneficial use, the right holder shall not assign ownership of the permit to another individual, corporation, partnership, or association without prior notification to the Department.
6. Project construction shall commence within one year from the date of permit issuance and shall proceed diligently to completion unless it can be shown to the satisfaction of the Director of the Department of Water Resources that delays were due to circumstances over which the permit holder had no control.
7. 26A Diversion and use of water with a temperature greater than 85 degrees Fahrenheit is not authorized under his right.
8. Right holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code and applicable Well Construction Rules of the Department.
9. 046 The Director retains jurisdiction to require the right holder to provide purchased or leased natural flow or stored water to offset depletion of Lower Snake River flows if needed for salmon migration purposes. The amount of water required to be released into the Snake River or a tributary, if needed for this purpose, will be determined by the Director based upon the reduction in flow caused by the use of water pursuant to this permit.
10. 121 This right does not grant any right-of-way or easement across the land of another.
11. 004 This right when combined with all other rights shall provide no more than 0.02 cfs per acre nor more than 4.5 afa per acre at the field headgate for irrigation of the place of use.
12. R65 This right authorizes the construction of 2 supply wells as points of diversion.
13. The Department shall be notified prior to the installation and calibration of flow meters on all supply wells.
- 14.

Dates:

Proof Due Date: 07/01/2018

Proof Made Date:

Approved Date: 07/17/2013

Moratorium Expiration Date:

Enlargement Use Priority Date:

Enlargement Statute Priority Date:

Application Received Date: 09/07/2016

Protest Deadline Date: 01/02/2017

Number of Protests: 0

Field Exam Date::

Date Sent to State Off:

Date Received at State Off:

Other Information:

State or Federal:

Owner Name Connector:

Water District Number:

Generic Max Rate per Acre: 0.02

Generic Max Volume per Acre: 4.5

Swan Falls Trust or Nontrust:

Swan Falls Dismissed:

DLE Act Number:

Cary Act Number:

Mitigation Plan: False

Close

Close

IDAHO DEPARTMENT OF WATER RESOURCES
Water Permit Report

2/5/2017

WATER RIGHT NO. 63-34038

<u>Owner Type</u>	<u>Name and Address</u>
Current Owner	CS PROPERTY DEVELOPMENT LLC PO BOX 27 BOISE, ID 83707 (208)336-2110
Original Owner	J R SIMPLOT COMPANY PO BOX 27 BOISE, ID 83707 (208)336-2110
Security Interest	WELLS FARGO BANK FOOD & AGRIBUSINESS COMMERCIAL BANKING OFFICE 905 S FILLMORE STE 701 MAC T3005-072 AMARILLO, TX 79101 806-371-3769

Priority Date: 06/26/2015

Status: Active

<u>Source</u>	<u>Tributary</u>
GROUND WATER	

<u>Beneficial Use</u>	<u>From</u>	<u>To</u>	<u>Diversion Rate</u>	<u>Volume</u>
IRRIGATION	03/01	11/15	3.2 CFS	
INDUSTRIAL	01/01	12/31	4 CFS	
Total Diversion			4 CFS	

Location of Point(s) of Diversion:

GROUND WATER	SWSE	Sec. 11	Township 01N	Range 01E	ADA County
GROUND WATER	SESE	Sec. 11	Township 01N	Range 01E	ADA County
GROUND WATER	SWNW	Sec. 12	Township 01N	Range 01E	ADA County
GROUND WATER	SENE	Sec. 12	Township 01N	Range 01E	ADA County
GROUND WATER	NWNE	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NWNW	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NESE	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NENE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWNE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	SWNE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	SENE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NESE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWSE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWSW Lt 6	Sec. 06	Township 01N	Range 02E	ADA County
GROUND WATER	NWSW Lt 6	Sec. 06	Township 01N	Range 02E	ADA County
GROUND WATER	SWSW Lt 7	Sec. 06	Township 01N	Range 02E	ADA County
GROUND WATER	SWSW Lt 7	Sec. 06	Township 01N	Range 02E	ADA County

INDUSTRIAL Use:

Number of other uses: meat process & packing

Place(s) of use:

Place of Use Legal Description: IRRIGATION ADA County

Township	Range	Section	Lot	Tract	Acres	Lot	Tract	Acres	Lot	Tract	Acres	Lot	Tract	Acres
01N	01E	11		SWSE	40		SESE	40						
		12		NENW	40		NWNW	40		SWNW	40		SENE	40
				NESW	40		NWSW	40		SWSW	40		SESW	40
				NWSE	40		SWSE	40		SESE	40			
		13		NENE	40		NWNE	40		SWNE	40		SENE	40
				NENW	40		NWNW	40						
				NESE	40									
		14		NENE	40		NWNE	40		SWNE	40		SENE	40
				SWNW	40		SENE	40						
				NESW	40		NWSW	40		SWSW	40		SESW	40
				NESE	40		NWSE	40		SWSE	40		SESE	40
		23		NENE	40		NWNE	40						
				NENW	40		NWNW	40						
		24		NENW	40		NWNW	40		SWNW	40		SENE	40

Place of Use Legal Description: INDUSTRIAL ADA County

Township	Range	Section	Lot	Tract	Acres	Lot	Tract	Acres	Lot	Tract	Acres	Lot	Tract	Acres	
01N	01E	11		SWSE			SESE								
				NENW		NWNW			SWNW		SENE		SESW		
				NESW		NWSW			SWSW		SESE				
			13		NWSE			SWSE			SWNE			SENE	
				NENE		NWNE			SWNW		SWSW		SENE		
				NENW		NWNW			SWSW		SESE		SENE		
			14		NESW			SWSE			SWNE			SENE	
				NENE		NWNE									
				NESE		NWSE									
			23		NENE			NWNE							
				NENW		NWNW									
				NENW		NWNW									
		24		NENW			NWNW			SWNW			SENE		
			NENW		NWNW										
	NENW			NWNW											
	02E	6		NESW			SESW								
	NWSE			SWSE											

Total Acres: 1680

Conditions of Approval:

1. 26A Project construction shall commence within one year from the date of permit issuance and shall proceed diligently to completion unless it can be shown to the satisfaction of the Director of the Department of Water Resources that delays were due to circumstances over which the permit holder had no control.
2. Each point of diversion (well) authorized for this right shall include a measuring device or other suitable method to allow measurement of the static water level in the well. Water level measurements shall be made monthly throughout the year from the beginning of the diversion and use of water in connection with this right until notified by the Department. The records shall be made available to the Department upon request.
3. 196 The right holder shall install or construct a straight length of conduit or ditch suitable for installation of a device for measuring the entire flow of water being diverted in connection with this right. If the right holder uses conduit, the straight length of conduit shall be at least fifteen times the diameter of the conduit and shall be above ground or otherwise easily accessible.
4. The right holder shall install a measuring device acceptable to the Department at each point of diversion authorized under this right. The measuring device shall be capable of displaying diversion flow rate and totalized volume measurement. The right holder shall record the flow rate and volume measurements monthly for any calendar year in which water is diverted and used in connection with this right until notified by the Department. The records shall be made available to the Department upon request.

5. 073 Diversion and use of water with a temperature greater than 85 degrees Fahrenheit is not authorized under this right.
6. If the Department determines based on credible evidence, measurement reports, area data or otherwise that diversion and use of ground water under this right is causing material injury to any senior water right(s), the Department may order the diversion reduced, the diversion curtailed, or the right holder to provide adequate mitigation to remedy the injury.
7. Prior to submitting proof of beneficial use, the right holder shall not assign ownership of the permit to another individual, corporation, partnership, or association without prior approval of the Department.
8. Proof of beneficial use may not be submitted until one month prior to the deadline to submit proof of beneficial use set forth in these conditions; provided, however, if less than four (4) years of ground water monitoring data have been collected while beneficial use authorized under this permit has occurred, then an extension of time for up to five additional years shall be requested by the permit holder. The permit holder shall submit a report from a qualified professional engineer, hydrologist, or hydrogeologist summarizing hydrogeologic data collected to fulfill the conditions of approval of this permit. Submittal of a proof of beneficial use statement without the required data and report will not be accepted by the Department and may result in lapse of the permit.
9. 046 Right holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code and applicable Well Construction Rules of the Department.
10. R65 This right when combined with all other rights shall provide no more than 0.02 cfs per acre nor more than 4.5 afa per acre at the field headgate for irrigation of the place of use.
11. 121 The Director retains jurisdiction to require the right holder to provide purchased or leased natural flow or stored water to offset depletion of Lower Snake River flows if needed for salmon migration purposes. The amount of water required to be released into the Snake River or a tributary, if needed for this purpose, will be determined by the Director based upon the reduction in flow caused by the use of water pursuant to this permit.
12. 069 Failure of the right holder to comply with any condition of approval is cause for the Director to cancel this permit.

Dates:

Proof Due Date: 11/01/2020

Proof Made Date:

Approved Date: 10/26/2015

Moratorium Expiration Date:

Enlargement Use Priority Date:

Enlargement Statute Priority Date:

Application Received Date: 09/07/2016

Protest Deadline Date: 01/02/2017

Number of Protests: 0

Field Exam Date::

Date Sent to State Off:

Date Received at State Off:

Other Information:

State or Federal:

Owner Name Connector:
Water District Number:
Generic Max Rate per Acre: 0.02
Generic Max Volume per Acre: 4.5
Swan Falls Trust or Nontrust:
Swan Falls Dismissed:
DLE Act Number:
Cary Act Number:
Mitigation Plan: False

Appendix B
Well Driller's Reports for Production and
Monitoring Wells

Plant Well 1

RECEIVED

Form 238-7
6/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

OCT 06 2015

WATER RESOURCES
WESTERN REGION

03

1. WELL TAG NO. D 0069003

Drilling Permit No. 948768-874825

Water right or injection well # _____

2. OWNER: JR Simplot Co.

Name _____

Address P.O. Box 27

City Boise State Idaho Zip 83707

3. WELL LOCATION:

Twp. 1 North or South Rge. 2 East or West

Sec. 6 NW 1/4 SW 1/4

Gov't Lot _____ County ADA

Lat. 43 26.841 (Deg and Decimal minutes)

Long. 116 16.380 (Deg and Decimal minutes)

Address of Well Site S. Cole Rd. 1/4 mile North of Barker

City Kuna

Lot _____ Blk. _____ Sub. Name _____

(Give at least name of road - Distance to Well or Landmark)

4. USE:

Domestic Municipal Monitor Irrigation Thermal Injection

Other _____

5. TYPE OF WORK:

New well Replacement well Modify existing well

Abandonment Other _____

6. DRILL METHOD:

Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
Neat cement	188ft	0	9 yd3	pumped
Neat cement	315ft	0	11 yd3	pumped

Neat cement 315ft 0 11 yd3 pumped

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
20"	0	188	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
14"	+2	395	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

20" 0 188 .375 steel

14" +2 395 .375 steel

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:

Perforations Y N Method _____

Manufactured screen Y N Type Joston

Method of installation set in

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
395	455	30	60ft	14"	ss	.375

395 455 30 60ft 14" ss .375

Length of Headpipe _____ Length of Tailpipe _____

Packer Y N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method
6-9	315	455	9850lbs	trimmie

6-9 315 455 9850lbs trimmie

11. FLOWING ARTESIAN:

Flowing Artesian? Y N Artesian Pressure (PSIG) _____

Describe control device plat

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 315 Static water level (ft) 294

Water temp (°F) 83 Bottom hole temp. (°F) 83

Describe access port _____

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Test method:			
			Pump	Basin	Air	Flowing artesian
43.1	1520	7.7 hrs	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (ft)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
24	0	2	top soil		
24	2	8	sandy dirt and gravel		
24	8	30	hard black lava		
24	30	38	broken soft black lava		
24	38	44	hard black lava		
24	44	48	soft red lava		
24	48	55	hard black lava		
24	55	77	soft black lava		
24	77	95	hard black lava		
24	95	105	soft black lava		
24	105	135	hard black lava		
24	135	145	soft black lava		
24	145	155	red cinders		
24	155	162	hard black lava		
24	162	177	hard black lava		
19	177	312	large gravel and sand		
19	312	315	rock and clay		
19	315	320	sand and gravel		
19	320	325	rock and clay		
19	325	402	sand and gravel		
19	402	425	white clay		
19	425	448	sand and gravel		
19	448	460	brown clay with gravel		
19	460	465	sand and gravel		
19	465	471	brown clay and little rock		
19	471	477	sand and gravel		
19	477	490	brown clay and rock		
19	490	523	big gravel and sand		
19	523	531	sand and gravel		
19	531	543	gravel and sand with clay		
19	543	555	sandstone		
19	555	560	gravel and sand		

Completed Depth (Measurable): 455

Date Started: 6/1/2015 Date Completed: 9/16/2015

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling Co No 560

*Principal Driller: [Signature] Date 9-22-15

*Driller _____ Date _____

*Operator II _____ Date _____

Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0069003

Drilling Permit No. _____

Water right or injection well # _____

2. OWNER: J R Simplot Co.

Name _____

Address P.O. Box 27

City Boise State ID Zip 83707

3. WELL LOCATION:

Twp. 1 North or South Rge. 2 East or West

Sec. 6 NW 1/4 SW 1/4 SE 1/4

Gov't Lot _____ County Ada

Lat. _____ (Deg. and Decimal minutes)

Long. _____ (Deg. and Decimal minutes)

Address of Well Site S Cole Rd 1/4 mile north of Center

City Kuna

Lot _____ Blk. _____ Sub. Name _____

4. USE:

Domestic Municipal Monitor Irrigation Thermal Injection
 Other

5. TYPE OF WORK:

New well Replacement well Modify existing well
 Abandonment Other

6. DRILL METHOD:

Air Rotary Mud Rotary Cable Other

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft)	Placement method/procedure
Neat cement	188	0	13 Yards	Pumped
Neat cement	315	0	10 1/2 Yards	Pumped

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing Liner	Threaded	Welded
20"	0	188	.375	Steel Case	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
14"	188	395	.375	Steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:

Perforations Y N Method _____

Manufactured screen Y N Type Alloy Screen

Method of installation Set in

From (ft)	To (ft)	Slot size	Number	Diameter (nominal)	Material	Gauge or Schedule
395	455		60		Stainless	.375

Length of Headpipe _____ Length of Tailpipe _____

Packer Y N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft)	Placement method
6-9	315	455	9850 lbs	Tremie

11. FLOWING ARTESIAN:

Flowing Artesian? Y N Artesian Pressure (PSIG) _____

Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 315 Static water level (ft) 294

Water temp. (°F) 83 Bottom hole temp. (°F) 83

Describe access port _____

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Ball	Air	Flowing artesian
33	200	60	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Test method:

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
24"	0	2	TOP SOIL		
"	2	8	Sandy dirt / Gravel		
14"	8	30	Hard black lava		
	30	38	Broken / soft black lava		
	38	44	Hard black lava		
	44	48	soft + red lava		
	48	55	Hard black lava		
	55	77	Soft + black lava		
	77	95	Hard black lava		
	95	105	soft black lava		
	105	135	Hard black lava		
	135	145	Soft + black lava		
	145	155	red cinders		
	155	160	Hard black lava		
	160	177	Hard black lava		
19"	177	312	Big Gravels + Sand		
"	312	315	Rock + Clay		
↓	315	320	Sand + Gravel		
	320	325	rock + clay		
	325	402	Sand + Gravel		
	402	425	white clay		
	425	448	Sand + Gravel		
	448	460	brn clay with gravel		
	460	465	Sand + Gravel		
	465	471	Brn clay + little rock		
	471	477	Sand + Gravel		
	477	490	Brn clay + rock		
	490	523	Big Gravels + Sand		
	523	531	Sand + Gravel		
	531	543	Gravels and little clay		
	543	555	sandstone		
	555	560	Gravel + Sand		

Completed Depth (Measurable): 455

Date Started: 7-1-15 Date Completed: 8-30-15

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling and Pumping #560

*Principal Driller Shawn Mikelsen Date 9-28-15

*Driller Shawn Mikelsen Date 9-28-15

*Operator II _____ Date _____

Operator I _____ Date _____

*Signature of Principal Driller and no operator are required

RECEIVED

OCT 02 2015

WATER RESOURCES
WESTERN REGION

Plant Well 2

Form 238-7
8/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0070211
 Drilling Permit No. 970455-876512
 Water right or injection well # 63-33207
 2. OWNER: JR Simplot Company

Name _____
 Address PO Box 27
 City Boise State Idaho Zip 83707

3. WELL LOCATION:
 Twp 1 North or South Rge. 2 East or West
 Sec. 6 1/4 SW 1/4 SW 1/4

Gov't Lot 7 County _____
 Lat. 43 28.845 (Deg. and Decimal minutes)
 Long -116 16.419 (Deg. and Decimal minutes)

Address of Well Site 150' East of south cole rd
1075' North of Barker Rd City Near Kuna
(Give at least three of road + markers to West or Southwest)
 Lot. _____ Blk. _____ Sub. Name _____

4. USE:
 Domestic Municipal Monitor Irrigation Thermal Injection
 Other Industrial

5. TYPE OF WORK:
 New well Replacement well Modify existing well
 Abandonment Other _____

6. DRILL METHOD:
 Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
Neat cement	188	0	9yd3	pumped
Neat cement	315	0	11yd3	pumped

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
26	0	11	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
20	+1	176	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
14	+1	395	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:
 Perforations Y N Method _____
 Manufactured screen Y N Type _____
 Method of installation _____

From (ft)	To (ft)	Slot size	Numberft	Diameter (nominal)	Material	Gauge or Schedule
395	455	40	60	14	SS	.375

Length of Headpipe _____ Length of Tailpipe _____
 Packer Y N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lb or ft ³)	Placement method
silica sand	320	455	8400lbs	trimmie

11. FLOWING ARTESIAN:
 Flowing Artesian? Y N Artesian Pressure (PSIG) _____
 Describe control device plat

12. STATIC WATER LEVEL and WELL TESTS:
 Depth first water encountered (ft) 290 Static water level (ft) 289
 Water temp. (°F) 82 Bottom hole temp (°F) 82
 Describe access port _____

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
338	2190	4hrs	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
32	0	1	top soil		X
32	1	11	bleachy basalt		
26	11	93	weathered basalt		
26	93	97	red cinders		
26	97	124	black basalt		
26	124	128	red cinders		
26	128	176	hard black basalt		
20	176	186	sand and gravel		
20	186	211	gravel and basalt boulders		
20	211	255	sand and gravel boulders		
20	255	266	cemented gravel		
20	266	290	sand and gravel		X
20	290	367	clay		
20	367	376	sand		
20	376	460	pea gravel and silty sand		

Completed Depth (Measurable) 455
 Date Started 9/10/2015 Date Completed 9/30/2015

14. DRILLER'S CERTIFICATION:
 I/We certify that all minimum well construction standards were complied with at the time the rig was removed

Company Name Treasure Valley Drilling Co No 560
 *Principal Driller: [Signature] Date 9-30-15
 *Driller _____ Date _____
 *Operator II _____ Date _____
 Operator I _____ Date _____
 * Signature of Principal Driller and rig operator are required.

Drill Water Supply Well (Monitoring)

Form 238-7
6/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0066263

Drilling Permit No. _____
Water right or injection well # _____

2. OWNER

Name Ray Montierth
Address 825 Hartland Dr
City Nampa State ID Zip 83686

3. WELL LOCATION:

Twp. 1 North or South Rge. 1 East or West
Sec. 14 1/4 SE 1/4 NE 1/4
10 acres 40 acres 160 acres

Gov't Lot _____ County ADA
Lat. 34 ° 25.612 (Deg. and Decimal minutes)
Long. 116 ° 17.845 (Deg. and Decimal minutes)

Address of Well Site Cross tracks on Cole heading south first right
1 mile left 1/2 mile left 1/4 mile City Kuna

Lot _____ Blk. _____ Sub. Name _____

4. USE:

Domestic Municipal Monitor Irrigation Thermal Injection
 Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

New Well Replacement well Modify existing well
 Abandonment Other _____

6. DRILL METHOD:

Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
Bentonite	0	38	950lbs	Pour

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
6	+2	38	230	Steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:

Perforations Y N Method _____
Manufactured screen Y N Type _____
Method of installation _____

From (ft)	To (ft)	Slot size	Number	Diameter (nominal)	Material	Gauge or Schedule

Length of Headpipe _____ Length of Tailpipe _____

Packer Y N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method
na	na	na	na na	na

11. FLOWING ARTESIAN:

Flowing Artesian? Y N Artesian Pressure (PSIG) _____
Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 265 Static water level (ft) 230
Water temp. (°F) 56 Bottom hole temp. (°F) _____
Describe access port Cap

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Test method:			
			Pump	Bailer	Air	Flowing artesian
35	20	1HR	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Water Quality test or comments:

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
10	0	2	Top Soil		X
10	2	8	Sandy Clay		X
10	8	15	Brown Clay		X
10	15	34	Brown Sandy Clay		X
10	34	38	Broken up Lava		X
6	38	54	Lava		X
6	54	57	Red Lava		X
6	57	81	Black Lava		X
6	81	83	Red Lava		X
6	83	101	Black Lava		X
6	101	104	Brown Lava		X
6	104	232	Brown Lava		X
6	232	245	Fractured Lava		X
6	245	258	Lava		X
6	258	265	Brown Lava		X
6	265	270	Coarse Sand	X	
6	270	280	Lava		X
6	280		Gravel	X	

Completed Depth (Measurable) 270
Date: Started 04/17/2014 Completed 4/20/2014

14. DRILLER'S CERTIFICATION

We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling Co. No. 560

*Principal Driller _____ Date _____
*Driller _____ Date _____
*Operator II _____ Date _____
Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.

Irrigation Well 1

63
Form 238-7
6/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0066300

Drilling Permit No. 965586-871645
Water right or injection well # 63-32680

2. OWNER

Name Ray Montierth
Address 825 Heartland Dr.
City Nampa State Id Zip 83686

3. WELL LOCATION:

Twp. 1 North or South Rge. 1 East or West
Sec. 14 sw 1/4 ne 1/4 ne 1/4
10 acres 40 acres 160 acres

Gov't Lot _____ County Ada
Lat. 43° 25.967 (Deg. and Decimal minutes)
Long. 116° 16.803 (Deg. and Decimal minutes)
Address of Well Site 1 mi. W. of S. Cole Rd 1 mi. S. of railroad ROW
City Kuna

(Give at least name of road - Distance to Road or Landmark)

Lot _____ Blk. _____ Sub. Name _____

4. USE:

Domestic Municipal Monitor Irrigation Thermal Injection
 Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

New Well Replacement well Modify existing well
 Abandonment Other _____

6. DRILL METHOD:

Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES

Seal material	From (ft)	To (ft)	Quantity (lbs or ft³)	Placement method/procedure
3/4 bentonite	0	38	23000 lbs	pour
cement	150	300	43 ft 3	trimmed

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
26	0	38	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
20	0	149	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
16	1	150	.250	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:

Perforations Y N Method _____
Manufactured screen Y N Type johnson
Method of installation set in

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
330	430	.40	100	16	ss	.375
440	540	.40	100	16	ss	.375

Length of Headpipe na Length of Tailpipe _____
Packer Y N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft³)	Placement method
silico sand	80	540	23000 lbs	pour

11. FLOWING ARTESIAN:

Flowing Artesian? Y N Artesian Pressure (PSIG) _____
Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) _____ Static water level (ft) _____
Water temp. (°F) 70 Bottom hole temp. (°F) 70
Describe access port flat plat

Well test:

Test method:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
23	3300	20 hr	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water Quality test or comments:

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
30	0	2	top soil		X
30	2	8	sandy clay		X
30	8	17	brown clay		X
30	17	35	brown sandy clay		X
30	35	38	broken up lava		X
25	38	73	lava		X
25	73	85	brown lava		X
25	85	130	lava		X
25	130	140	brown lava		X
25	140	153	fractured lava		X
25	153	175	red lava		X
25	175	186	brown lava		X
25	186	200	fractured lava		X
25	200	255	lava		X
25	255	266	brown lava		X
25	266	270	sand	X	
25	270	273	brown clay		X
25	273	278	lava		X
25	278	284	gravel	X	
20	284	291	coarse sand	X	
20	291	305	brown clay		X
20	305	317	brown sand	X	
20	317	335	brown clay		X
20	335	356	gravel	X	
20	356	360	brown clay		X
20	360	368	coarse sand	X	
20	368	373	medium sand	X	
20	373	378	brown clay		X
20	378	381	brown sand	X	
20	381	389	gravel	X	
20	389	410	coarse sand and gravel	X	
20	410	430	medium sand	X	

Completed Depth (Measurable)

Date: Started 4-16-14 Completed _____

14. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling Co. No. 560

*Principal Driller Monte Post Date 6-27-14

*Driller [Signature] Date 7-31-14

*Operator II _____ Date _____

Operator I Jeremy Bullock Date RECEIVED
*Signature of Principal Driller and rig operator are required.

JUL 03 2014

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

1. WELL TAG NO. D 0066300

Drilling Permit No. 965586-871645
Water right or injection well # 63-32680

2. OWNER

Name Ray Montierth
Address 825 Heartland Dr
City Nampa State Id Zip 83686

3. WELL LOCATION:

Twp. 1 North or South Rge. 1 East or West
Sec. 14 sw 1/4 ne 1/4 ne 1/4
10 acres 40 acres 160 acres

Gov't Lot _____ County Ada
Lat. 43 ° 25.967 (Deg. and Decimal minutes)
Long. 116 ° 16.803 (Deg. and Decimal minutes)
Address of Well Site 1 mi.W.of Cole Rd 1 mi. S. of railroad ROW
City Kuna

(Give at least name of road + Distance to Road or Landmark)
Lot _____ Blk. _____ Sub. Name _____

4. USE:

Domestic Municipal Monitor Irrigation Thermal Injection
 Other

5. TYPE OF WORK check all that apply (Replacement etc.)

New Well Replacement well Modify existing well
 Abandonment Other

6. DRILL METHOD:

Air Rotary Mud Rotary Cable Other

7. SEALING PROCEDURES

Seal material	From (ft)	To (ft)	Quantity (lbs or ft³)	Placement method/procedure

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
16	155	330	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
16	430	440	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:

Perforations Y N Method _____
Manufactured screen Y N Type _____
Method of installation _____

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule

Length of Headpipe _____ Length of Tailpipe _____
Packer Y N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft³)	Placement method

11. FLOWING ARTESIAN:

Flowing Artesian? Y N Artesian Pressure (PSIG) _____
Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 266 Static water level (ft) 225
Water temp. (°F) 70 Bottom hole temp. (°F) 70
Describe access port flat plate

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Test method:			
			Pump	Bailer	Air	Flowing artesian
23	3300	20 hr	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water Quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
20	430	438	brown clay		x
20	438	455	corse sand	x	
20	455	480	gravel	x	
20	480	499	corse sand	x	
20	499	502	brown clay		x
20	502	508	medium sand	x	
20	508	513	brown clay		x
20	513	518	gravel	x	
20	518	540	brown clay with sand strips	x	

RECEIVED

JUL 03 2014

WATER RESOURCES
WESTERN REGION

Completed Depth (Measurable) 540

Date: Started 4-16-14 Completed 6-4-14

14. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling Co. No. 560

*Principal Driller Monte Post Date 6-27-14

*Driller _____ Date _____

*Operator II _____ Date _____

Operator I Jeremy Bullard Date 6-27-14
*Signature of Principal Driller and rig operator are required.

63

Irrigation Well 2

10 of 2

Form 238-7
6/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0067448
 Drilling Permit No. 967343-873402
 Water right or injection well # _____

2. OWNER:
 Name Ray Montierth
 Address 825 Hartland
 City Nampa State ID Zip 83686

3. WELL LOCATION:
 Twp. 1 North or South Rge. 1 East or West
 Sec. 13 _____ 1/4 _____ 1/4 _____ 1/4 _____ 1/4 _____
 Gov't Lot _____ County ADA
 Lat. 43 _____ (Deg. and Decimal minutes)
 Long. 116 _____ (Deg. and Decimal minutes)
 Address of Well Site S.Cole

(Give at least name of road - Distance to Road or Landmark)
 City Kuna
 Lot. _____ Blk. _____ Sub. Name _____

4. USE:
 Domestic Municipal Monitor Irrigation Thermal Injection
 Other _____

5. TYPE OF WORK:
 New well Replacement well Modify existing well
 Abandonment Other _____

6. DRILL METHOD:
 Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
3/4 bentonite	0	39	4000 lbs	pour
concrete	270	300	3 1/2 yd	pumped

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
26	0	39	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
20	1	284	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
16	270	350	.250	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
16	510	535	.250	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:
 Perforations Y N Method _____
 Manufactured screen Y N Type Alloy
 Method of installation set in

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
350	510	.35	160	16	ss	.98
535	575	.35	40	16	ss	.98

Length of Headpipe 80 Length of Tailpipe _____
 Packer Y N Type double wing k-packer

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method
6/9 silica sand	305	575	16500 lbs	pour

11. FLOWING ARTESIAN:
 Flowing Artesian? Y N Artesian Pressure (PSIG) _____
 Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:
 Depth first water encountered (ft) 293 Static water level (ft) 236
 Water temp. (°F) 70 Bottom hole temp. (°F) 70
 Describe access port flat plate

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
22	2980	6 hr	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (In)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
30	0	3	top soil		x
30	3	27	sandy clay		x
30	27	35	coarse sand		x
30	35	39	red clay		x
24	39	65	hard lava		x
24	65	69	red cinders		x
24	69	82	gray lava		x
24	82	87	red broken up lava		x
24	87	99	black lava		x
24	99	101	broken up lava		x
24	101	107	gray lava		x
24	107	111	red lava		x
24	111	122	gray lava		x
24	122	151	gray broken up lava		x
24	151	158	black broken up lava		x
24	158	170	brown and red cinders		x
24	170	223	gray lava		x
24	223	230	broken up lava		x
24	230	258	black lava		x
24	258	267	coarse sand		x
24	267	286	brown lava		x
24	286	293	broken up lava		x
24	293	305	red cinders	x	
20	305	320	brown clay and red cinders		x
20	320	335	brown clay		x
20	335	370	gravel	x	
20	370	373	brown clay		x
20	373	429	coarse sand and gravel	x	
20	429	431	brown clay		x
20	431	435	coarse sand	x	
20	435	438	brown clay		x
20	438	445	gravel	x	

RECEIVED
JAN 05 2015
 WATER RESOURCES
 WESTERN REGION

Completed Depth (Measurable): 575
 Date Started: 9-14-14 Date Completed: 11-21-14

14. DRILLER'S CERTIFICATION:
 I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling Co. No. 560
 *Principal Driller Monte Post Date 11-30-14
 *Driller Jeremy Bulluck Date 11-30-14
 *Operator II _____ Date _____
 Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.

63

2 of 2

Form 238-7
6/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0067448

Drilling Permit No. 9167343-873402
Water right or injection well # _____

2. OWNER:

Name Ray Montierth
Address 825 Hartland
City Nampa State Id Zip 83686

3. WELL LOCATION:

Twp. 1 North or South Rge. 1 East or West
Sec. 13 1/4 NW 1/4 NW 1/4

Gov't Lot _____ County ada
Lat. 43 ° 25.608 (Deg. and Decimal minutes)
Long. 116 ° 17.611 (Deg. and Decimal minutes)
Address of Well Site S.Cole
City Kuna

Lot _____ Blk. _____ Sub. Name _____

4. USE:

Domestic Municipal Monitor Irrigation Thermal Injection
 Other _____

5. TYPE OF WORK:

New well Replacement well Modify existing well
 Abandonment Other _____

6. DRILL METHOD:

Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
3/4 bentonite	270	250	750 lbs	pour

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:

Perforations Y N Method _____

Manufactured screen Y N Type _____

Method of installation _____

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule

Length of Headpipe _____ Length of Tailpipe _____

Packer Y N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method

11. FLOWING ARTESIAN:

Flowing Artesian? Y N Artesian Pressure (PSIG) _____

Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 293 Static water level (ft) 236
Water temp. (°F) 70 Bottom hole temp. (°F) 70

Describe access port flat plate

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)
22	2980	6 hr

Test method:

Pump	Bailer	Air	Flowing artesian
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
20	445	447	brown clay		x
20	447	496	gravel	x	
20	496	511	brown clay		x
20	511	513	gravel	x	
20	513	516	brown clay		x
20	516	519	gravel	x	
20	519	536	brown clay		x
20	536	540	gravel	x	
20	540	547	brown clay		x
20	547	549	gravel	x	
20	549	551	brown clay		x
20	551	569	gravel	x	
20	569	575	brown clay		x

RECEIVED

JAN 05 2015

WATER RESOURCES
WESTERN REGION

Completed Depth (Measurable): 575

Date Started: 9-14-14

Date Completed: 11-21-14

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling Co. No. 560

*Principal Driller Monte Post Date 11-30-14

*Driller Jeremy Balllock Date 11-30-14

*Operator II _____ Date _____

Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.

Irrigation Well 3

Form 238-7
6/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D0071844

Drilling Permit No. _____
Water right or injection well # 63-33207-3403863-32680

2. OWNER: _____

Name JR Simplot Company
Address PO box 27
City Boise State Idaho Zip 83707

3. WELL LOCATION:

Twp. 1 North or South Rge. 1 East or West
Sec. 14 1/4 NE 1/4 SE 1/4

Gov't Lot _____ County Ada
Lat. 43 o 25.154 (Deg. and Decimal minutes)
Long 116 o 17.628 (Deg. and Decimal minutes)
Address of Well Site West of S. Cole rd. south of train tracks
City Kuna
(Give at least name of road - Distance to Road or Landmark)
Lot _____ Blk. _____ Sub. Name _____

4. USE:
 Domestic Municipal Monitor Irrigation Thermal Injection
 Other _____

5. TYPE OF WORK:
 New well Replacement well Modify existing well
 Abandonment Other _____

6. DRILL METHOD:
 Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
3/8 chip	0	53	15800	overbore
3/8 chip	280	265	500lbs	overbore

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
26	0	53	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
20	+1	280	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
16	257	345	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:
Perforations Y N Method _____
Manufactured screen Y N Type Johnson S.S.
Method of installation set in

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
545	345	.040		16"	S.S	.250

Length of Headpipe _____ Length of Tailpipe _____
Packer Y N Type Double k 257-255

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method
6-9 silica	545	273	8700lbs	overbore

11. FLOWING ARTESIAN:
Flowing Artesian? Y N Artesian Pressure (PSIG) _____
Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:
Depth first water encountered (ft) 280 Static water level (ft) 270
Water temp. (°F) 74 Bottom hole temp. (°F) _____
Describe access port flat plate

Well test: _____ Test method: _____

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
60'	3425		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
36	0	4	top soil		
36	4	12	sand		
36	42	53	brown clay		
25	53	78	black basalt		
25	78	86	red cinder		
25	86	192	black basalt		
25	192	204	brown clay		
25	204	227	sand and brown clay		
25	227	259	fractured basalt		
25	259	271	brown sand		
25	271	280	basalt		X
19	280	303	basalt		X
19	303	309	fractured basalt		X
19	309	318	baked brown clay		
19	318	324	sticky brown clay		
19	324	326	brown silt		X
19	326	329	sticky brown clay		
19	329	334	fine brown sand and silt		
19	334	347	sticky brown clay		
19	347	349	fine brown sand		X
19	349	357	sticky brown clay		
19	357	368	cemented sand		X
19	368	370	sticky brown clay		
19	370	394	brown sand and pea gravel		X
19	394	417	sticky brown clay		
19	417	436	brown sand		X
19	436	444	sticky brown clay		
19	444	529	brown sand with small clay seams		
19	529	555	sticky tan clay		

Completed Depth (Measurable) 545
Date Started 5-15-16 Date Completed 6-30-16

14. DRILLER'S CERTIFICATION:
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.
Company Name Treasure Valley Drilling Co. No. 560
*Principal Driller _____ Date Jul 26, 2016
*Driller [Signature] Date Jul 26, 2016
*Operator II [Signature] Date 5/27/2016
Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required

Monitoring Well

Form 238-7
6/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0066301

Drilling Permit No. **965601-871660**
Water right or injection well # _____

2. OWNER

Name **Ray Montierth**
Address **825 Hearland Dr**
City **Nampa** State **Id** Zip **83686**

3. WELL LOCATION:

Twp. **1** North or South Rge. **1** East or West
Sec. **12** NE 1/4 SW 1/4 SE 1/4

Gov't Lot _____ County **Ada**
Lat. **43° 25.967** (Deg. and Decimal minutes)
Long. **116° 16.803** (Deg. and Decimal minutes)
Address of Well Site **1/4 mi.w. of Cole Rd 1/4 mi.s. of railroad ROW**
City **Kuna**

Lot. _____ Blk. _____ Sub. Name _____

4. USE:

Domestic Municipal Monitor Irrigation Thermal Injection
 Other

5. TYPE OF WORK check all that apply (Replacement etc.)

New Well Replacement well Modify existing well
 Abandonment Other

6. DRILL METHOD:

Air Rotary Mud Rotary Cable Other

7. SEALING PROCEDURES

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
gran/bentoni	0	80	3600/lbs	pour

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
10	+3	4	.250	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
6	+2	378	.250	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
5	368	388	.250	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) **376**

9. PERFORATIONS/SCREENS:

Perforations Y N Method _____
Manufactured screen Y N Type **johnson**
Method of installation **set in**

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
388	398	.16	10 ft	5	ss	.250

Length of Headpipe **20** Length of Tailpipe _____
Packer Y N Type **neoprene**

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method

11. FLOWING ARTESIAN:

Flowing Artesian? Y N Artesian Pressure (PSIG) _____
Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) **280** Static water level (ft) **268**
Water temp. (°F) **72** Bottom hole temp. (°F) _____
Describe access port **cap**

Well test:

Test method:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
122	40	2hr	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Water Quality test or comments: **tested great, no smell, no sand**

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
10	0	2	top soil		X
10	2	9	brokin up lava		X
10	9	37	black lava		X
10	37	40	soft		X
8	39	46	brown lava		X
8	46	68	black lava		X
8	68	70	brown lava		X
8	70	84	black lava		X
8	84	86	fractured lava		X
8	86	88	crack		X
8	88	127	lava		X
8	127	131	soft lava		X
8	131	162	lava		X
8	162	170	soft lava		X
8	170	230	lava		X
8	230	238	sinders		X
6	238	262	gravel	X	
6	262	268	clay		X
6	268	340	gravel sand	X	
6	340	343	clay		X
6	343	347	gravel	X	
6	347	351	clay		X
6	351	356	sand	X	
6	356	360	clay		X
6	360	367	sand	X	
6	367	370	clay		X
6	370	375	sand	X	
6	375	378	clay		X
6	378	385	gravel	X	
6	385	387	clay		X
6	387	404	corse sand	X	

Completed Depth (Measurable) **398**

Date: Started **July 8, 2014** Completed **July 20, 2014**

14. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name **Treasure Valley Drilling** Co. No. **560**

*Principal Driller *Monte Ross* Date **4-3-15**

*Driller _____ Date _____

*Operator II _____ Date _____

Operator I *Pete L. ...* Date **4-3-15**
Signature of Principal Driller and rig operator are required.

RECEIVED

APR 03 2015

WATER RESOURCES
WESTERN REGION

Appendix C
Totalizer Photos




Irrigation Well No. 1 Totalizer (11/17/2017)



Irrigation Well No. 2 Totalizer (11/17/2017)



Irrigation Well No. 3 Totalizer (11/17/2017)



Plant Well #1 (East) Totalizer (12/29/2017)



Plant Well #2 (West) Totalizer (12/29/2017)

Close

IDAHO DEPARTMENT OF WATER RESOURCES
Water Permit Report

2/5/2017

WATER RIGHT NO. 63-34038

<u>Owner Type</u>	<u>Name and Address</u>
Current Owner	CS PROPERTY DEVELOPMENT LLC PO BOX 27 BOISE, ID 83707 (208)336-2110
Original Owner	J R SIMPLOT COMPANY PO BOX 27 BOISE, ID 83707 (208)336-2110
Security Interest	WELLS FARGO BANK FOOD & AGRIBUSINESS COMMERCIAL BANKING OFFICE 905 S FILLMORE STE 701 MAC T3005-072 AMARILLO, TX 79101 806-371-3769

Priority Date: 06/26/2015
Status: Active

<u>Source</u>	<u>Tributary</u>
GROUND WATER	

<u>Beneficial Use</u>	<u>From</u>	<u>To</u>	<u>Diversion Rate</u>	<u>Volume</u>
IRRIGATION	03/01	11/15	3.2 CFS	
INDUSTRIAL	01/01	12/31	4 CFS	
Total Diversion			4 CFS	

Location of Point(s) of Diversion:

GROUND WATER	SWSE	Sec. 11	Township 01N	Range 01E	ADA County
GROUND WATER	SESE	Sec. 11	Township 01N	Range 01E	ADA County
GROUND WATER	SWNW	Sec. 12	Township 01N	Range 01E	ADA County
GROUND WATER	SENE	Sec. 12	Township 01N	Range 01E	ADA County
GROUND WATER	NWNE	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NWNW	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NESE	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NENE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWNE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	SWNE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	SENE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NESE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWSE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWSW Lt 6	Sec. 06	Township 01N	Range 02E	ADA County
GROUND WATER	NWSW Lt 6	Sec. 06	Township 01N	Range 02E	ADA County
GROUND WATER	SWSW Lt 7	Sec. 06	Township 01N	Range 02E	ADA County
GROUND WATER	SWSW Lt 7	Sec. 06	Township 01N	Range 02E	ADA County

INDUSTRIAL Use:

Number of other uses: meat process & packing

Place(s) of use:

Place of Use Legal Description: IRRIGATION ADA County

<u>Township</u>	<u>Range</u>	<u>Section</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>
01N	01E	11		SWSE	40		SESE	40						
		12		NENW	40		NWNW	40		SWNW	40		SENE	40
				NESW	40		NWSW	40		SWSW	40		SESW	40
				NWSE	40		SWSE	40		SESE	40			
		13		NENE	40		NWNE	40		SWNE	40		SENE	40
				NENW	40		NWNW	40						
				NESE	40									
		14		NENE	40		NWNE	40		SWNE	40		SENE	40
				SWNW	40		SENE	40						
				NESW	40		NWSW	40		SWSW	40		SESW	40
				NESE	40		NWSE	40		SWSE	40		SESE	40
		23		NENE	40		NWNE	40						
				NENW	40		NWNW	40						
		24		NENW	40		NWNW	40		SWNW	40		SENE	40

Place of Use Legal Description: INDUSTRIAL ADA County

Township	Range	Section	Lot	Tract	Acres	Lot	Tract	Acres	Lot	Tract	Acres	Lot	Tract	Acres
01N	01E	11		SWSE			SESE							
		12		NENW			NWNW			SWNW			SENE	
				NESW			NWSW			SWSW			SESW	
				NWSE			SWSE			SESE				
		13		NENE			NWNE			SWNE			SENE	
				NENW			NWNW			SWNW			SENE	
				NESW			NWSW			SWSW			SESW	
				NESE			SWSE			SESE				
		14		NENE			NWNE			SWNE			SENE	
				NESE			NWSE							
		23		NENE			NWNE							
				NENW			NWNW							
		24		NENW			NWNW			SWNW			SENE	
	02E	6		NESW			SESW							
				NWSE			SWSE							

Total Acres: 1680

Conditions of Approval:

1. 26A Project construction shall commence within one year from the date of permit issuance and shall proceed diligently to completion unless it can be shown to the satisfaction of the Director of the Department of Water Resources that delays were due to circumstances over which the permit holder had no control.
2. Each point of diversion (well) authorized for this right shall include a measuring device or other suitable method to allow measurement of the static water level in the well. Water level measurements shall be made monthly throughout the year from the beginning of the diversion and use of water in connection with this right until notified by the Department. The records shall be made available to the Department upon request.
3. 196 The right holder shall install or construct a straight length of conduit or ditch suitable for installation of a device for measuring the entire flow of water being diverted in connection with this right. If the right holder uses conduit, the straight length of conduit shall be at least fifteen times the diameter of the conduit and shall be above ground or otherwise easily accessible.
4. The right holder shall install a measuring device acceptable to the Department at each point of diversion authorized under this right. The measuring device shall be capable of displaying diversion flow rate and totalized volume measurement. The right holder shall record the flow rate and volume measurements monthly for any calendar year in which water is diverted and used in connection with this right until notified by the Department. The records shall be made available to the Department upon request.

5. 073 Diversion and use of water with a temperature greater than 85 degrees Fahrenheit is not authorized under this right.
6. If the Department determines based on credible evidence, measurement reports, area data or otherwise that diversion and use of ground water under this right is causing material injury to any senior water right(s), the Department may order the diversion reduced, the diversion curtailed, or the right holder to provide adequate mitigation to remedy the injury.
7. Prior to submitting proof of beneficial use, the right holder shall not assign ownership of the permit to another individual, corporation, partnership, or association without prior approval of the Department.
8. Proof of beneficial use may not be submitted until one month prior to the deadline to submit proof of beneficial use set forth in these conditions; provided, however, if less than four (4) years of ground water monitoring data have been collected while beneficial use authorized under this permit has occurred, then an extension of time for up to five additional years shall be requested by the permit holder. The permit holder shall submit a report from a qualified professional engineer, hydrologist, or hydrogeologist summarizing hydrogeologic data collected to fulfill the conditions of approval of this permit. Submittal of a proof of beneficial use statement without the required data and report will not be accepted by the Department and may result in lapse of the permit.
9. 046 Right holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code and applicable Well Construction Rules of the Department.
10. R65 This right when combined with all other rights shall provide no more than 0.02 cfs per acre nor more than 4.5 afa per acre at the field headgate for irrigation of the place of use.
11. 121 The Director retains jurisdiction to require the right holder to provide purchased or leased natural flow or stored water to offset depletion of Lower Snake River flows if needed for salmon migration purposes. The amount of water required to be released into the Snake River or a tributary, if needed for this purpose, will be determined by the Director based upon the reduction in flow caused by the use of water pursuant to this permit.
12. 069 Failure of the right holder to comply with any condition of approval is cause for the Director to cancel this permit.

Dates:

Proof Due Date: 11/01/2020

Proof Made Date:

Approved Date: 10/26/2015

Moratorium Expiration Date:

Enlargement Use Priority Date:

Enlargement Statute Priority Date:

Application Received Date: 09/07/2016

Protest Deadline Date: 01/02/2017

Number of Protests: 0

Field Exam Date::

Date Sent to State Off:

Date Received at State Off:

Other Information:

State or Federal:

Owner Name Connector:
Water District Number:
Generic Max Rate per Acre: 0.02
Generic Max Volume per Acre: 4.5
Swan Falls Trust or Nontrust:
Swan Falls Dismissed:
DLE Act Number:
Cary Act Number:
Mitigation Plan: False

Appendix B
Well Driller's Reports for Production and
Monitoring Wells

Plant Well 1

RECEIVED

Form 238-7
6/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

OCT 06 2015

WATER RESOURCES
WESTERN REGION

03

1. WELL TAG NO. D 0069003

Drilling Permit No. 948748-874825

Water right or injection well # _____

2. OWNER: JR Simplot Co.

Name _____

Address P.O. Box 27

City Boise State Idaho Zip 83707

3. WELL LOCATION:

Twp 1 North or South Rge 2 East or West

Sec. 6 NW 1/4 SW 1/4 (1/4 section) (1/4 section)

Gov't Lot _____ County ADA

Lat. 43 ° 26.841 (Deg. and Decimal minutes)

Long. 116 ° 16.380 (Deg. and Decimal minutes)

Address of Well Site S. Cole Rd. 1/4 mile North of Barker

City Kuna

(Give at least name of road + distance to West of landmark)

Lot _____ Blk. _____ Sub. Name _____

4. USE:

Domestic Municipal Monitor Irrigation Thermal Injection

Other _____

5. TYPE OF WORK:

New well Replacement well Modify existing well

Abandonment Other _____

6. DRILL METHOD:

Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
Neat cement	188ft	0	9 yd3	pumped
Neat cement	315ft	0	11 yd3	pumped

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
20"	0	188	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
14"	+2	395	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:

Perforations Y N Method _____

Manufactured screen Y N Type Joston

Method of installation set in

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
395	455	30	60ft	14"	ss	.375

Length of Headpipe _____ Length of Tailpipe _____

Packer Y N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method
6-9	315	455	9850lbs	trimmie

11. FLOWING ARTESIAN:

Flowing Artesian? Y N Artesian Pressure (PSIG) _____

Describe control device plat

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 315 Static water level (ft) 294

Water temp (°F) 83 Bottom hole temp. (°F) 83

Describe access port _____

Well test:	Discharge or yield (gpm)	Test duration (minutes)	Test method:			
			Pump	Basin	Air	Flowing artesian
43.1	1520	7.7 hrs	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
24	0	2	top soil		
24	2	8	sandy dirt and gravel		
24	8	30	hard black lava		
24	30	38	broken soft black lava		
24	38	44	hard black lava		
24	44	48	soft red lava		
24	48	55	hard black lava		
24	55	77	soft black lava		
24	77	95	hard black lava		
24	95	105	soft black lava		
24	105	135	hard black lava		
24	135	145	soft black lava		
24	145	155	red cinders		
24	155	162	hard black lava		
24	162	177	hard black lava		
19	177	312	large gravel and sand		
19	312	315	rock and clay		
19	315	320	sand and gravel		
19	320	325	rock and clay		
19	325	402	sand and gravel		
19	402	425	white clay		
19	425	448	sand and gravel		
19	448	460	brown clay with gravel		
19	460	465	sand and gravel		
19	465	471	brown clay and little rock		
19	471	477	sand and gravel		
19	477	490	brown clay and rock		
19	490	523	big gravel and sand		
19	523	531	sand and gravel		
19	531	543	gravel and sand with clay		
19	543	555	sandstone		
19	555	560	gravel and sand		
Completed Depth (Measurable): <u>455</u>					
Date Started: <u>6/1/2015</u>		Date Completed: <u>9/16/2015</u>			

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were compiled with at the time the rig was removed.

Company Name Treasure Valley Drilling Co. No 560

*Principal Driller: [Signature] Date 9-22-15

*Driller _____ Date _____

*Operator II _____ Date _____

Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0069003

Drilling Permit No _____

Water right or injection well # _____

2. OWNER: J R Simplot Co.

Name _____

Address P.O. Box 27

City Boise State ID Zip 83707

3. WELL LOCATION:

Twp. 1 North or South Rge. 2 East or West

Sec. 6 NW 1/4 SW 1/4 _____ 1/4 _____

Gov't Lot _____ County Ada

Lat. _____ (Deg. and Decimal minutes)

Long. _____ (Deg. and Decimal minutes)

Address of Well Site S Cole Rd 1/4 mile north of Gader

City Kuna

(Give at least name of road + distance to head of landmark)

Lot _____ Blk. _____ Sub. Name _____

4. USE:

Domestic Municipal Monitor Irrigation Thermal Injection

Other _____

5. TYPE OF WORK:

New well Replacement well Modify existing well

Abandonment Other _____

6. DRILL METHOD:

Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft)	Placement method/procedure
Neat Cement	188'	0	13 Yards	Pumped
Neat Cement	315'	0	10 1/2 Yards	Pumped

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
20"	0	188	.375	Steel Casing	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
14"	42	395	.375	Steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:

Perforations Y N Method _____

Manufactured screen Y N Type Alloy Screen

Method of installation Set in

From (ft)	To (ft)	Slot size	Number	Diameter (nominal)	Material	Gauge or Schedule
395	455		60		Stainless	.375

Length of Headpipe _____ Length of Tailpipe _____

Packer Y N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft)	Placement method
6-9	315	455	9,850 lbs	Tremie

11. FLOWING ARTESIAN:

Flowing Artesian? Y N Artesian Pressure (PSIG) _____

Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 315 Static water level (ft) 294

Water temp. (°F) 83 Bottom hole temp (°F) 83

Describe access port _____

Well test:			Test method:			
Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
33	200	60	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
24"	0	2	TOP SOIL		
"	2	8	Sandy dirt / Gravel		
"	8	30	Hard black lava		
"	30	38	Broken / soft black lava		
"	38	44	Hard black lava		
"	44	48	soft red lava		
"	48	55	Hard black lava		
"	55	77	Soft black lava		
"	77	95	Hard black lava		
"	95	105	Soft black lava		
"	105	135	Hard black lava		
"	135	145	Soft black lava		
"	145	155	red cinders		
"	155	160	Hard black lava		
"	160	177	Hard black lava		
19"	177	312	Big Gravels + Sand		
"	312	315	Rock + Clay		
"	315	320	Sand + Gravel		
"	320	325	rock + Clay		
"	325	402	Sand + Gravel		
"	402	425	White Clay		
"	425	448	Sand + Gravel		
"	448	460	brn clay with gravel		
"	460	465	Sand + Gravel		
"	465	471	Brn clay + little rock		
"	471	477	Sand + Gravel		
"	477	490	Brn clay + rock		
"	490	523	Big Gravels + Sand		
"	523	531	Sand + Gravel		
"	531	543	Gravels and little clay		
"	543	555	sandstone		
"	555	560	Gravel + Sand		

Completed Depth (Measurable): 455

Date Started: 7-1-15 Date Completed: 8-30-15

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

560

Company Name Trousdale Valley Drilling and Pump

*Principal Driller Shawn Mikelson Date 9-28-15

*Driller Shawn Mikelson Date 9-28-15

*Operator II _____ Date _____

Operator I _____ Date _____

*Signature of Principal Driller and rig operator are required

RECEIVED

OCT 02 2015

WATER RESOURCES
WESTERN REGION

Plant Well 2

Form 238-7
6/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0070211

Drilling Permit No 970455-876512

Water right or injection well # 63-33207

2. OWNER: JR Simplot Company

Name _____

Address PO Box 27

City Boise State Idaho Zip 83707

3. WELL LOCATION:

Twp. 1 North or South Rge 2 East or West

Sec. 6 1/4 SW 1/4 SW 1/4

Gov't Lot 7 County _____

Lat. 43 26.845 (Deg. and Decimal minutes)

Long -116 16.419 (Deg. and Decimal minutes)

Address of Well Site 150' East of south cole rd

1075' North of Barker Rd City Near Kuna

(Give at least portion of road - Distance to West or East side)

Lot. _____ Blk. _____ Sub. Name _____

4. USE:

Domestic Municipal Monitor Irrigation Thermal Injection

Other Industrial

5. TYPE OF WORK:

New well Replacement well Modify existing well

Abandonment Other _____

6. DRILL METHOD:

Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
Neat cement	188	0	9yd3	pumped
Neat cement	315	0	11yd3	pumped

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
26	0	11	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
20	+1	176	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
14	+1	395	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:

Perforations Y N Method _____

Manufactured screen Y N Type _____

Method of installation _____

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
395	455	40	60	14	ss	.375

Length of Headpipe _____ Length of Tailpipe _____

Pecker Y N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method
silica sand	320	455	8400lbs	trimmie

11. FLOWING ARTESIAN:

Flowing Artesian? Y N Artesian Pressure (PSIG) _____

Describe control device plat

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 290 Static water level (ft) 289

Water temp. (°F) 82 Bottom hole temp. (°F) 82

Describe access port _____

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Test method:			
			Pump	Bailer	Air	Flowing artesian
338	2190	4hrs	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
32	0	1	top soil		X
32	1	11	bleachy basalt		
26	11	93	weathered basalt		
26	93	97	red cinders		
26	97	124	black basalt		
26	124	128	red cinders		
26	128	176	hard black basalt		
20	176	188	sand and gravel		
20	188	211	gravel and basalt boulders		
20	211	255	sand and gravel boulders		
20	255	286	cemented gravel		
20	286	290	sand and gravel		X
20	290	367	clay		
20	367	376	sand		
20	376	480	pea gravel and silty sand		

Completed Depth (Measurable) 455

Date Started 9/10/2015 Date Completed 9/30/2015

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling Co. No. 560

*Principal Driller: [Signature] Date 9-30-15

*Driller _____ Date _____

*Operator II _____ Date _____

Operator I _____ Date _____

*Signature of Principal Driller and rig operator are required.

Drill Water Supply Well (Monitoring)

Form 238-7
6/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0066263

Drilling Permit No. _____
Water right or injection well # _____

2. OWNER

Name Ray Montberth
Address 825 Hartland Dr
City Nampa State ID Zip 83686

3. WELL LOCATION:

Twp. 1 North or South Rge. 1 East or West
Sec. 14 1/4 SE 1/4 NE 1/4

Gov't Lot _____ County ADA
Lat. 34 ° 25.612 (Deg. and Decimal minutes)
Long. 116 ° 17.845 (Deg. and Decimal minutes)

Address of Well Site Cross tracks on Cole heading south first right
1 mile left 1/2 mile left 1/4 mile City Kuna

Lot _____ Blk _____ Sub. Name _____

4. USE:

Domestic Municipal Monitor Irrigation Thermal Injection
 Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

New Well Replacement well Modify existing well
 Abandonment Other _____

6. DRILL METHOD:

Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
Bentonite	0	38	950lbs	Pour

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
6	+2	38	.230	Steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:

Perforations Y N Method _____
Manufactured screen Y N Type _____
Method of installation _____

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule

Length of Headpipe _____ Length of Tailpipe _____

Packer Y N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method
na	na	na	na	na

11. FLOWING ARTESIAN:

Flowing Artesian? Y N Artesian Pressure (PSIG) _____
Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 265 Static water level (ft) 230
Water temp. (°F) 56 Bottom hole temp. (°F) _____
Describe access port Cap

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Test method:			Flowing artesian
			Pump	Bailer	Air	
35	20	1HR	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Water Quality test or comments:

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water Y N
10	0	2	Top Soil	X
10	2	8	Sandy Clay	X
10	8	15	Brown Clay	X
10	15	34	Brown Sandy Clay	X
10	34	38	Broken up Lava	X
6	38	54	Lava	X
6	54	57	Red Lava	X
6	57	81	Black Lava	X
6	81	83	Red Lava	X
6	83	101	Black Lava	X
6	101	104	Brown Lava	X
6	104	232	Brown Lava	X
6	232	245	Fractured Lava	X
6	245	258	Lava	X
6	258	265	Brown Lava	X
6	265	270	Coarse Sand	X
6	270	280	Lava	X
6	280		Gravel	X

Completed Depth (Measurable) 270
Date: Started 04/17/2014 Completed 4/20/2014

14. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling Co. No. 560

*Principal Driller _____ Date _____

*Driller _____ Date _____

*Operator II _____ Date _____

Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.

Irrigation Well 1

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0066300
 Drilling Permit No. 965586-871645
 Water right or injection well # 63-32680

2. OWNER
 Name Ray Montierth
 Address 825 Heartland Dr.
 City Nampa State Id Zip 83686

3. WELL LOCATION:
 Twp. 1 North or South Rge. 1 East or West
 Sec. 14 sw 1/4 ne 1/4 ne 1/4
 Gov't Lot _____ County Ada
 Lat. 43° 25.967 (Deg. and Decimal minutes)
 Long. 116° 16.803 (Deg. and Decimal minutes)
 Address of Well Site 1 mi. w. of S. Cole Rd 1 mi. S. of railroad ROW
 City Kuna

(Give at least name of road - Distance to Road or Landmark)
 Lot _____ Blk. _____ Sub. Name _____

4. USE:
 Domestic Municipal Monitor Irrigation Thermal Injection
 Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)
 New Well Replacement well Modify existing well
 Abandonment Other _____

6. DRILL METHOD:
 Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES

Seal material	From (ft)	To (ft)	Quantity (lbs or ft³)	Placement method/procedure
3/4 bentonite	0	38	23000 lbs	pour
cement	150	300	43 ft 3	trimmed

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
26	0	38	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
20	0	149	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
16	1	150	.250	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:
 Perforations Y N Method _____
 Manufactured screen Y N Type johnson
 Method of installation set in

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
330	430	.40	100	16	ss	.375
440	540	.40	100	16	ss	.375

Length of Headpipe na Length of Tailpipe _____
 Packer Y N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft³)	Placement method
silico sand	80	540	23000 lbs	pour

11. FLOWING ARTESIAN:
 Flowing Artesian? Y N Artesian Pressure (PSIG) _____
 Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:
 Depth first water encountered (ft) _____ Static water level (ft) _____
 Water temp. (°F) 70 Bottom hole temp. (°F) 70
 Describe access port flat plat

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)
23	3300	20 hr

Test method:
 Pump Bailer Air Flowing artesian

Water Quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
30	0	2	top soil		X
30	2	8	sandy clay		X
30	8	17	brown clay		X
30	17	35	brown sandy clay		X
30	35	38	broken up lava		X
25	38	73	lava		X
25	73	85	brown lava		X
25	85	130	lava		X
25	130	140	brown lava		X
25	140	153	fractured lava		X
25	153	175	red lava		X
25	175	186	brown lava		X
25	186	200	fractured lava		X
25	200	255	lava		X
25	255	266	brown lava		X
25	266	270	sand	X	
25	270	273	brown clay		X
25	273	278	lava		X
25	278	284	gravel	X	
20	284	291	corse sand	X	
20	291	305	brown clay		X
20	305	317	brown sand	X	
20	317	335	brown clay		X
20	335	356	gravel	X	
20	356	360	brown clay		X
20	360	368	corse sand	X	
20	368	373	medium sand	X	
20	373	378	brown clay		X
20	378	381	brown sand	X	
20	381	389	gravel	X	
20	389	410	corse sand and gravel	X	
20	410	430	medium sand	X	

Completed Depth (Measurable) _____
 Date: Started 4-16-14 Completed _____

14. DRILLER'S CERTIFICATION
 I/We certify that all minimum well construction standards were compiled with at the time the rig was removed.
 Company Name Treasure Valley Drilling Co. No. 560
 *Principal Driller Monte Post Date 6-27-14
 *Driller [Signature] Date 7-31-14
 *Operator II _____ Date _____
 Operator I Jeremy Bullock Date 7-31-14
 *Signature of Principal Driller and rig operator are required.

JUL 03 2014

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

1. WELL TAG NO. D 0066300

Drilling Permit No. 965586-871645
Water right or injection well # 63-32680

2. OWNER

Name Ray Montierth
Address 825 Heartland Dr
City Nampa State Id Zip 83686

3. WELL LOCATION:

Twp. 1 North or South Rge. 1 East or West
Sec. 14 sw 1/4 ne 1/4 ne 1/4
10 acres 40 acres 160 acres

Gov't Lot _____ County Ada
Lat. 43 ° 25.967 (Deg. and Decimal minutes)
Long. 116 ° 16.803 (Deg. and Decimal minutes)
Address of Well Site 1 mi.W.of Cole Rd 1 mi. S. of railroad ROW
City Kuna

(Give at least name of road + Distance to Road or Landmark.)
Lot _____ Blk. _____ Sub. Name _____

4. USE:

Domestic Municipal Monitor Irrigation Thermal Injection
 Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

New Well Replacement well Modify existing well
 Abandonment Other _____

6. DRILL METHOD:

Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
16	155	330	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
16	430	440	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:

Perforations Y N Method _____
Manufactured screen Y N Type _____
Method of installation _____

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule

Length of Headpipe _____ Length of Tailpipe _____
Packer Y N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method

11. FLOWING ARTESIAN:

Flowing Artesian? Y N Artesian Pressure (PSIG) _____
Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 266 Static water level (ft) 225
Water temp. (°F) 70 Bottom hole temp. (°F) 70
Describe access port flat plate

Well test:

Test method:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
23	3300	20 hr	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water Quality test or comments:

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
20	430	438	brown clay		X
20	438	455	corse sand	X	
20	455	480	gravel	X	
20	480	499	corse sand	X	
20	499	502	brown clay		X
20	502	508	medium sand	X	
20	508	513	brown clay		X
20	513	518	gravel	X	
20	518	540	brown clay with sand strips	X	

RECEIVED

JUL 03 2014

WATER RESOURCES
WESTERN REGION

Completed Depth (Measurable) 540

Date: Started 4-16-14 Completed 6-4-14

14. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling Co. No. 560

*Principal Driller Monte Post Date 6-27-14

*Driller _____ Date _____

*Operator II _____ Date _____

Operator I Jeremy Bullock Date 6-27-14
*Signature of Principal Driller and rig operator are required.

603

Irrigation Well 2

10f2

Form 238-7
6/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0067448
 Drilling Permit No. 967343-873402
 Water right or injection well # _____

2. OWNER:
 Name Ray Montierth
 Address 825 Hartland
 City Nampa State ID Zip 83686

3. WELL LOCATION:
 Twp. 1 North or South Rge. 1 East or West
 Sec. 13 10 acres 1/4 nw 40 acres 1/4 nw 160 acres 1/4
 Gov't Lot _____ County ADA
 Lat. 43 25.608 (Deg. and Decimal minutes)
 Long. 116 17.611 (Deg. and Decimal minutes)
 Address of Well Site S.Cole
 City Kuna

4. USE:
 Domestic Municipal Monitor Irrigation Thermal Injection
 Other _____

5. TYPE OF WORK:
 New well Replacement well Modify existing well
 Abandonment Other _____

6. DRILL METHOD:
 Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
3/4 bentonite	0	39	4000 lbs	pour
concrete	270	300	3 1/2 yd	pumped

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
26	0	39	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
20	1	284	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
16	270	350	.250	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
16	510	535	.250	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:
 Perforations Y N Method _____
 Manufactured screen Y N Type Alloy
 Method of installation set in

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
350	510	.35	160	16	ss	.98
535	575	.35	40	16	ss	.98

Length of Headpipe 80 Length of Tailpipe _____
 Packer Y N Type double wing k-packer

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method
6/9 silica sand	305	575	16500 lbs	pour

11. FLOWING ARTESIAN:
 Flowing Artesian? Y N Artesian Pressure (PSIG) _____
 Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:
 Depth first water encountered (ft) 293 Static water level (ft) 236
 Water temp. (°F) 70 Bottom hole temp. (°F) 70
 Describe access port flat plate

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
22	2980	6 hr	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
30	0	3	top soil		x
30	3	27	sandy clay		x
30	27	35	coarse sand		x
30	35	39	red clay		x
24	39	65	hard lava		x
24	65	69	red cinders		x
24	69	82	gray lava		x
24	82	87	red broken up lava		x
24	87	99	black lava		x
24	99	101	broken up lava		x
24	101	107	gray lava		x
24	107	111	red lava		x
24	111	122	gray lava		x
24	122	151	gray broken up lava		x
24	151	158	black broken up lava		x
24	158	170	brown and red cinders		x
24	170	223	gray lava		x
24	223	230	broken up lava		x
24	230	258	black lava		x
24	258	267	coarse sand		x
24	267	286	brown lava		x
24	286	293	broken up lava		x
24	293	305	red cinders	x	
20	305	320	brown clay and red cinders		x
20	320	335	brown clay		x
20	335	370	gravel	x	
20	370	373	brown clay		x
20	373	429	coarse sand and gravel	x	
20	429	431	brown clay		x
20	431	435	coarse sand	x	
20	435	438	brown clay		x
20	438	445	gravel	x	

RECEIVED
JAN 05 2015
 WATER RESOURCES
 WESTERN REGION

Completed Depth (Measurable): 575
 Date Started: 9-14-14 Date Completed: 11-21-14

14. DRILLER'S CERTIFICATION:
 I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling Co. No. 560
 *Principal Driller M. Bate Post Date 11-30-14
 *Driller Jeremy Bullak Date 11-30-14
 *Operator II _____ Date _____
 Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.

63

2 of 2

Form 238-7
6/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0067448
Drilling Permit No. 9167343-873402
Water right or injection well # _____

2. OWNER:
Name Ray Montieth
Address 825 Hartland
City Nampa State Id Zip 83686

3. WELL LOCATION:
Twp. 1 North or South Rge. 1 East or West
Sec. 13 1/4 NW 1/4 NW 1/4

Gov't Lot _____ County ada
Lat. 43 ° 25.608 (Deg. and Decimal minutes)
Long. 116 ° 17.611 (Deg. and Decimal minutes)
Address of Well Site S.Cole
City Kuna

(Give at least name of road - Distance to Road or Landmark)
Lot _____ Blk. _____ Sub. Name _____

4. USE:
 Domestic Municipal Monitor Irrigation Thermal Injection
 Other _____

5. TYPE OF WORK:
 New well Replacement well Modify existing well
 Abandonment Other _____

6. DRILL METHOD:
 Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
3/4 bentonite	270	250	750 lbs	pour

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:
Perforations Y N Method _____

Manufactured screen Y N Type _____

Method of installation _____

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule

Length of Headpipe _____ Length of Tailpipe _____

Packer Y N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method

11. FLOWING ARTESIAN:
Flowing Artesian? Y N Artesian Pressure (PSIG) _____
Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:
Depth first water encountered (ft) 293 Static water level (ft) 236
Water temp. (°F) 70 Bottom hole temp. (°F) 70
Describe access port flat plate

Well test: _____ Test method:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Baller	Air	Flowing artesian
22	2980	6 hr	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
20	445	447	brown clay		x
20	447	496	gravel	x	
20	496	511	brown clay		x
20	511	513	gravel	x	
20	513	516	brown clay		x
20	516	519	gravel	x	
20	519	536	brown clay		x
20	536	540	gravel	x	
20	540	547	brown clay		x
20	547	549	gravel	x	
20	549	551	brown clay		x
20	551	569	gravel	x	
20	569	575	brown clay		x

RECEIVED

JAN 05 2015

WATER RESOURCES
WESTERN REGION

Completed Depth (Measurable): 575
Date Started: 9-14-14 Date Completed: 11-21-14

14. DRILLER'S CERTIFICATION:
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling Co. No. 560

*Principal Driller Monte Post Date 11-30-14

*Driller Jeremy Ballwork Date 11-30-14

*Operator II _____ Date _____

Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.

Irrigation Well 3

Form 238-7
6/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D0071844

Drilling Permit No. _____
Water right or injection well # 63-33207-3403863-32680

2. OWNER: _____

Name JR Simplot Company
Address PO box 27
City Boise State Idaho Zip 83707

3. WELL LOCATION:

Twp. 1 North or South Rge. 1 East or West
Sec. 14 1/4 NE 1/4 SE 1/4

Gov't Lot _____ County Ada

Lat. 43 o 25.154 (Deg. and Decimal minutes)

Long 116 o 17.628 (Deg. and Decimal minutes)

Address of Well Site West of S. Cole rd. south of train tracks

City Kuna

(Give at least name of road - Distance to Road or Landmark)

Lot _____ Blk. _____ Sub. Name _____

4. USE:

Domestic Municipal Monitor Irrigation Thermal Injection
 Other _____

5. TYPE OF WORK:

New well Replacement well Modify existing well
 Abandonment Other _____

6. DRILL METHOD:

Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
3/8 chip	0	53	15800	overbore
3/8 chip	280	265	500lbs	overbore

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
26	0	53	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
20	+1	280	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
16	257	345	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:

Perforations Y N Method _____

Manufactured screen Y N Type Johnson S.S.

Method of installation set in

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
545	345	.040		16"	S.S	250

Length of Headpipe _____ Length of Tailpipe _____

Packer Y N Type Double k 257-255

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method
6-9 silica	545	273	8700lbs	overbore

11. FLOWING ARTESIAN:

Flowing Artesian? Y N Artesian Pressure (PSIG) _____

Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 280 Static water level (ft) 270

Water temp. (°F) 74 Bottom hole temp. (°F) _____

Describe access port flat plate

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Ballor	Air	Flowing artesian
60'	3425		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Test method:

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
36	0	4	top soil		
36	4	12	sand		
36	42	53	brown clay		
25	53	78	black basalt		
25	78	86	red cinder		
25	86	192	black basalt		
25	192	204	brown clay		
25	204	227	sand and brown clay		
25	227	259	fractured basalt		
25	259	271	brown sand		
25	271	280	basalt		X
19	280	303	basalt		X
19	303	309	fractured basalt		X
19	309	318	baked brown clay		
19	318	324	sticky brown clay		
19	324	326	brown silt		X
19	326	329	sticky brown clay		
19	329	334	fine brown sand and silt		
19	334	347	sticky brown clay		
19	347	349	fine brown sand		X
19	349	357	sticky brown clay		
19	357	368	cemented sand		X
19	368	370	sticky brown clay		
19	370	394	brown sand and pea gravel		X
19	394	417	sticky brown clay		
19	417	436	brown sand		X
19	436	444	sticky brown clay		
19	444	529	brown sand with small clay seams		
19	529	555	sticky tan clay		

Completed Depth (Measurable) 545
Date Started 5-15-16 Date Completed 6-30-16

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed

Company Name Treasure Valley Drilling Co. No. 560

*Principal Driller _____ Date Jul 26, 2016

*Drill _____ Date Jul 26, 2016

*Operator II [Signature] Date 5/27/2016

Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required

Monitoring Well

Form 238-7
6/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0066301

Drilling Permit No. **965601-871660**

Water right or injection well # _____

2. OWNER

Name **Ray Montierth**

Address **825 Hearland Dr**

City **Nampa**

State **Id**

Zip **83686**

3. WELL LOCATION:

Twp. **1** North or South Rge. **1** East or West

Sec. **12** NE 1/4 SW 1/4 SE 1/4
10 acres 40 acres 160 acres

Gov't Lot _____ County **Ada**

Lat. **43° 25.967** (Deg. and Decimal minutes)

Long. **116° 16.803** (Deg. and Decimal minutes)

Address of Well Site **1/4 mi.w.of Cole Rd 1/4 mi.s.of railroad ROW**

City **Kuna**

(Give at least name of road + Distance to Road or Landmark)

Lot _____ Blk. _____ Sub. Name _____

4. USE:

Domestic Municipal Monitor Irrigation Thermal Injection
 Other _____

5. TYPE OF WORK check all that apply

(Replacement etc.)

New Well Replacement well Modify existing well

Abandonment Other _____

6. DRILL METHOD:

Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
gran/bentoni	0	80	3600/lbs	pour

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
10	+3	4	.250	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
6	+2	378	.250	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
5	368	388	.250	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) **376**

9. PERFORATIONS/SCREENS:

Perforations Y N Method _____

Manufactured screen Y N Type **johnson**

Method of installation **set in**

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
388	398	.16	10 ft	5	ss	.250

Length of Headpipe **20** Length of Tailpipe _____

Packer Y N Type **neoprene**

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method

11. FLOWING ARTESIAN:

Flowing Artesian? Y N Artesian Pressure (PSIG) _____

Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) **280** Static water level (ft) **268**

Water temp. (°F) **72** Bottom hole temp. (°F) _____

Describe access port **cap**

Well test:

Test method:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
122	40	2hr	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Water Quality test or comments: **tested great, no smell, no sand**

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
10	0	2	top soil		X
10	2	9	brokin up lava		X
10	9	37	black lava		X
10	37	40	soft		X
8	39	46	brown lava		X
8	46	68	black lava		X
8	68	70	brown lava		X
8	70	84	black lava		X
8	84	86	fractured lava		X
8	86	88	crack		X
8	88	127	lava		X
8	127	131	soft lava		X
8	131	162	lava		X
8	162	170	soft lava		X
8	170	230	lava		X
8	230	238	sinders		X
6	238	262	gravel	X	
6	262	268	clay		X
6	268	340	gravel sand	X	
6	340	343	clay		X
6	343	347	gravel	X	
6	347	351	clay		X
6	351	356	sand	X	
6	356	360	clay		X
6	360	367	sand	X	
6	367	370	clay		X
6	370	375	sand	X	
6	375	378	clay		X
6	378	385	gravel	X	
6	385	387	clay		X
6	387	404	corse sand	X	

Completed Depth (Measurable) **398**

Date: Started **July 8, 2014** Completed **July 20, 2014**

14. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name **Treasure Valley Drilling** Co. No. **560**

*Principal Driller *Monte Ross* Date **4-3-15**

*Driller _____ Date _____

*Operator II _____ Date _____

Operator I *Pipe Langer* Date **4-3-15**

Signature of Principal Driller and rig operator are required.

RECEIVED

APR 03 2015

WATER RESOURCES
WESTERN REGION

Appendix C
Totalizer Photos



Irrigation Well No. 1 Totalizer (11/17/2017)



Irrigation Well No. 2 Totalizer (11/17/2017)



Irrigation Well No. 3 Totalizer (11/17/2017)



Plant Well #1 (East) Totalizer (12/29/2017)



Plant Well #2 (West) Totalizer (12/29/2017)

Appendix D
Water Level Data

Close

IDAHO DEPARTMENT OF WATER RESOURCES
Water Permit Report

2/5/2017

WATER RIGHT NO. 63-34038

<u>Owner Type</u>	<u>Name and Address</u>
Current Owner	CS PROPERTY DEVELOPMENT LLC PO BOX 27 BOISE, ID 83707 (208)336-2110
Original Owner	J R SIMPLOT COMPANY PO BOX 27 BOISE, ID 83707 (208)336-2110
Security Interest	WELLS FARGO BANK FOOD & AGRIBUSINESS COMMERCIAL BANKING OFFICE 905 S FILLMORE STE 701 MAC T3005-072 AMARILLO, TX 79101 806-371-3769

Priority Date: 06/26/2015
Status: Active

<u>Source</u>	<u>Tributary</u>
GROUND WATER	

<u>Beneficial Use</u>	<u>From</u>	<u>To</u>	<u>Diversion Rate</u>	<u>Volume</u>
IRRIGATION	03/01	11/15	3.2 CFS	
INDUSTRIAL	01/01	12/31	4 CFS	
Total Diversion			4 CFS	

Location of Point(s) of Diversion:

GROUND WATER	SWSE	Sec. 11	Township 01N	Range 01E	ADA County
GROUND WATER	SESE	Sec. 11	Township 01N	Range 01E	ADA County
GROUND WATER	SWNW	Sec. 12	Township 01N	Range 01E	ADA County
GROUND WATER	SENE	Sec. 12	Township 01N	Range 01E	ADA County
GROUND WATER	NWNE	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NWNW	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NESE	Sec. 13	Township 01N	Range 01E	ADA County
GROUND WATER	NENE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWNE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	SWNE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	SENE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NESE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWSE	Sec. 14	Township 01N	Range 01E	ADA County
GROUND WATER	NWSW Lt 6	Sec. 06	Township 01N	Range 02E	ADA County
GROUND WATER	NWSW Lt 6	Sec. 06	Township 01N	Range 02E	ADA County
GROUND WATER	SWSW Lt 7	Sec. 06	Township 01N	Range 02E	ADA County
GROUND WATER	SWSW Lt 7	Sec. 06	Township 01N	Range 02E	ADA County

INDUSTRIAL Use:

Number of other uses: meat process & packing

Place(s) of use:

Place of Use Legal Description: IRRIGATION ADA County

<u>Township</u>	<u>Range</u>	<u>Section</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>	<u>Lot</u>	<u>Tract</u>	<u>Acres</u>
01N	01E	11		SWSE	40		SESE	40						
		12		NENW	40		NWNW	40		SWNW	40		SENE	40
				NESW	40		NWSW	40		SWSW	40		SESW	40
				NWSE	40		SWSE	40		SESE	40			
		13		NENE	40		NWNE	40		SWNE	40		SENE	40
				NENW	40		NWNW	40						
				NESE	40									
		14		NENE	40		NWNE	40		SWNE	40		SENE	40
				SWNW	40		SENE	40						
				NESW	40		NWSW	40		SWSW	40		SESW	40
				NESE	40		NWSE	40		SWSE	40		SESE	40
		23		NENE	40		NWNE	40						
				NENW	40		NWNW	40						
		24		NENW	40		NWNW	40		SWNW	40		SENE	40

Place of Use Legal Description: INDUSTRIAL ADA County

Township	Range	Section	Lot	Tract	Acres	Lot	Tract	Acres	Lot	Tract	Acres	Lot	Tract	Acres
01N	01E	11		SWSE			SESE							
		12		NENW			NWNW			SWNW			SENE	
				NESW			NWSW			SWSW			SESW	
				NWSE			SWSE			SESE				
		13		NENE			NWNE			SWNE			SENE	
				NENW			NWNW			SWNW			SENE	
				NESW			NWSW			SWSW			SESW	
				NESE			SWSE			SESE				
		14		NENE			NWNE			SWNE			SENE	
				NESE			NWSE							
		23		NENE			NWNE							
				NENW			NWNW							
		24		NENW			NWNW			SWNW			SENE	
	02E	6		NESW			SESW							
				NWSE			SWSE							

Total Acres: 1680

Conditions of Approval:

1. 26A Project construction shall commence within one year from the date of permit issuance and shall proceed diligently to completion unless it can be shown to the satisfaction of the Director of the Department of Water Resources that delays were due to circumstances over which the permit holder had no control.
2. Each point of diversion (well) authorized for this right shall include a measuring device or other suitable method to allow measurement of the static water level in the well. Water level measurements shall be made monthly throughout the year from the beginning of the diversion and use of water in connection with this right until notified by the Department. The records shall be made available to the Department upon request.
3. 196 The right holder shall install or construct a straight length of conduit or ditch suitable for installation of a device for measuring the entire flow of water being diverted in connection with this right. If the right holder uses conduit, the straight length of conduit shall be at least fifteen times the diameter of the conduit and shall be above ground or otherwise easily accessible.
4. The right holder shall install a measuring device acceptable to the Department at each point of diversion authorized under this right. The measuring device shall be capable of displaying diversion flow rate and totalized volume measurement. The right holder shall record the flow rate and volume measurements monthly for any calendar year in which water is diverted and used in connection with this right until notified by the Department. The records shall be made available to the Department upon request.

5. 073 Diversion and use of water with a temperature greater than 85 degrees Fahrenheit is not authorized under this right.
6. If the Department determines based on credible evidence, measurement reports, area data or otherwise that diversion and use of ground water under this right is causing material injury to any senior water right(s), the Department may order the diversion reduced, the diversion curtailed, or the right holder to provide adequate mitigation to remedy the injury.
7. Prior to submitting proof of beneficial use, the right holder shall not assign ownership of the permit to another individual, corporation, partnership, or association without prior approval of the Department.
8. Proof of beneficial use may not be submitted until one month prior to the deadline to submit proof of beneficial use set forth in these conditions; provided, however, if less than four (4) years of ground water monitoring data have been collected while beneficial use authorized under this permit has occurred, then an extension of time for up to five additional years shall be requested by the permit holder. The permit holder shall submit a report from a qualified professional engineer, hydrologist, or hydrogeologist summarizing hydrogeologic data collected to fulfill the conditions of approval of this permit. Submittal of a proof of beneficial use statement without the required data and report will not be accepted by the Department and may result in lapse of the permit.
9. 046 Right holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code and applicable Well Construction Rules of the Department.
10. R65 This right when combined with all other rights shall provide no more than 0.02 cfs per acre nor more than 4.5 afa per acre at the field headgate for irrigation of the place of use.
11. 121 The Director retains jurisdiction to require the right holder to provide purchased or leased natural flow or stored water to offset depletion of Lower Snake River flows if needed for salmon migration purposes. The amount of water required to be released into the Snake River or a tributary, if needed for this purpose, will be determined by the Director based upon the reduction in flow caused by the use of water pursuant to this permit.
12. 069 Failure of the right holder to comply with any condition of approval is cause for the Director to cancel this permit.

Dates:

Proof Due Date: 11/01/2020

Proof Made Date:

Approved Date: 10/26/2015

Moratorium Expiration Date:

Enlargement Use Priority Date:

Enlargement Statute Priority Date:

Application Received Date: 09/07/2016

Protest Deadline Date: 01/02/2017

Number of Protests: 0

Field Exam Date::

Date Sent to State Off:

Date Received at State Off:

Other Information:

State or Federal:

Owner Name Connector:

Water District Number:

Generic Max Rate per Acre: 0.02

Generic Max Volume per Acre: 4.5

Swan Falls Trust or Nontrust:

Swan Falls Dismissed:

DLE Act Number:

Cary Act Number:

Mitigation Plan: False

Close

Appendix B
Well Driller's Reports for Production and
Monitoring Wells

Plant Well 1

RECEIVED

Form 238-7
6/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

OCT 06 2015

WATER RESOURCES
WESTERN REGION

CP3

1. WELL TAG NO. D 0069003

Drilling Permit No. 9148708 - 874825

Water right or injection well # _____

2. OWNER: JR Simplot Co.

Name _____

Address P.O. Box 27

City Boise State Idaho Zip 83707

3. WELL LOCATION:

Twp 1 North or South Rge 2 East or West

Sec 6 NW 1/4 SW 1/4 _____ 1/4 _____ 1/4

Gov't Lot _____ County ADA

Lat. 43 ° 26.841 (Deg and Decimal minutes)

Long. 116 ° 16.380 (Deg and Decimal minutes)

Address of Well Site S. Cole Rd. 1/4 mile North of Barker

City Kuna

Lot _____ Blk. _____ Sub. Name _____

4. USE:

Domestic Municipal Monitor Irrigation Thermal Injection

Other _____

5. TYPE OF WORK:

New well Replacement well Modify existing well

Abandonment Other _____

6. DRILL METHOD:

Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
Neat cement	188ft	0	9 yd3	pumped
Neat cement	315ft	0	11 yd3	pumped

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
20"	0	188	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
14"	+2	395	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:

Perforations Y N Method _____

Manufactured screen Y N Type Joston

Method of installation set in

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
395	455	30	60ft	14"	ss	.375

Length of Headpipe _____ Length of Tailpipe _____

Packer Y N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method
6-9	315	455	9850lbs	trimmie

11. FLOWING ARTESIAN:

Flowing Artesian? Y N Artesian Pressure (PSIG) _____

Describe control device plat

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 315 Static water level (ft) 294

Water temp (°F) 83 Bottom hole temp (°F) 83

Describe access port _____

Well test: _____ Test method: _____

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Basin	Air	Flowing artesian
43.1	1520	7.7 hrs	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
24	0	2	top soil		
24	2	8	sandy dirt and gravel		
24	8	30	hard black lava		
24	30	38	broken soft black lava		
24	38	44	hard black lava		
24	44	48	soft red lava		
24	48	55	hard black lava		
24	55	77	soft black lava		
24	77	95	hard black lava		
24	95	105	soft black lava		
24	105	135	hard black lava		
24	135	145	soft black lava		
24	145	155	red cinders		
24	155	162	hard black lava		
24	162	177	hard black lava		
19	177	312	large gravel and sand		
19	312	315	rock and clay		
19	315	320	sand and gravel		
19	320	325	rock and clay		
19	325	402	sand and gravel		
19	402	425	white clay		
19	425	448	sand and gravel		
19	448	460	brown clay with gravel		
19	460	465	sand and gravel		
19	465	471	brown clay and little rock		
19	471	477	sand and gravel		
19	477	490	brown clay and rock		
19	490	523	big gravel and sand		
19	523	531	sand and gravel		
19	531	543	gravel and sand with clay		
19	543	555	sandstone		
19	555	580	gravel and sand		

Completed Depth (Measurable): 455

Date Started: 6/1/2015 Date Completed: 9/16/2015

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling Co No 560

*Principal Driller: [Signature] Date 9-22-15

*Driller _____ Date _____

*Operator II _____ Date _____

Operator I _____ Date _____

*Signature of Principal Driller and rig operator are required

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0069003

Drilling Permit No _____
Water right or injection well # _____

2. OWNER: J R Simplot Co.

Name _____
Address P.O. Box 27
City Boise State ID Zip 83707

3. WELL LOCATION:
Twp. 1 North or South Rge. 2 East or West
Sec. 6 NW 1/4 SW 1/4 _____ 1/4

Gov't Lot _____ County Ada

Lat. _____ (Deg. and Decimal minutes)

Long. _____ (Deg. and Decimal minutes)

Address of Well Site S. Cole Rd. 1/4 mile north of Barker

City Kuna

Lot _____ Blk. _____ Sub. Name _____

4. USE:
 Domestic Municipal Monitor Irrigation Thermal Injection
 Other

5. TYPE OF WORK:
 New well Replacement well Modify existing well
 Abandonment Other

6. DRILL METHOD:
 Air Rotary Mud Rotary Cable Other

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
Neat cement	188	0	13 Yards	Pumped
Neat cement	315	0	10 1/2 Yards	Pumped

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
20"	0	188	.375	Steel Casing	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
14"	42	395	.375	Steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:
Perforations Y N Method _____
Manufactured screen Y N Type Alloy Screen
Method of installation Set in

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
395	455		60'		Stainless	.375

Length of Headpipe _____ Length of Tailpipe _____

Packer Y N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method
6-9	315	455	9,850 lbs	Tremie

11. FLOWING ARTESIAN:
Flowing Artesian? Y N Artesian Pressure (PSIG) _____
Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:
Depth first water encountered (ft) 315 Static water level (ft) 294
Water temp (°F) 83 Bottom hole temp (°F) 83

Describe access port _____

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
33	200	60	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
24"	0	2	TOP SOIL		
"	2	8	Sandy dirt / Gravel		
14"	8	30	Hard black lava		
	30	38	Broken / soft Black lava		
	38	44	Hard black lava		
	44	48	soft + red lava		
	48	55	Hard black lava		
	55	77	Soft black lava		
	77	95	Hard black lava		
	95	105	Soft black lava		
	105	135	Hard black lava		
	135	145	Soft black lava		
	145	155	red cinders		
	155	160	Hard black lava		
	160	177	Hard black lava		
19"	177	312	Big Gravels + Sand		
"	312	315	Rock + Clay		
↓	315	320	Sand + Gravel		
	320	325	rock + clay		
	325	402	Sand + Gravel		
	402	425	White Clay		
	425	448	Sand + Gravel		
	448	460	brn clay with gravel		
	460	465	Sand + Gravel		
	465	471	Brn clay + little rock		
	471	477	Sand + Gravel		
	477	490	Brn clay + rock		
	490	523	Big Gravels + Sand		
	523	531	Sand + Gravel		
	531	543	Gravels and little clay		
	543	555	Sandstone		
	555	560	Gravel + Sand		

Completed Depth (Measurable): 455
Date Started: 7-1-15 Date Completed: 8-30-15

14. DRILLER'S CERTIFICATION:
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.
#560
Company Name Treasure Valley Drilling and Pump
*Principal Driller Shawn Mikela Date 9-28-15
*Driller Shawn Mikela Date 9-28-15
*Operator II _____ Date _____
Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required

RECEIVED
OCT 02 2015
WATER RESOURCES
WESTERN REGION

Plant Well 2

Form 238-7
8/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0070211
 Drilling Permit No 970455-876512
 Water right or injection well # 63-33207
 2. OWNER: JR Simplot Company

Name _____
 Address PO Box 27
 City Boise State Idaho Zip 83707

3. WELL LOCATION:
 Twp 1 North or South Rge 2 East or West
 Sec 6 1/4 SW 1/4 SW 1/4

Gov't Lot 7 County _____
 Lat. 43 26.845 (Deg and Decimal minutes)
 Long -116 16.419 (Deg and Decimal minutes)

Address of Well Site 150' East of south cole rd
1075' North of Barker Rd City Near Kuna
(Give at least name of road - Distance to Road or Landmark)
 Lot. _____ Blk. _____ Sub. Name _____

4. USE:
 Domestic Municipal Monitor Irrigation Thermal Injection
 Other Industrial

5. TYPE OF WORK:
 New well Replacement well Modify existing well
 Abandonment Other _____

6. DRILL METHOD:
 Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
Neat cement	188	0	9yd3	pumped
Neat cement	315	0	11yd3	pumped

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
26	0	11	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
20	+1	176	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
14	+1	395	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:
 Perforations Y N Method _____
 Manufactured screen Y N Type _____
 Method of installation _____

From (ft)	To (ft)	Slot size	Numberft	Diameter (nominal)	Material	Gauge or Schedule
395	455	40	60	14	SS	.375

Length of Headpipe _____ Length of Tailpipe _____
 Packer Y N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method
silica sand	320	455	8400lbs	trimmie

11. FLOWING ARTESIAN:
 Flowing Artesian? Y N Artesian Pressure (PSIG) _____
 Describe control device plait

12. STATIC WATER LEVEL and WELL TESTS:
 Depth first water encountered (ft) 290 Static water level (ft) 289
 Water temp. (°F) 82 Bottom hole temp. (°F) 82
 Describe access port _____

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
338	2190	4hrs	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
32	0	1	top soil		X
32	1	11	cleachy basalt		
26	11	93	weathered basalt		
26	93	97	red cinders		
26	97	124	black basalt		
26	124	128	red cinders		
26	128	176	hard black basalt		
20	176	186	sand and gravel		
20	186	211	gravel and basalt boulders		
20	211	255	sand and gravel boulders		
20	255	266	cemented gravel		
20	266	290	sand and gravel		X
20	290	367	clay		
20	367	376	sand		
20	376	460	pea gravel and silty sand		

Completed Depth (Measurable) 455
 Date Started 9/10/2015 Date Completed 9/30/2015

14. DRILLER'S CERTIFICATION:
 I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling Co. No 560
 *Principal Driller [Signature] Date 9-30-15
 *Driller _____ Date _____
 *Operator II _____ Date _____
 Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.

Drill Water Supply Well (Monitoring)

Form 238-7
6/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0066263

Drilling Permit No. _____
Water right or injection well # _____

2. OWNER

Name Ray Montierth
Address 825 Hartland Dr
City Nampa State ID Zip 83686

3. WELL LOCATION:

Twp. 1 North or South Rge. 1 East or West
Sec. 14 1/4 SE 1/4 NE 1/4
10 acres 40 acres 160 acres

Gov't Lot _____ County ADA

Lat. 34 ° 25.612 (Deg. and Decimal minutes)
Long. 116 ° 17.845 (Deg. and Decimal minutes)

Address of Well Site Cross tracks on Cole heading south first right 1 mile left 1/2 mile left 1/4 mile City Kuna

Lot _____ Blk. _____ Sub. Name _____

4. USE:

Domestic Municipal Monitor Irrigation Thermal Injection
 Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

New Well Replacement well Modify existing well
 Abandonment Other _____

6. DRILL METHOD:

Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
Bentonite	0	38	950lbs	Pour

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Linear	Threaded	Welded
6	+2	38	.230	Steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:

Perforations Y N Method _____
Manufactured screen Y N Type _____
Method of installation _____

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule

Length of Headpipe _____ Length of Tailpipe _____

Pecker Y N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method
na	na	na	na na	na

11. FLOWING ARTESIAN:

Flowing Artesian? Y N Artesian Pressure (PSIG) _____
Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 265 Static water level (ft) 230
Water temp. (°F) 56 Bottom hole temp. (°F) _____
Describe access port Cap

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Test method:			
			Pump	Bailer	Air	Flowing artesian
<u>35</u>	<u>20</u>	<u>1HR</u>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
10	0	2	Top Soil		X
10	2	8	Sandy Clay		X
10	8	15	Brown Clay		X
10	15	34	Brown Sandy Clay		X
10	34	38	Broken up Lava		X
6	38	54	Lava		X
6	54	57	Red Lava		X
6	57	81	Black Lava		X
6	81	83	Red Lava		X
6	83	101	Black Lava		X
6	101	104	Brown Lava		X
6	104	232	Brown Lava		X
6	232	245	Fractured Lava		X
6	245	258	Lava		X
6	258	265	Brown Lava		X
6	265	270	Coarse Sand	X	
6	270	280	Lava		X
6	280		Gravel	X	

Completed Depth (Measurable) 270
Date: Started 04/17/2014 Completed 4/20/2014

14. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling Co. No. 560

*Principal Driller _____ Date _____

*Driller _____ Date _____

*Operator II _____ Date _____

Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.

Irrigation Well 1

Form 238-7
6/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0066300

Drilling Permit No. 965586-871645
Water right or injection well # 63-32680

2. OWNER

Name Ray Montierth
Address 825 Heartland Dr.
City Nampa State Id Zip 83686

3. WELL LOCATION:

Twp. 1 North or South Rge. 1 East or West
Sec. 14 sw 1/4 ne 1/4 ne 1/4
10 acres 40 acres 160 acres
Gov't Lot _____ County Ada

Lat. 43° 25.967 (Deg. and Decimal minutes)
Long. 116° 16.803 (Deg. and Decimal minutes)
Address of Well Site 1 mi. w. of S. Cole Rd 1 mi. S. of railroad ROW
City Kuna

(Give at least name of road + Distance to Road or Landmark)

Lot _____ Blk. _____ Sub. Name _____

4. USE:

Domestic Municipal Monitor Irrigation Thermal Injection
 Other

5. TYPE OF WORK check all that apply (Replacement etc.)

New Well Replacement well Modify existing well
 Abandonment Other

6. DRILL METHOD:

Air Rotary Mud Rotary Cable Other

7. SEALING PROCEDURES

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
3/4 bentonite	0	38	23000 lbs	pour
cement	150	300	43 ft 3	trimmed

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
26	0	38	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
20	0	149	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
16	1	150	.250	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:

Perforations Y N Method _____
Manufactured screen Y N Type johnson
Method of installation set in

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
330	430	.40	100	16	ss	.375
440	540	.40	100	16	ss	.375

Length of Headpipe na Length of Tailpipe _____

Packer Y N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method
silico sand	80	540	23000 lbs	pour

11. FLOWING ARTESIAN:

Flowing Artesian? Y N Artesian Pressure (PSIG) _____
Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) _____ Static water level (ft) _____
Water temp. (°F) 70 Bottom hole temp. (°F) 70
Describe access port flat plat

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
23	3300	20 hr	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Test method:

Water Quality test or comments:

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
30	0	2	top soil		x
30	2	8	sandy clay		x
30	8	17	brown clay		x
30	17	35	brown sandy clay		x
30	35	38	broken up lava		x
25	38	73	lava		x
25	73	85	brown lava		x
25	85	130	lava		x
25	130	140	brown lava		x
25	140	153	fractured lava		x
25	153	175	red lava		x
25	175	186	brown lava		x
25	186	200	fractured lava		x
25	200	255	lava		x
25	255	266	brown lava		x
25	266	270	sand	x	
25	270	273	brown clay		x
25	273	278	lava		x
25	278	284	gravel	x	
20	284	291	corse sand	x	
20	291	305	brown clay		x
20	305	317	brown sand	x	
20	317	335	brown clay		x
20	335	356	gravel	x	
20	356	360	brown clay		x
20	360	368	corse sand	x	
20	368	373	medium sand	x	
20	373	378	brown clay		x
20	378	381	brown sand	x	
20	381	389	gravel	x	
20	389	410	corse sand and gravel	x	
20	410	430	medium sand	x	

Completed Depth (Measurable) _____
Date: Started 4-16-14 Completed _____

14. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling Co. No. 560

*Principal Driller Monte Post Date 6-27-14

*Driller [Signature] Date 7-31-14

*Operator II _____ Date _____

Operator I Jeremy Bullock Date 6-27-14

*Signature of Principal Driller and rig operator are required.

JUL 03 2014

63

Irrigation Well 2

10f2

Form 238-7
6/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0067448

Drilling Permit No. 967343-873402

Water right or injection well # _____

2. OWNER: _____

Name Ray Montierth

Address 825 Hartland

City Nampa State ID Zip 83686

3. WELL LOCATION:

Twp. 1 North or South Rge. 1 East or West

Sec. 13 1/4 1/4 1/4 1/4

Gov't Lot _____ County ADA

Lat. 43 25.608 (Deg. and Decimal minutes)

Long. 116 17.611 (Deg. and Decimal minutes)

Address of Well Site S.Cole

City Kuna

(Give at least name of road - Distance to Road or Landmark)

Lot. _____ Blk. _____ Sub. Name _____

4. USE:

Domestic Municipal Monitor Irrigation Thermal Injection

Other _____

5. TYPE OF WORK:

New well Replacement well Modify existing well

Abandonment Other _____

6. DRILL METHOD:

Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
3/4 bentonite	0	39	4000 lbs	pour
concrete	270	300	3 1/2 yd	pumped

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
26	0	39	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
20	1	284	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
16	270	350	.250	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
16	510	535	.250	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:

Perforations Y N Method _____

Manufactured screen Y N Type Alloy

Method of installation set in

From (ft)	To (ft)	Slot size	Number/rft	Diameter (nominal)	Material	Gauge or Schedule
350	510	.35	160	16	ss	.98
535	575	.35	40	16	ss	.98

Length of Headpipe 80 Length of Tailpipe _____

Packer Y N Type double wing k-packer

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method
6/9 silica sand	305	575	16500 lbs	pour

11. FLOWING ARTESIAN:

Flowing Artesian? Y N Artesian Pressure (PSIG) _____

Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 293 Static water level (ft) 236

Water temp. (°F) 70 Bottom hole temp. (°F) 70

Describe access port flat plate

Well test:	Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Test method:			
				Pump	Bailer	Air	Flowing artesian
	22	2980	6 hr	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
30	0	3	top soil		x
30	3	27	sandy clay		x
30	27	35	coarse sand		x
30	35	39	red clay		x
24	39	65	hard lava		x
24	65	69	red cinders		x
24	69	82	gray lava		x
24	82	87	red broken up lava		x
24	87	99	black lava		x
24	99	101	broken up lava		x
24	101	107	gray lava		x
24	107	111	red lava		x
24	111	122	gray lava		x
24	122	151	gray broken up lava		x
24	151	158	black broken up lava		x
24	158	170	brown and red cinders		x
24	170	223	gray lava		x
24	223	230	broken up lava		x
24	230	258	black lava		x
24	258	267	coarse sand		x
24	267	286	brown lava		x
24	286	293	broken up lava		x
24	293	305	red cinders	x	
20	305	320	brown clay and red cinders		x
20	320	335	brown clay		x
20	335	370	gravel	x	
20	370	373	brown clay		x
20	373	429	coarse sand and gravel	x	
20	429	431	brown clay		x
20	431	435	coarse sand	x	
20	435	438	brown clay		x
20	438	445	gravel	x	

RECEIVED
JAN 05 2015

WATER RESOURCES
WESTERN REGION

Completed Depth (Measurable): 575

Date Started 9-14-14 Date Completed: 11-21-14

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling Co. No. 560

*Principal Driller Monte Post Date 11-30-14

*Driller Jeremy Bullak Date 11-30-14

*Operator II _____ Date _____

Operator I _____ Date _____

*Signature of Principal Driller and rig operator are required

63

2 of 2

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0067448

Drilling Permit No. 9167343-873402
Water right or injection well # _____

2. OWNER:

Name Ray Montierth
Address 825 Hartland
City Nampa State Id Zip 83686

3. WELL LOCATION:

Twp. 1 North or South Rge. 1 East or West
Sec. 13 1/4 NW 1/4 NW 1/4

Gov't Lot _____ County ada
Lat. 43 ° 25.608 (Deg. and Decimal minutes)
Long. 116 ° 17.611 (Deg. and Decimal minutes)
Address of Well Site S.Cole

(Give at least name of road - Distance to Road or Landmark)
City Kuna
Lot _____ Blk. _____ Sub. Name _____

4. USE:

Domestic Municipal Monitor Irrigation Thermal Injection
 Other _____

5. TYPE OF WORK:

New well Replacement well Modify existing well
 Abandonment Other _____

6. DRILL METHOD:

Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
3/4 bentonite	270	250	750 lbs	pour

8. CASING/LINER:

Diameter (in/ft)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:

Perforations Y N Method _____

Manufactured screen Y N Type _____

Method of installation _____

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule

Length of Headpipe _____ Length of Tailpipe _____

Packer Y N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method

11. FLOWING ARTESIAN:

Flowing Artesian? Y N Artesian Pressure (PSIG) _____

Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 293 Static water level (ft) 236
Water temp. (°F) 70 Bottom hole temp. (°F) 70
Describe access port flat plate

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)
22	2980	6 hr

Test method:

Pump	Bailer	Air	Flowing artesian
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
20	445	447	brown clay		x
20	447	496	gravel	x	
20	496	511	brown clay		x
20	511	513	gravel	x	
20	513	516	brown clay		x
20	516	519	gravel	x	
20	519	536	brown clay		x
20	536	540	gravel	x	
20	540	547	brown clay		x
20	547	549	gravel	x	
20	549	551	brown clay		x
20	551	569	gravel	x	
20	569	575	brown clay		x

RECEIVED

JAN 05 2015

WATER RESOURCES
WESTERN REGION

Completed Depth (Measurable) 575

Date Started: 9-14-14

Date Completed: 11-21-14

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling Co. No. 560

*Principal Driller Monte Post Date 11-30-14

*Driller Jeremy Bullock Date 11-30-14

*Operator II _____ Date _____

Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.

Irrigation Well 3

Form 238-7
6/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D00071844

Drilling Permit No. _____
Water right or injection well # 63-33207-3403863-32680

2. OWNER:

Name JR Simplot Company
Address PO box 27
City Boise State Idaho Zip 83707

3. WELL LOCATION:

Twp. 1 North or South Rge. 1 East or West
Sec. 14 10 acres 1/4 40 acres NE 1/4 SE 1/4

Gov't Lot _____ County Ada
Lat. 43 25.154 (Deg. and Decimal minutes)
Long 116 17.628 (Deg. and Decimal minutes)
Address of Well Site West of S. Cole rd. south of train tracks
City Kuna

(Give at least name of road + Distance to Road or Landmark)

Lot _____ Blk _____ Sub Name _____

4. USE:

Domestic Municipal Monitor Irrigation Thermal Injection
 Other _____

5. TYPE OF WORK:

New well Replacement well Modify existing well
 Abandonment Other _____

6. DRILL METHOD:

Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
3/8 chip	0	53	15800	overbore
3/8 chip	280	265	500lbs	overbore

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
26	0	53	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
20	+1	280	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
16	257	345	.375	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) _____

9. PERFORATIONS/SCREENS:

Perforations Y N Method _____

Manufactured screen Y N Type Johnson S.S.

Method of installation set in

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
545	345	.040		16"	S.S.	.250

Length of Headpipe _____ Length of Tailpipe _____

Packer Y N Type Double k 257-255

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method
6-9 silica	545	273	8700lbs	overbore

11. FLOWING ARTESIAN:

Flowing Artesian? Y N Artesian Pressure (PSIG) _____

Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 280 Static water level (ft) 270

Water temp. (°F) 74 Bottom hole temp. (°F) _____

Describe access port flat plate

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Sailer	Air	Flowing artesian
60'	3425		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Test method:

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
36	0	4	top soil		
36	4	12	sand		
36	42	53	brown clay		
25	53	78	black basalt		
25	78	86	red cinder		
25	86	192	black basalt		
25	192	204	brown clay		
25	204	227	sand and brown clay		
25	227	259	fractured basalt		
25	259	271	brown sand		
25	271	280	basalt		X
19	280	303	basalt		X
19	303	309	fractured basalt		X
19	309	318	baked brown clay		
19	318	324	sticky brown clay		
19	324	326	brown silt		X
19	326	329	sticky brown clay		
19	329	334	fine brown sand and silt		
19	334	347	sticky brown clay		
19	347	349	fine brown sand		X
19	349	357	sticky brown clay		
19	357	368	cemented sand		X
19	368	370	sticky brown clay		
19	370	394	brown sand and pea gravel		X
19	394	417	sticky brown clay		
19	417	436	brown sand		X
19	436	444	sticky brown clay		
19	444	529	brown sand with small clay seams		
19	529	555	sticky tan clay		

Completed Depth (Measurable) 545
Date Started 5-15-16 Date Completed 6-30-16

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed

Company Name Treasure Valley Drilling Co. No 560

*Principal Driller _____ Date Jul 26, 2016

*Driller [Signature] Date Jul 26, 2016

*Operator II [Signature] Date Jul 27, 2016

Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required

Monitoring Well

Form 238-7
6/07

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0066301

Drilling Permit No. 965601-871660

Water right or injection well # _____

2. OWNER

Name Ray Montierth

Address 825 Hearland Dr

City Nampa State Id Zip 83686

3. WELL LOCATION:

Twp. 1 North or South Rge. 1 East or West

Sec. 12 NE 1/4 SW 1/4 SE 1/4
0 acres 40 acres 160 acres

Gov't Lot _____ County Ada

Lat. 43° 25.967 (Deg. and Decimal minutes)

Long 116° 16.803 (Deg. and Decimal minutes)

Address of Well Site 1/4 mi.w of Cole Rd 1/4 mi.s of railroad ROW

City Kuna

Lot _____ Blk. _____ Sub. Name _____

4. USE:

Domestic Municipal Monitor Irrigation Thermal Injection
 Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

New Well Replacement well Modify existing well
 Abandonment Other _____

6. DRILL METHOD:

Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
gran/bentoni	0	80	3600/lbs	pour

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
10	+3	4	.250	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
6	+2	378	.250	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
5	368	388	.250	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) 376

9. PERFORATIONS/SCREENS:

Perforations Y N Method _____

Manufactured screen Y N Type johnson

Method of installation set in

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
388	398	.16	10 ft	5	ss	.250

Length of Headpipe 20 Length of Tailpipe _____

Packer Y N Type neoprene

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method

11. FLOWING ARTESIAN:

Flowing Artesian? Y N Artesian Pressure (PSIG) _____

Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 280 Static water level (ft) 268

Water temp. (°F) 72 Bottom hole temp. (°F) _____

Describe access port cap

Well test:	Test method:
Drawdown (feet)	Pump <input type="checkbox"/> Bailer <input type="checkbox"/> Air <input checked="" type="checkbox"/> Flowing artesian <input type="checkbox"/>
Discharge or yield (gpm)	
Test duration (minutes)	
<u>122</u>	
<u>40</u>	
<u>2hr</u>	

Water Quality test or comments: tested great, no smell, no sand

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
10	0	2	top soil		X
10	2	9	brokin up lava		X
10	9	37	black lava		X
10	37	40	soft		X
8	39	46	brown lava		X
8	46	68	black lava		X
8	68	70	brown lava		X
8	70	84	black lava		X
8	84	86	fractured lava		X
8	86	88	crack		X
8	88	127	lava		X
8	127	131	soft lava		X
8	131	162	lava		X
8	162	170	soft lava		X
8	170	230	lava		X
8	230	238	sinders		X
6	238	262	gravel	X	
6	262	268	clay		X
6	268	340	gravel sand	X	
6	340	343	clay		X
6	343	347	gravel	X	
6	347	351	clay		X
6	351	356	sand	X	
6	356	360	clay		X
6	360	367	sand	X	
6	367	370	clay		X
6	370	375	sand	X	
6	375	378	clay		X
6	378	385	gravel	X	
6	385	387	clay		X
6	387	404	corse sand	X	

Completed Depth (Measurable) 398

Date: Started July 8, 2014 Completed July 20, 2014

14. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Treasure Valley Drilling Co. No. 560

*Principal Driller Monte Post Date 4-3-15

*Driller _____ Date _____

*Operator II _____ Date _____

Operator I Pete L. Anderson Date 4-3-15

Signature of Principal Driller and rig operator are required.

RECEIVED

APR 03 2015

WATER RESOURCES
WESTERN REGION

Appendix C
Totalizer Photos



Irrigation Well No. 1 Totalizer (11/17/2017)



Irrigation Well No. 2 Totalizer (11/17/2017)



Irrigation Well No. 3 Totalizer (11/17/2017)



Plant Well #1 (East) Totalizer (12/29/2017)



Plant Well #2 (West) Totalizer (12/29/2017)

Appendix D
Water Level Data

APPENDIX D
SUBMITTED AS A DISC

PLEASE SEE PC DOCS FOR THE EXCEL FILE