



State of Idaho

DEPARTMENT OF WATER RESOURCES

Northern Region • 7600 N. Mineral Drive, Suite 100 • Coeur d'Alene, Idaho 83815-7763
Phone: (208) 762-2800 • Fax: (208) 762-2819 • Website: www.idwr.idaho.gov

C.L. "BUTCH" OTTER
Governor

GARY SPACKMAN
Director

September 11, 2017

KOOTENAI ENVIRONMENTAL
ALLIANCE
PO BOX 1598
COEUR D ALENE, ID 83816-1598

RE: Conditional Withdrawal of Protest against Application for Permit No. 95-17320

Dear Protestant:

The Department of Water Resources acknowledges receipt of your withdrawal of protest against the above referenced application with the following conditions:

1. The volume of all water pumped for system use will be measured either by the installation of an Elapsed Time Hour Meter (ETHM), a totalizing water meter or a sprinkler system that by design will not allow more than the approved volume of water at full use.
2. Watering shall be limited to between hours of 8:00 pm and 6:00 am.
3. An automated sprinkler system utilizing smart sprinkler technology consisting of, at a minimum rain sensors, will be installed.
4. The daily volume pumped will not exceed the lessor of 2.5 acres or the number of acres eventually licensed by IDWR times 0.02 cfs.
5. The annual volume of water pumped shall not exceed 7.5AF (3.0 AF/Acre x 2.5 acres).

The application does not have any remaining protests; therefore, the department will take the steps necessary to bring the application to a final resolution.

Please contact this office if you have any questions regarding this procedure. Information about water rights and other matters administered by this agency is also available on the Internet at www.idwr.idaho.gov.

Sincerely,

Douglas Jones, P.E.
Northern Regional Manager



State of Idaho

DEPARTMENT OF WATER RESOURCES

Northern Region • 7600 N. Mineral Drive, Suite 100 • Coeur d'Alene, Idaho 83815-7763
Phone: (208) 762-2800 • Fax: (208) 762-2819 • Website: www.idwr.idaho.gov

C.L. "BUTCH" OTTER
Governor

GARY SPACKMAN

Director

September 11, 2017

JEFFEREY FAUTT
55 KEMLINE CT
ALAMO, CA 94507

RE: Withdrawal of Protest against Application for Permit No. 95-17320

Dear Applicant:

The Department of Water Resources has received withdrawal of protest against the above referenced application. Withdrawals have been received from the following protestants:

KOOTENAI ENVIRONMENTAL ALLIANCE AS FOLLOWS:

1. The volume of all water pumped for system use will be measured either by the installation of an Elapsed Time Hour Meter (ETHM), a totalizing water meter or a sprinkler system that by design will not allow more than the approved volume of water at full use.
2. Watering shall be limited to between hours of 8:00 pm and 6:00 am.
3. An automated sprinkler system utilizing smart sprinkler technology consisting of, at a minimum rain sensors, will be installed.
4. The daily volume pumped will not exceed the lessor of 2.5 acres or the number of acres eventually licensed by IDWR times 0.02 cfs.
5. The annual volume of water pumped shall not exceed 7.5AF (3.0 AF/Acre x 2.5 acres).

The application does not have any remaining protests; therefore, the department will take the steps necessary to bring the application to a final resolution.

Please contact this office if you have any questions regarding this procedure. Information about water rights and other matters administered by this agency is also available on the Internet at www.idwr.idaho.gov.

Sincerely,

Douglas Jones
Northern Regional Manager

Cc: UNITED CROWN PUMP AND DRILLING
C/O RICH AGUEROS
3125 W HAYDEN AVE
HAYDEN, ID 83835

RECEIVED

AUG 15 2017

IDWR / NORTH

**An Agreement Between the Kootenai Environmental Alliance
and Jefferey Fautt to Resolve the Protest of Application for
Permit 95-17320**

In consideration of the agreement on the part of Jefferey Fautt to the following stipulations, the Kootenai Environmental Alliance hereby withdraws its protest against the approval of Application for Permit No. 95-17320.

1. The volume of all water pumped for system use will be measured either by the installation of an Elapsed Time Hour Meter (ETHM) , a totalizing water meter or a sprinkler system that by design will not allow more than the approved volume of water at full use.
2. Watering shall be limited to between hours of 8:00PM and 6:00AM.
3. An automated sprinkler system utilizing smart sprinkler technology consisting of, at a minimum rain sensors, will be installed.
4. The daily volume pumped will not exceed the lesser of 2.5 acres or the number of acres eventually licensed by IDWR times 0.02 cfs.
5. The annual volume of water pumped shall not exceed 7.5AF (3.0AF/Acre X 2.5acres).

Signed,

Sharon Boley for

Kootenai Environmental Alliance

Bob Haynes for

Jefferey Fautt

~~September 2015~~

SCANNED
AUG 15 2017