



RECEIVED

NOV 14 2016

DEPARTMENT OF
WATER RESOURCES

November 2, 2016

To: Official Mailing List Recipient

Subject: PacifiCorp Facility, EPA ID No. IDD000602631

HWMF / RCRA Part B Class 1 Modification Number 4

This letter is to inform you that PacifiCorp has submitted a Class 1 Permit Modification to the Idaho Department of Environmental Quality (IDEQ). The submittal was made in accordance with the requirements of IDAPA 58.01.05.012 [40 CFR Part 270.42] on October 12, 2016. The purpose of this modification is to replace a weir box and galvanized piping involved in the groundwater collection and treatment systems. Replacement of galvanized metal components is being implemented to help reduce zinc concentrations detected in the plant effluent.

If you have questions regarding this Permit Modification, please feel free to contact me at (801) 220-2989, or Kim Custer of the IDEQ at (208) 373-0502. No public hearing or comment period is required for Class 1 Permit Modifications. However, any person may request that the Director review a Class 1 Permit Modification. If you have any questions regarding this procedure, please contact the IDEQ.

If you are no longer interested in receiving these notices, or your address information has changed, please inform Kim Custer of the IDEQ by phone at the number listed above or by mail at 1410 North Hilton, Boise, Idaho 83706.

I certify under penalty of law that this permit modification was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the-system, or those persons directly responsible for gathering the information, the information submitted is, to be the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

Jeff Tucker P.E.
Principal Engineer