

**STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES**

**TRANSFER OF WATER RIGHT
TRANSFER NO. 78371**

This is to certify that: **THE TERTELING CO INC**
3858 N GARDEN CENTER WAY STE 300
BOISE, ID 83703

has requested a change to the water right(s) listed below. This change in water right(s) is authorized pursuant to the provisions of Section 42-222, Idaho Code. A summary of the changes is also listed below. The authorized change for each affected water right, including conditions of approval, is shown on the following pages of this document.

Summary of Water Rights Before the Proposed Changes

<u>Water Right</u>	<u>Origin/Basis</u>	<u>Priority Date</u>	<u>Diversion Rate</u>	<u>Diversion Volume</u>	<u>Acre Limit</u>	<u>Total Acres</u>	<u>Source</u>
63-12	WR/DECREED	7/1/1921	0.140 cfs	101.4 af	6.0	15.0	GROUND WATER
63-13	WR/DECREED	7/1/1922	0.660 cfs	400.0 af	6.0	15.0	GROUND WATER
63-15	WR/DECREED	3/23/1927	0.800 cfs	400.0 af	6.0	15.0	GROUND WATER

Purpose of Transfer (Changes Proposed)

<u>Current Number</u>	<u>Split</u>	<u>POD</u>	<u>POU</u>	<u>Add POD</u>	<u>Period of Use</u>	<u>Nature of Use</u>
63-12	NO	NO	NO	YES	NO	NO
63-13	NO	NO	NO	YES	NO	NO
63-15	NO	NO	NO	YES	NO	NO

Summary Of Water Rights After the Approved Change

<u>Existing Right</u>	<u>New No. (Changed Portion)</u>	<u>Transfer Rate</u>	<u>Transfer Volume</u>	<u>Acre Limit</u>	<u>Total Acres</u>	<u>New No. (remaining portion)</u>	<u>Remaining Rate</u>	<u>Remaining Volume</u>	<u>Remaining Acre Limit</u>	<u>Remaining Total Acres</u>
63-12	63-12	0.140 cfs	101.4 af	6.0	15.0	N/A	N/A	N/A	N/A	N/A
63-13	63-13	0.660 cfs	400.0 af	6.0	15.0	N/A	N/A	N/A	N/A	N/A
63-15	63-15	0.800 cfs	400.0 af	6.0	15.0	N/A	N/A	N/A	N/A	N/A
COMBINED TOTALS		0.860 cfs	400.0 af	6.0	15.0		N/A	N/A	N/A	N/A

This water right(s) is subject to all prior water rights and shall be administered in accordance with Idaho law and applicable rules of the Department of Water Resources. Detailed Water Right Description(s) attached.

Dated this 30th day of September, 2016.


PAMELA S. SKAGGS, Water Rights Supervisor

SUPPORT DATA

IN FILE # 63-12

Transfer No. 78371

WATER RIGHT NO. 63-12**As Modified by Transfer No. 78371**

In accordance with the approval of Transfer No. 78371, Water Right No. 63-12 is now described as follows:

Right Holder: THE TERTELING CO INC
3858 N GARDEN CENTER WAY STE 300
BOISE, ID 83703

Priority Date: 7/2/1921

Source: GROUND WATER

<u>BENEFICIAL USE</u>	<u>From</u>	<u>To</u>	<u>Diversion Rate</u>	<u>Diversion Volume</u>
DOMESTIC	01/01	to 12/31	0.040 cfs	0.6 af
HEATING	01/01	to 12/31	0.140 cfs	101.4 af
IRRIGATION	01/01	to 12/31	0.140 cfs	38.0 af
			0.140 cfs	101.4 af

LOCATION OF POINT(S) OF DIVERSION

GROUND WATER	SWNW	Sec 22 Twp 04N Rge 02E	ADA County
GROUND WATER	NESW	Sec 22 Twp 04N Rge 02E	ADA County
GROUND WATER	NWSW	Sec 22 Twp 04N Rge 02E	ADA County
GROUND WATER	NWSW	Sec 28 Twp 04N Rge 02E	ADA County
GROUND WATER	NESE	Sec 29 Twp 04N Rge 02E	ADA County
GROUND WATER	NESE	Sec 29 Twp 04N Rge 02E	ADA County

PLACE OF USE: DOMESTIC

Twp	Rng	Sec	NE				NW				SW				SE				Totals
			NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
04N	02E	22									X			X					
04N	02E	29													X				

PLACE OF USE: HEATING

Twp	Rng	Sec	NE				NW				SW				SE				Totals
			NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
04N	02E	22									X			X					
04N	02E	29													X				

PLACE OF USE: IRRIGATION

Twp	Rng	Sec	NE				NW				SW				SE				Totals
			NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
04N	02E	22									7.0			0.5					7.5
04N	02E	29													7.5				7.5

Right Acre Limit: 6.0
POU Total Acres: 15.0

Transfer No. 78371

WATER RIGHT NO. 63-12
As Modified by Transfer No. 78371

CONDITIONS OF APPROVAL

1. This right authorizes diversion and use of low temperature geothermal water from from the Stewart Gulch Geothermal Aquifer.
2. Use of water under this water right will be regulated by the watermaster of State Water District No. 63-S, Stewart Gulch. Water District 63-S regulates the water rights from wells within its boundary that produce from the low temperature geothermal aquifer known locally as the Stewart Gulch Geothermal Aquifer.
3. The right holder shall comply with the measuring and reporting requirements of the Boise Front Geothermal Monitoring and Reporting Plan.
4. Prior to diversion of water under this approval, the right holder shall provide a means of measurement and lockable controlling works for all authorized points of diversion. The means of measurement and controlling works must be suitable for control of the diversions and acceptable to the watermaster.
5. The points of diversion are also known as the Greenhouse well (NESW S22 T4N R2E), the Pool well (SWNW S22 T4N R2E), the Windsock well (NWSW S22 T4N R2E), the Tiegs well (NWSW S28 T4N R2E), and the Silkey House and Shed wells (T4N R2E S29 NENESE).
6. The right holder must have the measuring devices for all the points of diversion calibrated by an independent method of measurement at least once a year. Notification of these calibrations shall be included in the watermaster's annual report to the Department.
7. Prior to diversion from the new points of diversion authorized by Transfer 78371 (Pool well and proposed Greenhouse well), the right holder shall conduct a pump test sufficient to confirm through pressure changes in the Windsock well that the new points of diversion have a direct and immediate hydraulic connection to the Stewart Gulch Geothermal Aquifer. The pump test must also include water temperature measurements. The right holder shall report the results of the pump test to the Department. The watermaster of Water District 63-S will authorize diversion of water from the new points of diversion when the Department is satisfied they are drawing low temperature geothermal water from the Stewart Gulch Geothermal Aquifer.
8. The right holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code and applicable Well Construction Rules of the Department. The drilling permit(s) will be conditioned to target low temperature geothermal water in the Stewart Gulch Geothermal Aquifer.
9. Diversion from the Windsock well (NWNWSW S22 T4N R2E), the Pool well (SESWNW S22 T4N R2E) and the new Greenhouse well (NESW S22 T4N R2) shall not significantly reduce artesian pressure for water rights under the authority of Water District 63-S with a priority date earlier than December 20, 2000, that divert water from the low temperature geothermal aquifer known locally as the Stewart Gulch Geothermal Aquifer. Upon written complaint to the watermaster of significant reduction from the holder of such a water right as described herein or upon IDWR's own initiative, and upon a preliminary finding by IDWR that there has been a significant reduction in pressure, the Director may require the right holder to: (a) conduct further monitoring to determine whether diversion from the Windsock, Pool, and Greenhouse wells is causing the significant reduction in pressure; (b) curtail diversion of water from the Windsock, Pool, and Greenhouse wells; or (c) require mitigation for diversion of water from the Windsock, Pool, and Greenhouse wells.

WATER RIGHT NO. 63-12
As Modified by Transfer No. 78371

CONDITIONS OF APPROVAL

10. Diversion and use of water from the Windsock, Pool, and Greenhouse wells is contingent upon continued administration by Water District 63-S.
11. Right 63-12 is limited to the irrigation of 6.0 acres within the place of use described above in a single irrigation season.
12. The total instantaneous diversion of water from all points of diversion under Rights 63-12, 63-13 and 63-15 shall not exceed 0.86 cfs, nor a total combined annual volume of 400.0 af.
13. Rights 63-12, 63-13 and 63-15 when combined shall not exceed a total annual maximum diversion volume of 38.0 af for irrigation of 6.0 acres, 0.6 af for domestic use, and 400.0 af for heating and all combined uses.
14. The rights listed below are limited to the irrigation of a combined total of 178 acres in a single irrigation season. Combined Right Nos.: 63-12, 63-13, 63-15, 63-308, 63-3603, 63-7595, 63-27649, 63-27671, 63-31050, 63-31052, 63-31053, 63-31054, 63-31055, 63-31056. Right Nos. 63-12, 63-13 and 63-15 are not subject to this combined place of use limitation when used in S29.
15. Low temperature geothermal water diverted under this right shall not be used for domestic or irrigation purposes unless it is first used for heating purposes.
16. Irrigation use is for inside commercial greenhouses and outside irrigation.
17. Domestic use is for business offices.
18. This water right is subject to the terms of an Agreement dated January 24, 2002, recorded at the Ada County Recorder's Office on August 27, 2002 as Instrument No. 102097169.
19. The right holder shall accomplish the change authorized by this transfer within three years of the date of this approval.
20. Failure of the right holder to comply with the conditions of this transfer is cause for the Director to rescind approval of the transfer.
21. Pursuant to Section 42-1412(6), Idaho Code, this water right is subject to such general provisions necessary for the definition of the rights or for the efficient administration of water rights as determined by the Snake River Basin Adjudication court in the final unified decree entered 08/26/2014.

WATER RIGHT NO. 63-13**As Modified by Transfer No. 78371**

In accordance with the approval of Transfer No. 78371, Water Right No. 63-13 is now described as follows:

Right Holder: THE TERTELING CO INC
3858 N GARDEN CENTER WAY STE 300
BOISE, ID 83703

Priority Date: 7/1/1922

Source: GROUND WATER

<u>BENEFICIAL USE</u>	<u>From</u>	<u>To</u>	<u>Diversion Rate</u>	<u>Diversion Volume</u>
DOMESTIC	01/01	to 12/31	0.040 cfs	0.6 af
HEATING	01/01	to 12/31	0.660 cfs	400.0 af
IRRIGATION	01/01	to 12/31	0.660 cfs	38.0 af
			0.660 cfs	400.0 af

LOCATION OF POINT(S) OF DIVERSION

GROUND WATER	SWNW	Sec 22 Twp 04N Rge 02E	ADA County
GROUND WATER	NESW	Sec 22 Twp 04N Rge 02E	ADA County
GROUND WATER	NWSW	Sec 22 Twp 04N Rge 02E	ADA County
GROUND WATER	NWSW	Sec 28 Twp 04N Rge 02E	ADA County
GROUND WATER	NESE	Sec 29 Twp 04N Rge 02E	ADA County
GROUND WATER	NESE	Sec 29 Twp 04N Rge 02E	ADA County

PLACE OF USE: DOMESTIC

Twp	Rng	Sec	NE				NW				SW				SE				Totals
			NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
04N	02E	22									X			X					
04N	02E	29													X				

PLACE OF USE: HEATING

Twp	Rng	Sec	NE				NW				SW				SE				Totals
			NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
04N	02E	22									X			X					
04N	02E	29													X				

PLACE OF USE: IRRIGATION

Twp	Rng	Sec	NE				NW				SW				SE				Totals
			NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
04N	02E	22									7.0			0.5					7.5
04N	02E	29													7.5				7.5

Right Acre Limit: 6.0

POU Total Acres: 15.0

Transfer No. 78371

WATER RIGHT NO. 63-13

As Modified by Transfer No. 78371

CONDITIONS OF APPROVAL

1. This right authorizes diversion and use of low temperature geothermal water from from the Stewart Gulch Geothermal Aquifer.
2. Use of water under this water right will be regulated by the watermaster of State Water District No. 63-S, Stewart Gulch. Water District 63-S regulates the water rights from wells within its boundary that produce from the low temperature geothermal aquifer known locally as the Stewart Gulch Geothermal Aquifer.
3. The right holder shall comply with the measuring and reporting requirements of the Boise Front Geothermal Monitoring and Reporting Plan.
4. Prior to diversion of water under this approval, the right holder shall provide a means of measurement and lockable controlling works for all authorized points of diversion. The means of measurement and controlling works must be suitable for control of the diversions and acceptable to the watermaster.
5. The points of diversion are also known as the Greenhouse well (NESW S22 T4N R2E), the Pool well (SWNW S22 T4N R2E), the Windsock well (NWSW S22 T4N R2E), the Tiegs well (NWSW S28 T4N R2E), and the Silkey House and Shed wells (T4N R2E S29 NENESE).
6. The right holder must have the measuring devices for all the points of diversion calibrated by an independent method of measurement at least once a year. Notification of these calibrations shall be included in the watermaster's annual report to the Department.
7. Prior to diversion from the new points of diversion authorized by Transfer 78371 (Pool well and proposed Greenhouse well), the right holder shall conduct a pump test sufficient to confirm through pressure changes in the Windsock well that the new points of diversion have a direct and immediate hydraulic connection to the Stewart Gulch Geothermal Aquifer. The pump test must also include water temperature measurements. The right holder shall report the results of the pump test to the Department. The watermaster of Water District 63-S will authorize diversion of water from the new points of diversion when the Department is satisfied they are drawing low temperature geothermal water from the Stewart Gulch Geothermal Aquifer.
8. The right holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code and applicable Well Construction Rules of the Department. The drilling permit(s) will be conditioned to target low temperature geothermal water in the Stewart Gulch Geothermal Aquifer.
9. Diversion from the Windsock well (NWNWSW S22 T4N R2E), the Pool well (SESWNW S22 T4N R2E) and the new Greenhouse well (NESW S22 T4N R2) shall not significantly reduce artesian pressure for water rights under the authority of Water District 63-S with a priority date earlier than December 20, 2000, that divert water from the low temperature geothermal aquifer known locally as the Stewart Gulch Geothermal Aquifer. Upon written complaint to the watermaster of significant reduction from the holder of such a water right as described herein or upon IDWR's own initiative, and upon a preliminary finding by IDWR that there has been a significant reduction in pressure, the Director may require the right holder to: (a) conduct further monitoring to determine whether diversion from the Windsock, Pool, and Greenhouse wells is causing the significant reduction in pressure; (b) curtail diversion of water from the Windsock, Pool, and Greenhouse wells; or (c) require mitigation for diversion of water from the Windsock, Pool, and Greenhouse wells.

WATER RIGHT NO. 63-13
As Modified by Transfer No. 78371

CONDITIONS OF APPROVAL

10. Diversion and use of water from the Windsock, Pool, and Greenhouse wells is contingent upon continued administration by Water District 63-S.
11. Right 63-13 is limited to the irrigation of 6.0 acres within the place of use described above in a single irrigation season.
12. The total instantaneous diversion of water from all points of diversion under Rights 63-12, 63-13 and 63-15 shall not exceed 0.86 cfs, nor a total combined annual volume of 400.0 af.
13. Rights 63-12, 63-13 and 63-15 when combined shall not exceed a total annual maximum diversion volume of 38.0 af for irrigation of 6.0 acres, 0.6 af for domestic use, and 400.0 af for heating and all combined uses.
14. The rights listed below are limited to the irrigation of a combined total of 178 acres in a single irrigation season. Combined Right Nos.: 63-12, 63-13, 63-15, 63-308, 63-3603, 63-7595, 63-27649, 63-27671, 63-31050, 63-31052, 63-31053, 63-31054, 63-31055, 63-31056. Right Nos. 63-12, 63-13 and 63-15 are not subject to this combined place of use limitation when used in S29.
15. Low temperature geothermal water diverted under this right shall not be used for domestic or irrigation purposes unless it is first used for heating purposes.
16. Irrigation use is for inside commercial greenhouses and outside irrigation.
17. Domestic use is for business offices.
18. This water right is subject to the terms of an Agreement dated January 24, 2002, recorded at the Ada County Recorder's Office on August 27, 2002 as Instrument No. 102097169.
19. The right holder shall accomplish the change authorized by this transfer within three years of the date of this approval.
20. Failure of the right holder to comply with the conditions of this transfer is cause for the Director to rescind approval of the transfer.
21. Pursuant to Section 42-1412(6), Idaho Code, this water right is subject to such general provisions necessary for the definition of the rights or for the efficient administration of water rights as determined by the Snake River Basin Adjudication court in the final unified decree entered 08/26/2014.

WATER RIGHT NO. 63-15**As Modified by Transfer No. 78371**

In accordance with the approval of Transfer No. 78371, Water Right No. 63-15 is now described as follows:

Right Holder: THE TERTELING CO INC
3858 N GARDEN CENTER WAY STE 300
BOISE, ID 83703

Priority Date: 3/23/1927

Source: GROUND WATER

BENEFICIAL USE	From	To	Diversion Rate	Diversion Volume
DOMESTIC	01/01	to 12/31	0.040 cfs	0.6 af
HEATING	01/01	to 12/31	0.800 cfs	400.0 af
IRRIGATION	01/01	to 12/31	0.800 cfs	38.0 af
			0.800 cfs	400.0 af

LOCATION OF POINT(S) OF DIVERSION

GROUND WATER	SWNW	Sec 22 Twp 04N Rge 02E	ADA County
GROUND WATER	NESW	Sec 22 Twp 04N Rge 02E	ADA County
GROUND WATER	NWSW	Sec 22 Twp 04N Rge 02E	ADA County
GROUND WATER	NWSW	Sec 28 Twp 04N Rge 02E	ADA County
GROUND WATER	NESE	Sec 29 Twp 04N Rge 02E	ADA County
GROUND WATER	NESE	Sec 29 Twp 04N Rge 02E	ADA County

PLACE OF USE: DOMESTIC

Twp	Rng	Sec	NE				NW				SW				SE				Totals
			NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
04N	02E	22									X				X				
04N	02E	29													X				

PLACE OF USE: HEATING

Twp	Rng	Sec	NE				NW				SW				SE				Totals
			NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
04N	02E	22									X				X				
04N	02E	29													X				

PLACE OF USE: IRRIGATION

Twp	Rng	Sec	NE				NW				SW				SE				Totals
			NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
04N	02E	22									7.0				0.5				7.5
04N	02E	29													7.5				7.5

Right Acre Limit: 6.0
POU Total Acres: 15.0

Transfer No. 78371

WATER RIGHT NO. 63-15
As Modified by Transfer No. 78371

CONDITIONS OF APPROVAL

1. This right authorizes diversion and use of low temperature geothermal water from from the Stewart Gulch Geothermal Aquifer.
2. Use of water under this water right will be regulated by the watermaster of State Water District No. 63-S, Stewart Gulch. Water District 63-S regulates the water rights from wells within its boundary that produce from the low temperature geothermal aquifer known locally as the Stewart Gulch Geothermal Aquifer.
3. The right holder shall comply with the measuring and reporting requirements of the Boise Front Geothermal Monitoring and Reporting Plan.
4. Prior to diversion of water under this approval, the right holder shall provide a means of measurement and lockable controlling works for all authorized points of diversion. The means of measurement and controlling works must be suitable for control of the diversions and acceptable to the watermaster.
5. The points of diversion are also known as the Greenhouse well (NESW S22 T4N R2E), the Pool well (SWNW S22 T4N R2E), the Windsock well (NWSW S22 T4N R2E), the Tiegs well (NWSW S28 T4N R2E), and the Silkey House and Shed wells (T4N R2E S29 NENESE).
6. The right holder must have the measuring devices for all the points of diversion calibrated by an independent method of measurement at least once a year. Notification of these calibrations shall be included in the watermaster's annual report to the Department.
7. Prior to diversion from the new points of diversion authorized by Transfer 78371 (Pool well and proposed Greenhouse well), the right holder shall conduct a pump test sufficient to confirm through pressure changes in the Windsock well that the new points of diversion have a direct and immediate hydraulic connection to the Stewart Gulch Geothermal Aquifer. The pump test must also include water temperature measurements. The right holder shall report the results of the pump test to the Department. The watermaster of Water District 63-S will authorize diversion of water from the new points of diversion when the Department is satisfied they are drawing low temperature geothermal water from the Stewart Gulch Geothermal Aquifer.
8. The right holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code and applicable Well Construction Rules of the Department. The drilling permit(s) will be conditioned to target low temperature geothermal water in the Stewart Gulch Geothermal Aquifer.
9. Diversion from the Windsock well (NWNWSW S22 T4N R2E), the Pool well (SESWNW S22 T4N R2E) and the new Greenhouse well (NESW S22 T4N R2) shall not significantly reduce artesian pressure for water rights under the authority of Water District 63-S with a priority date earlier than December 20, 2000, that divert water from the low temperature geothermal aquifer known locally as the Stewart Gulch Geothermal Aquifer. Upon written complaint to the watermaster of significant reduction from the holder of such a water right as described herein or upon IDWR's own initiative, and upon a preliminary finding by IDWR that there has been a significant reduction in pressure, the Director may require the right holder to: (a) conduct further monitoring to determine whether diversion from the Windsock, Pool, and Greenhouse wells is causing the significant reduction in pressure; (b) curtail diversion of water from the Windsock, Pool, and Greenhouse wells; or (c) require mitigation for diversion of water from the Windsock, Pool, and Greenhouse wells.


WATER RIGHT NO. 63-15
As Modified by Transfer No. 78371

CONDITIONS OF APPROVAL

10. Diversion and use of water from the Windsock, Pool, and Greenhouse wells is contingent upon continued administration by Water District 63-S.
11. Right 63-15 is limited to the irrigation of 6.0 acres within the place of use described above in a single irrigation season.
12. The total instantaneous diversion of water from all points of diversion under Rights 63-12, 63-13 and 63-15 shall not exceed 0.86 cfs, nor a total combined annual volume of 400.0 af.
13. Rights 63-12, 63-13 and 63-15 when combined shall not exceed a total annual maximum diversion volume of 38.0 af for irrigation of 6.0 acres, 0.6 af for domestic use, and 400.0 af for heating and all combined uses.
14. The rights listed below are limited to the irrigation of a combined total of 178 acres in a single irrigation season. Combined Right Nos.: 63-12, 63-13, 63-15, 63-308, 63-3603, 63-7595, 63-27649, 63-27671, 63-31050, 63-31052, 63-31053, 63-31054, 63-31055, 63-31056. Right Nos. 63-12, 63-13 and 63-15 are not subject to this combined place of use limitation when used in S29.
15. Low temperature geothermal water diverted under this right shall not be used for domestic or irrigation purposes unless it is first used for heating purposes.
16. Irrigation use is for inside commercial greenhouses and outside irrigation.
17. Domestic use is for business offices.
18. This water right is subject to the terms of an Agreement dated January 24, 2002, recorded at the Ada County Recorder's Office on August 27, 2002 as Instrument No. 102097169.
19. The right holder shall accomplish the change authorized by this transfer within three years of the date of this approval.
20. Failure of the right holder to comply with the conditions of this transfer is cause for the Director to rescind approval of the transfer.
21. Pursuant to Section 42-1412(6), Idaho Code, this water right is subject to such general provisions necessary for the definition of the rights or for the efficient administration of water rights as determined by the Snake River Basin Adjudication court in the final unified decree entered 08/26/2014.

State of Idaho
Department of Water Resources
Attachment to Transfer 78371
63-12, 63-13, and 63-15

This map depicts the HEATING place of use boundary for these water rights at the time of this approval and is attached to the approval document solely for illustrative purposes.




- Point of Diversion
- Place Of Use Boundary
- Townships
- PLS Sections

0 0.25 0.5 1 Miles



State of Idaho
Department of Water Resources
Attachment to Transfer 78371
63-12, 63-13, and 63-15

This map depicts the IRRIGATION place of use boundary for these water rights at the time of this approval and is attached to the approval document solely for illustrative purposes.




-  Point of Diversion
-  Place Of Use Boundary
-  Townships
-  PLS Sections

0 0.25 0.5 1 Miles



State of Idaho
Department of Water Resources
Attachment to Transfer 78371
63-12, 63-13, and 63-15

This map depicts the DOMESTIC place of use boundary for these water rights at the time of this approval and is attached to the approval document solely for illustrative purposes.



-  Point of Diversion
-  Place Of Use Boundary
-  Townships
-  PLS Sections

