

State of Idaho
Department of Water Resources
Permit to Appropriate Water

NO. 96-09632

Priority: July 11, 2016

Maximum Diversion Rate: 0.20 CFS

This is to certify, that CHARLES & MARLA MAILE FAMILY TRUST NOVEMBER 24 2008
223 SKY MEADOW LANE
SAGLE ID 83860

has applied for a permit to appropriate water from:

Source: GROUND WATER

and a permit is APPROVED for development of water as follows:

<u>BENEFICIAL USE</u>	<u>PERIOD OF USE</u>	<u>RATE OF DIVERSION</u>
IRRIGATION	04/01 to 10/31	0.16 CFS
DOMESTIC	01/01 to 12/31	0.04 CFS

LOCATION OF POINT(S) OF DIVERSION:

GROUND WATER SE1/4SW1/4 Sec. 4, Twp 56N, Rge 01W, B.M. BONNER County

PLACE OF USE: IRRIGATION

Twp	Rge	Sec	NE				NW				SW				SE				Totals	
			NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE		
56N	01W	4									2.0								6.5	8.5

Total Acres: 8.5

PLACE OF USE: DOMESTIC

Twp	Rge	Sec	NE				NW				SW				SE				Totals
			NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
56N	01W	4												X					

CONDITIONS OF APPROVAL

1. Proof of application of water to beneficial use shall be submitted on or before **September 01, 2020**.
2. Subject to all prior water rights.
3. This right does not grant any right-of-way or easement across the land of another.
4. Project construction shall commence within one year from the date of permit issuance and shall proceed diligently to completion unless it can be shown to the satisfaction of the Director of the Department of Water Resources that delays were due to circumstances over which the permit holder had no control.
5. Right holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code and applicable Well Construction Rules of the Department.
6. Domestic use is for 1 home. Irrigation of lawn, garden and landscaping associated with the home is authorized under the irrigation component of this right.


State of Idaho
Department of Water Resources
Permit to Appropriate Water
NO. 96-09632

7. This right when combined with all other rights shall provide no more than 0.02 cfs per acre nor more than 3.0 afa per acre at the field headgate for irrigation of the place of use.
8. Rights 96-9486 and 96-9632 when combined are for a single domestic use not to exceed 13,000 gallons per day and irrigation of 8.5 acres.

This permit is issued pursuant to the provisions of Section 42-204, Idaho Code.

Signed this 15th day of September, 20 16.

Morgan Case
MORGAN CASE, Northern Regional Manager



State of Idaho
Department of Water Resources

Attachment to Permit to Appropriate Water

96-9632

This map depicts the IRRIGATION place of use boundary for this water right at the time of this approval and is attached to the approval document solely for illustrative purposes.

01W



-  Point of Diversion
-  Place Of Use Boundary
-  PLS Sections
-  Taxlots

0 0.025 0.05 0.1 Miles




State of Idaho
Department of Water Resources

Attachment to Permit to Appropriate Water

96-9632

This map depicts the DOMESTIC place of use boundary for this water right at the time of this approval and is attached to the approval document solely for illustrative purposes.



-  Point of Diversion
-  Place Of Use Boundary
-  PLS Sections
-  Taxlots

0 0.035 0.07 0.14 Miles





State of Idaho

DEPARTMENT OF WATER RESOURCES

Northern Region, 7600 Mineral Drive, Suite 100, Coeur d'Alene, Idaho 83815

Phone: (208) 762-2800 FAX: (208) 762-2819 www.idwr.idaho.gov

C.L. "BUTCH" OTTER
Governor

September 23, 2016

GARY SPACKMAN
Director

CHARLES & MARLA MAILE
FAMILY TRUST NOVEMBER 24 2008
223 SKY MEADOW LANE
SAGLE ID 83860

RE: Permit No.96-9632

Permit Approval Notice

Dear Permit Holder:

The Department of Water Resources has issued the enclosed permit authorizing you to establish a new water right. Please be sure to thoroughly review the conditions of approval and remarks listed on your permit.

The permit is a PRELIMINARY ORDER issued by the Department pursuant to Section 67-5243, Idaho Code. It can and will become a final order without further action by the Department unless a party petitions for reconsideration or files an exception and/or brief within fourteen (14) days of the service date as described in the enclosed information sheet.

As a permit owner you must commence the excavation or construction of the diverting works within one year of the date the permit was issued, and you must proceed diligently until the project is completed. The date shown under condition no. 1 is the date when the project must be completed.

The Department will send you a 'Proof Due Notice' approximately 60 days prior to the above referenced date requesting you to file either a Proof of Beneficial Use form or a Request for Extension of Time form.

The right to drill a well is not a part of this permit to appropriate water. Beginning in July of 1987, a statute was enacted which requires a drilling permit for new well construction and deepening of existing wells. If the well(s) proposed for use under this water right permit were drilled or deepened after July 1, 1987, a separate drilling permit must be obtained from this Department. Please contact the Ground Water Protection Section located here at this office or our regional office nearest you.

Also, please note that water right owners are required to report any change of water right ownership and/or mailing address to the Department within 120 days of the change. Failure to report these changes could result in a \$100 late filing fee. Contact any office of the Department or visit the Department's homepage on the Internet to obtain the proper forms and instructions.

If you have any questions, please contact me at (208) 762-2800.

Sincerely,


Morgan Case
Northern Regional Manager

Enclosure(s)

CERTIFICATE OF SERVICE

I hereby certify that on September 23, 2016 I mailed a true and correct copy, postage prepaid, of the foregoing PRELIMINARY ORDER(Approved Permit) to the person(s) listed below:

RE: WATER RIGHT NO.

96-9632

**CHARLES & MARLA MAILE FAMILY TRUST NOVEMBER 24 2008
223 SKY MEADOW LANE
SAGLE ID 83860**



**Dianne L. Ball
Administrative Assistant**

EXPLANATORY INFORMATION TO ACCOMPANY A PRELIMINARY ORDER

(To be used in connection with actions when a hearing was not held)

(Required by Rule of Procedure 730.02)

The accompanying order or approved document is a "Preliminary Order" issued by the department pursuant to section 67-5243, Idaho Code. It can and will become a final order without further action of the Department of Water Resources ("department") unless a party petitions for reconsideration, files an exception and brief, or requests a hearing as further described below:

PETITION FOR RECONSIDERATION

Any party may file a petition for reconsideration of a preliminary order with the department within fourteen (14) days of the service date of this order. **Note: the petition must be received by the department within this fourteen (14) day period.** The department will act on a petition for reconsideration within twenty-one (21) days of its receipt, or the petition will be considered denied by operation of law. See Section 67-5243(3) Idaho Code.

EXCEPTIONS AND BRIEFS

Within fourteen (14) days after: (a) the service date of a preliminary order, (b) the service date of a denial of a petition for reconsideration from this preliminary order, or (c) the failure within twenty-one (21) days to grant or deny a petition for reconsideration from this preliminary order, any party may in writing support or take exceptions to any part of a preliminary order and may file briefs in support of the party's position on any issue in the proceeding with the Director. Otherwise, this preliminary order will become a final order of the agency.

REQUEST FOR HEARING

Unless a right to a hearing before the Department or the Water Resource Board is otherwise provided by statute, any person aggrieved by any final decision, determination, order or action of the Director of the Department and who has not previously been afforded an opportunity for a hearing on the matter may request a hearing pursuant to section 42-1701A(3), Idaho Code. A written petition contesting the action of the Director and requesting a hearing shall be filed within fifteen (15) days after receipt of the denial or conditional approval.

ORAL ARGUMENT

If the Director grants a petition to review the preliminary order, the Director shall allow all parties an opportunity to file briefs in support of or taking exceptions to the preliminary order and may schedule oral argument in the matter before issuing a final order. If oral arguments are to be heard, the Director will within a reasonable time period notify each party of the place, date and hour for the argument of the case. Unless the Director orders otherwise, all oral arguments will be heard in Boise, Idaho.

CERTIFICATE OF SERVICE

All exceptions, briefs, requests for oral argument and any other matters filed with the Director in connection with the preliminary order shall be served on all other parties to the proceedings in accordance with IDAPA Rules 37.01.01302 and 37.01.01303 (Rules of Procedure 302 and 303).

FINAL ORDER

The Director will issue a final order within fifty-six (56) days of receipt of the written briefs, oral argument or response to briefs, whichever is later, unless waived by the parties or for good cause shown. The Director may remand the matter for further evidentiary hearings if further factual development of the record is necessary before issuing a final order. The department will serve a copy of the final order on all parties of record.

Section 67-5246(5), Idaho Code, provides as follows:

Unless a different date is stated in a final order, the order is effective fourteen (14) days after its service date if a party has not filed a petition for reconsideration. If a party has filed a petition for reconsideration with the agency head, the final order becomes effective when:

- (a) The petition for reconsideration is disposed of; or
- (b) The petition is deemed denied because the agency head did not dispose of the petition within twenty-one (21) days.

APPEAL OF FINAL ORDER TO DISTRICT COURT

Pursuant to sections 67-5270 and 67-5272, Idaho Code, if this preliminary order becomes final, any party aggrieved by the final order or orders previously issued in this case may appeal the final order and all previously issued orders in this case to district court by filing a petition in the district court of the county in which:

- i. A hearing was held.
- ii. The final agency action was taken.
- iii. The party seeking review of the order resides, or
- iv. The real property or personal property that was the subject of the agency action is located.

The appeal must be filed within twenty-eight (28) days of this preliminary order becoming final. See section 67-5273, Idaho Code. The filing of an appeal to district court does not itself stay the effectiveness or enforcement of the order under appeal.

MEMORANDUM

Date: September 13, 2016
To: Water Right File 96-9632
From: smaxey
Re: NON-STANDARD AMOUNT

APPLICANT DISCUSSED CFS AMOUNT WITH IDWR DURING APPLICATION PROCESS FOR IRRIGATION SYSTEM TO BE BUILT DURING DEVELOPMENT PERIOD. APPLICANT WANTS TO KEEP FULL AMOUNT FOR DOMESTIC USE ALLOWED BY IDAHO CODE) (.04 CFS).

APPLICANT DID NOT WANT TO PAY EXTRA APPLICATION FEE AMOUNT THAT WOULD BE REQUIRED FOR STANDARD DOMESTIC USE (.04 CFS) PLUS FEE FOR STANDARD IRRIGATION RATE OF .02 CFS PER ACRE X 8.5 ACRES (.17 CFS) (TOTAL .21 CFS = \$250 FEE VERSUS .20 CFS = \$100

APPLICANT BELIEVES OBEJECTIVES CAN BE MET WITH IRRIGATION RATE OF .16 CFS INSTEAD OF .17 CFS.

MEMORANDUM

Date: September 08, 2016
To: Water Right File 96-9632
From: smaxey
Re: APPLICANT ADDRESS

ONE DIGIT WAS LEFT OUT OF THE PO BOX IN THE ADDRESS PUBLISHED IN THE FIRST LEGAL NOTICE. THE CORRECT PO BOX NUMBER WAS PUBLISHED IN THE SECOND LEGAL NOTICE. IDWR NORTHERN REGION STAFF HAVE DETERMINED REPUBLICATION IS NOT REQUIRED SINCE THERE HAVE BEEN NO PROTESTS AND THERE IS LITTLE OR NO LIKELIHOOD OF DAMAGE TO OTHER WATER RIGHTS OR THE PUBLIC DUE TO THE ERROR.

AFFIDAVIT OF PUBLICATION

RECEIVED
SEP 8 2013
IDWR / NORTH

STATE OF IDAHO)
) ss.
County of Bonner)

Holly Fredericks, being first duly sworn on oath, deposes and states:

1. I am a citizen of the United States of America, over the age of 18 years, a resident of Bonner County, Idaho, and am not a party to the proceedings referred to in the attached legal notice.
My business address is P.O. Box 159, Sandpoint, Idaho.
2. I am the legals clerk of the Bonner County Daily Bee, a newspaper of general publication in Bonner County, Idaho;
3. Said newspaper has been continuously and uninterruptedly published in Bonner County, Idaho during a period of 12 months prior to the first publication of said Notice, and thereafter.
4. The attached Notice was published in the regular and entire issue of the Bonner County Daily Bee for a period of 2 consecutive weeks, commencing on the 18 day of Aug, 2016, and ending on the 25 day of Aug, 2016.

H Fredericks


State of Idaho, county of Bonner ss.

On this 25 day of Aug, in the year of 2016, before me, Katrina George, Notary Public, personally appeared Holly Fredericks, known or identified to me to be the person whose name is subscribed to the within instrument, and acknowledged to me that he (or they) executed the same.

Katrina George
Notary Public

Residing at: Kootenai County

Comm. Exp.: MY COMMISSION EXPIRES 8/29/17



RECEIVED

SEP 06 2015

IDWR / NORTH

97-7537

JANA OSTLER

4672 GLEASON MC ABEE FALLS RD

PRIEST RIVER, ID 83853

Point of Diversion NENESW S8 T58N R04W BONNER County

Source SPRING tributary SINKS

Point of Diversion NESW S8 T58N R04W BONNER County

Source SURFACE RUNOFF

Use: DIVERSION to Storage 01/01 to 12/31 0.07 CFS

Use: FIRE Protection Storage 01/01 to 12/31 0.2 AF

Use: IRRIGATION 04/01 to 10/31 0.03 CFS

Use: IRRIGATION from Storage 04/01 to 10/31 3 AF

Use: IRRIGATION Storage 01/01 to 12/31 3.2 AF

Use: STOCKWATER 01/01 to 12/31 0.02 CFS

Use: STOCKWATER from Storage 01/01 to 12/31 0.1 AF

Use: STOCKWATER Storage 01/01 to 12/31 0.3 AF

Total Diversion: 0.12 CFS 3.3 AF

Date Filed: 7/22/2016

Place of Use: STOCKWATER T58N R04W S8 SENW NESW

Place of Use: FIRE Protection Storage T58N R04W S8 NESW

Place of Use: STOCKWATER Storage T58N R04W S8 NESW

Place of Use: IRRIGATION from Storage T58N R04W S8 NESW

Place of Use: STOCKWATER from Storage T58N R04W S8 SENW

NESW

Place of Use: IRRIGATION Storage T58N R04W S8 NESW

Place of Use: IRRIGATION T58N R04W S8 NESW

Total Acres: 1

Stockwater use is for 12 head of mixed stock.

97-7538

JANA OSTLER

4672 GLEASON MC ABEE FALLS RD

PRIEST RIVER, ID 83853

Point of Diversion NENESW S8 T58N R04W BONNER County

Source SPRING tributary SINKS

Point of Diversion NESW S8 T58N R04W BONNER County

Source SURFACE RUNOFF

Use: DIVERSION to Storage 01/01 to 12/31 0.12 CFS

Use: FIRE Protection Storage 01/01 to 12/31 0.2 AF

Use: IRRIGATION 04/01 to 10/31 .03 CFS

Use: IRRIGATION from Storage 04/01 to 10/31 3 AF

Use: IRRIGATION Storage 01/01 to 12/31 3.2 AF

Use: STOCKWATER 01/01 to 12/31 0.02 CFS

Use: STOCKWATER from Storage 01/01 to 12/31 0.1 AF

Use: STOCKWATER Storage 01/01 to 12/31 0.3 AF

Total Diversion: 0.17 CFS 3.3 AF

Date Filed: 7/22/2016

Place of Use: IRRIGATION T58N R04W S8 NESW

Place of Use: FIRE Protection Storage T58N R04W S8 NESW

Place of Use: STOCKWATER Storage T58N R04W S8 NESW

Place of Use: STOCKWATER T58N R04W S8 SENW NESW

Place of Use: STOCKWATER from Storage T58N R04W S8 SENW

NESW

Place of Use: IRRIGATION Storage T58N R04W S8 NESW

Place of Use: IRRIGATION from Storage T58N R04W S8 NESW

Total Acres: 1

Stockwater use is for 12 head of mixed stock.

Permits will be subject to all prior water rights. For additional information concerning the property location, contact Northern Region office at (208) 762-2800; or for a full description of the right(s), please see:

<http://www.idwr.idaho.gov/apps/ExtSearch/WRApplicationResults/>

Protests may be submitted based on the criteria of Idaho Code § 42-203A. Any protest against the approval of this application must be filed with the Director, Dept. of Water Resources, Northern Region, 7600 Mineral Drive, Suite 100, Coeur D'Alene ID 83815 together with a protest fee of \$25.00 for each application on or before 9/6/2016. The protestant must also send a copy of the protest to the applicant.

GARY SPACKMAN, Director

Published on 8/18/2016 and 8/25/2016

SNP LEAL 4050

AUGUST 18, 25, 2016

The following application(s) have been filed to appropriate the public waters of the State of Idaho:

96-9632

CHARLES & MARLA MAILE FAMILY TRUST NOVEMBER 24

2008

223 SKY MEADOW LANE

SAGLE, ID 83860

Point of Diversion SESW S4 T56N R01W BONNER County

Source GROUND WATER

Use: DOMESTIC 01/01 to 12/31 0.04 CFS

Use: IRRIGATION 04/01 to 10/31 0.16 CFS

Total Diversion: 0.2 CFS

Date Filed: 7/11/2016

Place of Use: IRRIGATION T56N R01W S4 SWSW SESW

Place of Use: DOMESTIC T56N R01W S4 SESW

Total Acres: 8.5

DOMESTIC USE IS FOR 1 HOME.

96-9633

KEN FINLAYSON

ANGELA FINLAYSON

12300 N HOLMES LN

HAYDEN, ID 83835

Point of Diversion SWSEW S27 T55N R03W BONNER County

Source SPRING tributary SINKS

Point of Diversion SENW S27 T55N R03W BONNER County

Source UNNAMED STREAM tributary FISH CREEK

Use: DOMESTIC 01/01 to 12/31 0.04 CFS

Use: IRRIGATION 04/01 to 10/31 0.15 CFS

Total Diversion: 0.19 CFS

Date Filed: 7/20/2016

Place of Use: DOMESTIC T55N R03W S27 SENW

Place of Use: IRRIGATION T55N R03W S27 SENW

Total Acres: 5

Domestic use is for 1 home.

96-9634

PETER FREEMAN

PO BOX 157

DOVER, ID 83825-0157

Point of Diversion NESW S23 T57N R03W BONNER County

Source GROUND WATER Tributary CARR CREEK

Point of Diversion NESW S23 T57N R03W BONNER County

Source GROUND WATER tributary CARR CREEK

Use: DIVERSION to Storage 01/01 to 12/31 0.2 CFS

Use: DOMESTIC 01/01 to 12/31 0.04 CFS

Use: FIRE Protection Storage 01/01 to 12/31 1.4 AF

Use: IRRIGATION 04/01 to 10/31 0.05 CFS

Use: IRRIGATION from Storage 04/01 to 10/31 4.5 AF

Use: IRRIGATION Storage 01/01 to 12/31 5.9 AF

Use: STOCKWATER 01/01 to 12/31 0.02 CFS

Use: STOCKWATER from Storage 01/01 to 12/31 0.1 AF

Use: STOCKWATER Storage 01/01 to 12/31 1.5 AF

Total Diversion: 0.2 CFS 6 AF

Date Filed: 7/11/2016

Place of Use: IRRIGATION T57N R03W S23 NESW SESW

Place of Use: DOMESTIC T57N R03W S23 NESW

Place of Use: STOCKWATER T57N R03W S23 NESW SESW

Place of Use: IRRIGATION from Storage T57N R03W S23 NESW

SESW

Place of Use: IRRIGATION Storage T57N R03W S23 NESW SESW

Place of Use: STOCKWATER Storage T57N R03W S23 NESW

SESW

Place of Use: STOCKWATER from Storage T57N R03W S23 NESW

SESW

Place of Use: FIRE Protection Storage T57N R03W S23 NESW

SESW

Total Acres: 1.5

Domestic use is for 1 home

Stockwater use is for 10 head mixed stock.

97-7536

LEVI EDGEcombe

DENISE EDGEcombe

11123 148TH ST E

PUYALLUP, ID 98374

Point of Diversion L1 (SENE) S28 T60N R04W BONNER County

Source PRIEST LAKE tributary PRIEST RIVER

Use: DOMESTIC 01/01 to 12/31 0.04 CFS

Total Diversion: 0.04 CFS

Date Filed: 7/20/2016

Place of Use: DOMESTIC T60N R04W S28 L1 (SENE)

Domestic use is for 1 home, with up to 1/2 acre irrigation.

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0072061

Drilling Permit No. 879030
Water right or injection well # _____

2. OWNER:

Name Charles and Maria Maile
Address 223 Sky Meadow Lane
City Sagle State ID Zip 83860

3. WELL LOCATION:

Twp. 56 North ☒ or South ☐ Rge. 1 East ☐ or West ☒
Sec. 4 1/4 SE 1/4 SW 1/4

Gov't Lot _____ County Bonner
Lat. 48 • 13.445 (Deg. and Decimal minutes)
Long. 116 • 27.248 (Deg. and Decimal minutes)
Address of Well Site 223 Sky Meadow Lane

City Sagle
Lot _____ Blk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation ☐ Thermal ☐ Injection
☐ Other _____

5. TYPE OF WORK:

☒ New well ☐ Replacement well ☐ Modify existing well
☐ Abandonment ☐ Other _____

6. DRILL METHOD:

☒ Air Rotary ☐ Mud Rotary ☐ Cable ☐ Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
Bentonite Chipp	0	38	1000 lbs.	Temp. Casing

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
6"	+2	160	.250	Steel	☒	☐	☐	☒
4"	25	365	40	PVC	☐	☒	☐	☐

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) Ring @ 160'

9. PERFORATIONS/SCREENS:

Perforations ☒ Y ☐ N Method Saw Cut

Manufactured screen ☐ Y ☒ N Type _____

Method of installation _____

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
265	365	1/8"x6"	1	4"	PVC	40

Length of Headpipe NA Length of Tailpipe NA

Packer ☐ Y ☒ N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method
NA				

11. FLOWING ARTESIAN:

Flowing Artesian? ☒ Y ☐ N Artesian Pressure (PSIG) 1 psi

Describe control device Sealed Cap

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 70 Static water level (ft) 0
Water temp. (°F) Cold Bottom hole temp. (°F) Cold
Describe access port Sealed Cap

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)
NA	50 gpm	240

Test method:

Pump ☐ Bafer ☐ Air ☒ Flowing artesian ☐

Water quality test or comments: _____

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
12	0	17	Top Soil and Gravel		X
12	17	38	Broken Weathered Shale		X
8	38	70	Broken Weathered Shale		X
8	70	110	Broken Weathered Shale	X	
8	110	150	Broken Shale		X
8	150	160	Shale		X
6	160	190	Shale		X
6	190	210	Fractured Shale 5 gpm	X	
6	210	216	Shale		X
6	216	220	Fractured Shale	X	
6	220	230	Shale		X
6	230	238	Fractured Shale	X	
6	238	248	Shale		X
6	248	255	Fractured Shale	X	
6	255	290	Shale		X
6	290	293	Fractured Shale	X	
6	293	315	Shale		X
6	315	321	Fractured Shale	X	
6	321	345	Shale		X
6	345	355	Fractured Shale	X	
6	355	365	Shale		X

RECEIVED

JUL 11 2016

IDWR / NORTH

Completed Depth (Measurable): 365'

Date Started: 6/7/2016

Date Completed: 6/13/2016

14. DRILLER'S CERTIFICATION:

We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Horsley Drilling, Inc. Co. No. 632

*Principal Driller C. Mark Horsley Date 6/14/2016

*Driller Jack Horsley Date 6/14/2016

*Operator II _____ Date _____

Operator I CH Date 6/14/2016

* Signature of Principal Driller and rig operator are required.