

Permit No. 25-4438
Name Mavis J. Olson Personal
Trust

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
In-Office Beneficial Use Examination

1. X Copy of Permit
2. X Copy of proof of beneficial use
3. X Copies of amendments/orders
4. X Qualifies under Rule 35.01.r (IDAPA 37.03.02)
5. X Point of Diversion

Township 03N, Range 38E, Section 21, QQ NWNW

Method used to determine POD: Aerial Photography / Google Earth

6. X Place of Use

Township 03N, Range 38E, Section 21, QQ NWNW

Method used to determine POU: Aerial Photography / Bonneville County
Tax Lot Data

7. X POD and POU match Permit Approval
8. X Aerial photo of place of use
9. X Well driller's report
10. X Within a water district? (WD# 120)
11. X Volume Calculation

0.6 Acre x 2 homes = 1.2 Acre
(in-house use)

12. X Other information

Examiner Name Blake Jordan Date 9/12/2016

Reviewer _____ Date _____

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT
Use Typewriter or Ballpoint pen

Office Use Only
Inspected by: _____
Twp _____ Rge _____ Sec _____
1/4 _____ 1/4 _____ 1/4 _____
Lat: _____ Long: _____

1 WELL TAG NO.

DRILLING PERMIT NC

Other IDWR NO. D0044210

2 OWNER:

Name: Mavis Olson

Address: 9478 North 15th East

City: Idaho Falls State: ID Zip 83401

3 LOCATION OF WELL by legal description.

N
Twp 3 North South
Rge 38 East West
Sec 21 1/4 NW 1/4 NW 1/4
Gov't Lot 10 Acres 40 Acres 160 Acres
County Bonneville
Lat: _____ Long: _____
S

Address of Well Site: 9478 North 15th East
City: Idaho Falls

(Give at least name of Road + Distance to Road or Landmark)

Lot No. _____ Blk No. _____ Subd. Name: _____

4 USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5 TYPE OF WORK:

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6 DRILL METHOD:

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7 SEALING PROCEDURES:

SEAL/FILTER PACK		AMOUNT		Method
From	To	From	To	
Bentonite	0	20	16 bags / 800 lbs	Annular

Was drive shoe used? ☒ Yes ☐ No Shoe Depth(s) 8" @ 56
Was drive shoe seal tested? ☒ Yes ☐ No How? Air
Shoes: 6" @ 20' and 180'

8 CASING/LINER:

Dia.	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
8	+2	-56	0.25	Steel	☒	☐	☒	☐
6"	20	180	0.25	Steel	☐	☒	☒	☐

Length of headpipe: _____ Length of Tailpipe: _____

9 PERFORATIONS/SCREENS:

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						☐	☐
						☐	☐
						☐	☐

STATIC WATER LEVEL OR ARTESIAN PRESSURE:

106 ft below ground Artesian Pressure: _____ lb

Describe access port or control devices: _____

11 WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Flowing Artesian

Yield	Drawdown	Pumping Level	Time
30+			

Water Temp _____ Cold _____ Bottom hole temp _____

Water Quality test or comments: _____

12 LITHOLOGIC LOG:

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
10	0	1	Top Soil		X
10	1	20	Sand & Gravel		X
8	20	26	Sand & Gravel		X
8	26	56	Clay & Gravel		X
8	56	65	Basalt Broken		X
8	65	80	Basalt Hard		X
8	80	98	Firm Black Basalt		X
8	98	110	Black & Red Basalt		X
8	110	145	Firm Black Basalt	X	
8	145	161	Brown Sand & Gravel	X	
8	161	164	Broken Basalt	X	
8	164	180	Basalt Hard	X	
6	180	195	Basalt Hard	X	
6	195	200	Cinders	X	

RECEIVED

NOV 13 2006

Completed Depth: 195 ft

Date Started: 10/26/06

Date Completed: 10/28/06

Department of Water Resources
Eastern Region

13 DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm: Independent Drilling md Firm No. 343

Firm Official: Robert H. Hunsaker Date: 11/7/2006
and

Supervisor/Operator: Mark Dusef Date: 11/7/2006

State of Idaho
Department of Water Resources
Water Right License
25-14438



-  Point of Diversion
-  Place Of Use Boundary
-  Townships
-  PLS Sections

0 0.035 0.07 0.14 Miles





Google earth

© 2016 Google

