

RECEIVED

AUG 22 2016

WATER RESOURCES
WESTERN REGION

Agreement In Lieu of Protest

The City of Meridian (City) seeks to protect groundwater quality within the City's impact area through implementation of rigorous well construction standards. Specialty Construction Supply (SCS) has filed Application for Permit No. 63-34250 to drill a new well for commercial uses. The City has agreed not to protest Application for Permit 63-34250 provided that SCS agrees to construct any well deeper than 200 feet to City standards. Specifically, SCS agrees to the following conditions.

1. Any well constructed deeper than 200 feet pursuant to Application for Permit No. 63-34250 must be constructed using either mud-rotary or reverse-rotary drilling methods.
2. Any well constructed deeper than 200 feet pursuant to Application for Permit No. 63-34250 must be constructed with a full depth seal extending from ground surface to within 30 feet of the well production zone.
3. Any well constructed deeper than 200 feet pursuant to Application for Permit No. 63-34250 must be constructed using plastic well casing.
4. In the event that a new well drilled for Application for Permit No. 63-34250 does not comply with conditions 1, 2, and 3, above, SCS shall abandon the well within 30 days of notice from the City.
5. A copy of this Agreement in Lieu of Protest shall be filed in the file maintained by the Idaho Department of Water Resources for this application.

Dated this 18 day of August, 2016

Dated this 18 day of August, 2016

By [Signature]
Specialty Construction Supply

By [Signature]
City of Meridian



SPF WATER
ENGINEERING

August 19, 2016

RECEIVED

AUG 22 2016

WATER RESOURCES
WESTERN REGION

Angie Grimm
IDWR Western Region Office
2735 Airport Way
Boise, ID 83705

Subject: Specialty Construction Supply Application 63-34250

Dear Angie,

Attached is a signed private agreement between Specialty Construction Supply and the City of Meridian for Application No. 63-34250. The agreement is signed by Tracy Hopkins, managing member, and by Kyle Radek, Assistant City Engineer for City of Meridian.

In lieu of a protest from the City, please include the appropriate condition on the permit approval recognizing the attached agreement. Thank you for your attention to this matter and please let me know if any further information is needed.

Sincerely,

Lori Graves
Water Rights Specialist

Cc: Kyle Radek

Enclosures

SPF file number: 790.0341