

10-06-15

RECEIVED
OCT 13 2015
Department of Water Resources
Eastern Region

To: I.D.W.R. Eastern Region
900 N. Skyline Dr. Suite A
Idaho Falls, Idaho 83402-1718

Re: Permit No. 15-7268
Received Certified Preliminary Order voiding Permit (10-05-15)
Petition For Reconsideration


To: James Cefalo per our telephone conversation

Dear Mr. Cefalo,

As we spoke with you on Tuesday, we thought everything was okay until next Spring, as we had been working with Cooper Fritz and told him I was not feeling well. I had been in the hospital, the E.R. (twice) and several doctors visits. Much to our surprise, Scott showed up at our farm in Malad, (unannounced) to do a field exam 2 days later. He showed that the field exam failed due to the fact that it was not hooked up to the wheel lines. We had already explained to Cooper that we were unable to hook the well into our lines because of the fact that the Deep Creek Water was still in the lines. We have a question, how can you prove up on a Supplemental Ground Water Right, if it violates the supplemental conditions on our permit? We have been using the surface irrigation water all of these years. But we have had more drought seasons than not. Had we have known Scott was coming, we could have rented the generator from Glenn's Electric in Logan and hooked it up to some hand lines that we had to show that our well was workable, We have spent considerable time & money developing this well, let alone all of the hard work and worry. Malad is trying to put moratoriums on wells in our area and our chances are pretty slim to get another permit. So please have some empathy and understanding on our part to reconsider this petition. We have had some set backs with the power situation from Rocky Mt. Power. They wanted about \$15,000 - \$20,000 to go across the road. "Absurd"!!!

Please find enclosed a copy from Glenn's Electric showing what we were able to pump that day on April 20, 2015 and also the I.D.W.R. Proof Report for Water Permit 15-7268.

Sincerely yours,

Gordon & Rhea Smith

cc: Jeff Peppersack
cc: Shelley Keen
cc: Gary Spackman



Rec'd 4-29-15
WR. 15-7268
9-16-15 Copy to water Res. in
4/24/2015 T.F. & I.F.

**GORDON SMITH
MALAD FARM
800 N 300 W
MALAD, ID.**

Glenn
5-23-15 10:30 AM

Set 10 HP sub. Pump on April 20th, 2015.

Starting Amps

Pump set at 350 feet.

Running Amps

Pump model# 60S100-18 Grundfos.

6-2-15 460 Volt 3 Ph

Static water level is 276 feet.

60 KW

Pumped 66 GPM for 2 hours with 18 feet draw down.

THANK YOU,

KENT GLENN

Cell: (435)994-0656

Office: (435)752-4178

6-2-15 (435) 752-4499

Bob Dunn
Service Technician

501 North Main Street • Logan, UT 84321
Phone: 435-752-4178 • Fax: 435-752-4214
Cell: 435-994-0673 • info@glennselectric.com



2. Customer is not responsible for any damage to equipment.
3. Equipment will be made to conform to applicable
ANSI, UL, OSHA, or Safety Standards.

CLAIM CHECK
D-04567
4-30-15
Check # 706