

80250

Ident. No.

95-17049

RECEIVED

JUL 17 2015

IDWR / NORTH

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
APPLICATION FOR PERMIT
To appropriate the public waters of the State of Idaho

1. Name of applicant(s) ROBERT A COLVIN AND/OR SUSAN L COLVIN Phone 912-507-8708
Name connector (check one): ☐ and ☐ or ☒ and/or
Mailing address 19980 S PROVIDENCE LN City WORLEY
State ID Zip 83876 Email ROBERT.COLVIN77@GMAIL.COM
2. Source of water supply GROUNDWATER which is a tributary of _____
3. Location of point(s) of diversion:

TWP	RGE	SEC	Govt Lot	1/4	1/4	1/4	County	Source	Local name or tag #
48N	04W	18			SE	SE	KOOTENAI	GROUNDWATER	D0056684
48N	04W	17	6		SW	SW	KOOTENAI	GROUNDWATER	D0033351

4. Water will be used for the following purposes:
- Amount 0.08 CFS for DOMESTIC purposes from 1/1 to 12/31 (both dates inclusive)
(cfs or acre-feet per year)
- Amount 0.06 CFS for IRRIGATION purposes from 3/15 to 11/15 (both dates inclusive)
(cfs or acre-feet per year)
- Amount _____ for _____ purposes from _____ to _____ (both dates inclusive)
(cfs or acre-feet per year)
- Amount _____ for _____ purposes from _____ to _____ (both dates inclusive)
(cfs or acre-feet per year)
5. Total quantity to be appropriated is (a) 0.14 CFS cubic feet per second (cfs) and/or (b) _____ acre feet per year (af).
6. Proposed diverting works:
- a. Describe type and size of devices used to divert water from the source. TWO WELLS SUPPLY HOME, GUEST HOME AND FUTURE HOME WITH IN HOUSE USE AND IRRIGATION
- b. Height of storage dam _____ feet; active reservoir capacity _____ acre-feet; total reservoir capacity _____ acre-feet. If the reservoir will be filled more than once each year, describe the refill plan in item 11. For dams 10 feet or more in height OR reservoirs with a total storage capacity of 50 acre-feet or more, submit a separate Application for Construction or Enlargement of a New or Existing Dam. Application required? ☐ Yes ☐ No
- c. Proposed well diameter is _____ inches; proposed depth of well is _____ feet.
- d. Is ground water with a temperature of greater than 85°F being sought? ☐ Yes ☐ No
- e. If well is already drilled, when? 2003, 2009; drilling firm UNITED, AMERICAN;
well was drilled for (well owner) GENE HOLM, CENTURY CONSTRUCTION; Drilling Permit No. 809184.
7. Description of proposed uses (if irrigation only, go to item 8):
- a. Hydropower; show total feet of head and proposed capacity in kW. _____
- b. Stockwatering; list number and kind of livestock. _____
- c. Municipal; complete and attach the [Municipal Water Right Application Checklist](#).
- d. Domestic; show number of households 3 HOMES. (3RD HOME IS GUEST RESIDENCE)
- e. Other; describe fully. DOMESTIC FOR 3 HOMES AND IRRIGATION OF 2 ACRES

8. Description of place of use:

- a. If water is for irrigation, indicate acreage in each subdivision in the tabulation below.
- b. If water is used for other purposes, place a symbol of the use (example: D for Domestic) in the corresponding place of use below. See instructions for standard symbols.

TWP	RGE	SEC	NE				NW				SW				SE				TOTALS
			NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
48N	04W	18																D/D	
																		1	1
48N	04W	17											D						
													1						1
													GL6						

Total number of acres to be irrigated: 2

9. Describe any other water rights used for the same purposes as described above. Include water delivered by a municipality, canal company, or irrigation district. If this application is for domestic purposes, do you intend to use this water, water from another source, or both, to irrigate your lawn, garden, and/or landscaping?

10. a. Who owns the property at the point of diversion? APPLICANT
- b. Who owns the land to be irrigated or place of use? APPLICANT
- c. If the property is owned by a person other than the applicant, describe the arrangement enabling the applicant to make this filing:

11. Describe your proposal in narrative form, and provide additional explanation for any of the items above. Attach additional pages if necessary.

APPLICANT HAS 2 WELLS THAT SUPPLY EXISITING HOME AND GUEST HOME. WELLS PUMP INTO A 1,500 GALLON CISTERN THAT THEN SUPPLIES EXISITING HOME. APPLICANT PLANS TO BUILD FUTURE HOME ON EMPTY LOT. IRRIGATION OF 1 ACRE PER HOME SITE. APPLICANT HAS GUEST HOME IN ADDITION TO FULL TIME RESIDENCE.

12. Time required for completion of works and application of water to proposed beneficial use is 5 years (minimum 1 year).

13. **MAP OF PROPOSED PROJECT REQUIRED** - Attach an 8½" x 11" map clearly identifying the proposed point of diversion, place of use, section #, township & range. A photocopy of a USGS 7.5 minute topographic quadrangle map is preferred.

The information contained in this application is true to the best of my knowledge. I understand that any willful misrepresentations made in this application may result in rejection of the application or cancellation of an approval.

Signature of Applicant

Signature of Applicant

ROBERT COLVIN

Print Name (and title, if applicable)

Print Name (and title, if applicable)


For Department Use:

Received by _____ Date _____ Time _____ Preliminary check by _____

Fee \$ 350.00 Received by NJ Receipt No. N031367 Date 7-17-15

(100 + 250 for up grade)

COLVIN APPLICATION MAP



Legend

- Taxlots
- Sections
- QQ

0 0.045 0.09 0.18 Miles



* Signature of Principal Driller and rig operator are required.

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

Office Use Only			
Inspected by _____			
Twp _____	Rge _____	Sec _____	
1/4 _____	1/4 _____	1/4 _____	
Lat: : :	Long: : :		

1. WELL TAG NO. **D0033351****RECEIVED**

DRILLING PERMIT NO

809184**JAN 30 2004**

Other IDWR No.

2. OWNER:

Name **Gene Holm**Address **300 West 4th N**City **Burley**State **ID**Zip **83318-34**

3. LOCATION OF WELL by legal description:

N	Twp 49N		North ☒ or South ☐
W	Rge 04W	East ☐ or West ☒	
E	Sec 18	1/4 SW 1/4 SW 1/4	
S	Gov't Lot _____	County Kootenai	
	Lat _____	Long _____	

Address of Well Site: (see next line)

Sun Up Bay to Providence to first right to end

City _____

Lot _____ Blk _____ Sub. Name (see next line) _____

4. USE:

- ☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

- ☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

- ☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
Bentonite Grans	0	18	14 sacks	Pour In

Drive Shoe Used? ☒ Y ☐ N Shoe Depth(s) **530**Drive Shoe Seal Tested? ☐ Y ☒ N How? _____

8. CASING/LINER

Diam	From	To	Gauge	Material	Casing	Liner	Weld	Thrded
6	1	530	0.250	Steel	☒	☐	☒	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length Headpipe _____ Length Tailpipe _____

9. PERFORATIONS/SCREENS

☐ Perforations? Method _____☐ Screens? Screen Type _____

From	To	Slot	Nmbr	Diam	Material	Casing	Liner
						☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

400 ? ft. below ground. Artesian pressure _____ lb.

Depth flow encountered **630, 830, 890** ft. Describe access port orcontrol devices: **Steel Cap Welded**

11. WELL TESTS:

- ☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
7	100%	915	1 Hour

Water Temp. _____

Cold

Bottom hole temp. _____

Cold

Water Quality test or comments: (below) Depth first Water Encountered **630**

Slight color, No Smell, Cold

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Lithology, Water Quality and Temperature	Water	
				Y	N
8	0	5	Topsoil	☐	☒
8	5	55	Basalt: Clay Mix Soft	☐	☒
8	55	62	Clay: Brown and Tan	☐	☒
8	62	180	Basalt: Black Hard	☐	☒
8	180	185	Clay: Brown	☐	☒
8	185	205	Clay: Gray	☐	☒
8	205	215	Clay: Brown	☐	☒
8	215	225	Sand: Brown with Clay	☐	☒
8	225	240	Clay: Tan and Brown	☐	☒
8	240	255	Clay: Orange	☐	☒
8	255	268	Clay: Brown	☐	☒
8	268	292	Clay: Basalt Mix Soft	☐	☒
8	292	410	Basalt: Black Medium	☐	☒
8	410	420	Basalt: Broken	☐	☒
8	420	430	Clay: Black and Brown	☐	☒
8	430	452	Clay: Brown and Tan	☐	☒
8	452	480	Clay: Orange	☐	☒
8	480	520	Granite: Decomposed and Clay Soft	☐	☒
8	520	530	Granite: Soft Brown	☐	☒
6	530	590	Granite: Green and White Medium	☐	☒
6	590	660	Granite: Green and White Black	☒	☐
			Very Soft 1 GPM	☐	☐
6	660	730	Granite: Purple, White, Black Medium	☐	☒
6	730	780	Granite: Black and White Medium	☐	☒
6	780	810	Granite: Purple, Black, White Medium	☐	☒
6	810	830	Granite: Green, Black, White Med. 2 GPM	☒	☐
6	830	870	Granite: Purple, White, Black Medium	☐	☒
6	870	920	Granite: Green, Black, White Medium	☐	☒
			4 GPM at 890 feet	☒	☐

Completed Depth **920** (Measurable)Date: Started **11/18/03** Completed **11/26/03**

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name **United Drilling Inc.**Firm No **414**

Firm Official and _____

Date **11/26/03**Supervisor or Operator **Jason C. Beckham**Date **11/26/03****49N 4W 18**



State of Idaho

DEPARTMENT OF WATER RESOURCES

Northern Region, 7600 Mineral Drive, Suite 100, Coeur d'Alene, Idaho 83815

Phone: (208) 762-2800 FAX: (208) 762-2819 www.idwr.idaho.gov

C.L. "BUTCH" OTTER
Governor

GARY SPACKMAN
Director

August 18, 2015

ROBERT A COLVIN
SUSAN L COLVIN
19980 S PROVIDENCE LN
WORLEY, ID 83876

Application For Permit No. 95-17049

Dear Applicant(s):

The Department of Water Resources has received your water right application. Please refer to the number referenced above in all future correspondence regarding this application.

A legal notice of the application has been prepared and is scheduled for publication in the COEUR D ALENE PRESS on 8/20/2015 and 8/27/2015. Protests to this application may be submitted for a period ending ten (10) days after the second publication.

If the application is protested, you will be sent a copy of each protest. All protests must be resolved before the application can be considered for approval. If the protest(s) cannot be resolved voluntarily, the Department will conduct a conference and/or hearing on the matter.

If the application is not protested, the Department will process your application and notify you of any action taken on the application. If your application is approved, the Department will send you a copy of the permit.

Please contact this office if you have any questions regarding the application.

Sincerely,

Dianne Ball
Administrative Assistant

Ball, Dianne

From: Ball, Dianne
Sent: Tuesday, August 18, 2015 11:05 AM
To: Legal Notices-CdA Press
Subject: Application for Permit No. 95-17047, 95-17048, 95-17049
Attachments: LegalNotice 08-18-15 CDA e-mail 95-17047,48,49.doc

Please publish the enclosed legal notice on the dates indicated, August 20 and 27, 2015, (once a week for two consecutive weekly issues). If you cannot publish the notice on the proposed dates, please contact us immediately.

This should be very close to press ready for 2-column, Country Old Style font, 8pt. Please note the areas under USE containing dates and water amounts that are offset and lined up. Our legal should appear in this format.

Please also send a proof/preview copy for my review before this actually goes to press.

An affidavit of publication must be submitted to the Department along with the publication bill. Please send the affidavit and bill to this office before 9/8/2015. Your cooperation is appreciated.

If you have any questions, please call me at number below, or reply to this e-mail.

Thanks for all your super help – always – for your help see that our legals appear as submitted, and look great.

Dianne Ball

Administrative Assistant
Idaho Department of Water Resources
7600 N Mineral Dr., Ste. 100
Coeur d'Alene, ID 83815
208-762-2800 Fax 208-762-2819

The following application(s) have been filed to appropriate the public waters of the State of Idaho:

95-17047

CORY S COLVIN

PO BOX 2682

SPOKANE, ID 99220

Point of Diversion L2(SWNE) S28 T48N R04W KOOTENAI CO

Source COEUR D ALENE LAKE tributary SPOKANE RIVER

Use: DOMESTIC 01/01 to 12/31 0.04 CFS

Total Diversion: 0.04 CFS

Date Filed: 7/8/2015

Place of Use: DOMESTIC T48N R04W S28 L2(SWNE)

Domestic use is for one home.

95-17048

HAGADONE HOSPITALITY CORP

PO BOX 6200

COEUR D ALENE, ID 83816

Points of Diversion(2) L2(SWSW) S20 T50N R03W

KOOTENAI County

Source GROUND WATER

Use: COMMERCIAL 01/01 to 12/31 0.07 CFS

Total Diversion: 0.07 CFS

Date Filed: 7/15/2015

Place of Use: COMMERCIAL T50N R03W S19 L6(NESE)

T50N R03W S20 L2(SWSW)

Commercial use is for 300 Slip Marina

95-17049

ROBERT A COLVIN

SUSAN L COLVIN

19980 S PROVIDENCE LN

WORLEY, ID 83876

Point of Diversion SESE 18 T48N R04W KOOTENAI CO

Source GROUND WATER

Point of Diversion L6(SWSW) S17 T48N R04W KOOTENAI CO

Source GROUND WATER

Use: DOMESTIC 01/01 to 12/31 0.08 CFS

Use: IRRIGATION 03/15 to 11/15 0.06 CFS

Total Diversion: 0.14 CFS

Date Filed: 7/17/2015

Place of Use: DOMESTIC T48 R04W S17 L6(SWSW)

T48N R04W S18 SESE

Place of Use: IRRIGATION T48N R04W S17 L6(SWSW)

T48N R04W S18 SESE

Total Acres: 2

Domestic use is for three homes.

Permits will be subject to all prior water rights. For additional information concerning the property location, contact Northern Region office at (208) 762-2800 ; or for a full description of the right(s), please see:

www.idwr.idaho.gov/apps/ExtSearch/WRFiling.asp.

Protests may be submitted based on the criteria of Idaho Code § 42-203A. Any protest against the approval of this application must be filed with the Director, Dept. of Water Resources, Northern Region, 7600 Mineral Drive, Suite 100, Coeur D' Alene ID 83815 together with a protest fee of \$25.00 for each application on or before 9/8/2015. The protestant must also send a copy of the protest to the applicant.

GARY SPACKMAN, Director

Published on 8/20/2015 and 8/27/2015