

Block, Darla

From: Cefalo, James
Sent: Tuesday, July 21, 2015 1:24 PM
To: Kristin Moore
Cc: Block, Darla
Subject: 25-14379 M & B Investments LLC
Attachments: DOC003.pdf

Kristin,

Sorry for the delayed response. I just received a copy of your letter this morning. The original must have been mailed to Boise with the proof of beneficial use.

Idaho Code Section 42-701 provides the statutory authority for requiring lockable controlling works and measuring devices. Section 42-701 does not include any exemptions for subdivision domestic uses. It is hard to predict how curtailment may occur in pending or future delivery calls. There could be a scenario where curtailment of both permits may be warranted. Therefore, I do not support waiving the lockable controlling works requirement. I am surprised that the power panel is not configured in a way that would qualify as a lockable works. Most ground water diversions are curtailed by locking the power supply to the pump.

James

From: Block, Darla
Sent: Tuesday, July 21, 2015 10:40 AM
To: Cefalo, James
Subject: 25-14379 M & B Investments LLC

July 21, 2015

Good Morning James,

I received proof of beneficial use along with the attached letter addressed to you regarding permit condition #6 requirement of a lockable device. I am unable to move forward with processing proof until I have received notice from you whether or not you agree with Rocky Mountain Environmental regarding removal of permit condition #6. Please respond as soon as possible.

Thank You,
Darla Block