

Hemenway, Sandy

From: Jeff Cook [jeffcook@rtci.net]
Sent: Monday, April 14, 2014 3:32 PM
To: Hemenway, Sandy
Subject: glens ferry pumping

Sandy,

With the way our Treatment Plant is set up the Snake River is our primary source. The pumps in the river start to run when the plant is asking for 400gpm and then at 800gpm it will split the demand between the river and the springs. The Plant is designed for 1mgd of production using the 2 sources.
Jeff