

Nelson, Dan

From: Jeff Cook [jeffcook@rtci.net]
Sent: Monday, December 08, 2014 10:26 AM
To: Nelson, Dan
Subject: Fwd: Glenns Ferry
Attachments: iphone 362.JPG; iphone 372.JPG

----- Forwarded message -----

From: Jeff Cook <jeffcook@rtci.net>
Date: Mon, Dec 8, 2014 at 10:11 AM
Subject: Glenns Ferry
To: dan.nelson@idwr.id.gov

Dan,

Here are the pictures of the max pumping from both locations.

The River flows are 500gpm lower than the Springs however the spring pumps were just recently rebuilt so that is why we see the difference.

The River flows were taken on 12/08/2014 at 8:20 am of 1104 gpm

The spring flows were taken on 12/08/2014 at 8:35 am of 1676 gpm

Hopefully this gives you the needed information if not please don't hesitate to give me a call.

Have a Great Day.

Jeff

--

Jeff Cook
Public Works Director
City of Glenns Ferry
Office [\(208\)366-7418](tel:(208)366-7418)
Cell [\(208\)599-3741](tel:(208)599-3741)

--

Jeff Cook
Public Works Director
City of Glenns Ferry
Office (208)366-7418
Cell (208)599-3741



G.P.M.



1000 GALLONS



G.P.M.

10
5 15 30

1000 GALLONS

