



STATE OF IDAHO
DEPARTMENT OF
ENVIRONMENTAL QUALITY

RECEIVED

JAN 26 2015

DEPT OF WATER RESOURCES
SOUTHERN REGION

650 Addison Avenue West, Suite 110 • Twin Falls, Idaho 83301 • (208) 736-2190
www.deq.idaho.gov

C.L. "Butch" Otter, Governor
Curt Fransen, Director

January 22, 2015

37-262A / 78927
37-22850

The Honorable Walter Nelson
Mayor, City of Gooding
308 5th Avenue West
Gooding, Idaho 83330-1205

Re: "Record Drawing" Review, **City of Gooding Recharge Proposal - Groundwater Quality Program Monitoring Well MW-2 and MW-3 Post Construction Record Drawing Review**, Gooding Idaho

Dear Mayor Nelson:

Please be aware that Chuck Brockway, with Brockway Engineers has submitted record drawings for the above referenced ground water recharge project to this office for our review and certification.

This office has reviewed the submittal and we have the following comments:

- **Post Construction Monitoring Well (MW) Drawings. Editorial Comment.** Be aware it appears from a discussion with the project engineer that the monitoring well drawing with a pump illustrated at 149-feet meant to be identified as MW-3.
- **Additional Data Requested Relative to MW-1, MW-2 and MW-3. General Comment.** After reviewing the provided record drawings, we respectfully request that the ground surface elevation at each well head; private well static water level; and well head GPS information preferably set up using Decimal Degrees, Projection NAD-1983_Idaho_TM Geographic GCS North American_1983 standard be provided for our use and record.
- **Monitoring Program Approval Condition. General Comment.** Be reminded that the city of Gooding is required via DEQ approval of the ground water quality monitoring program to provide routine monitoring to DEQ within ten days of acquisition. At this time, it doesn't appear baseline or routine monitoring results have been submitted for our review and record. Resultantly, we respectfully request that this information be forwarded for our immediate use, review and record.
- **Use of Private and Domestic Ground Water Sources. General Comment.** Pursuant to deliverables outlined in the November 6, 2014 ground water quality monitoring program

amendment, we respectfully request that the private well (MW-1) use easement and agreement be provided for our use and record.

At appears from our review of the drawings that both monitoring wells were constructed in accordance with the approved design and conditions imposed by this office at approval. We hereby certify both monitoring wells for operation.

We respectfully request that additional information be provided to this office for our use, review and project record at the city's earliest convenience.

If you have any questions, please do not hesitate to contact this office at (208) 736-2190.

Sincerely,



Brian A. Reed, PE
Technical Engineer I

BAR:gl

- cc: Todd Bunn, City of Gooding
Holly Crawford, BLM, Shoshone Field Office
Casey Prestwich, BLM, Shoshone Field Office
Alan Merrit, PE, IDWR, Twin Falls
Oksana Roth, EI, Keller & Associates, Pocatello
- ec: Irene Nautch, DEQ-Twin Falls Regional Office
David Anderson, DEQ-Twin Falls Regional Office
Mike Brown, DEQ-Twin Falls Regional Office
Tonia Mitchell, DEQ-State Office
MaryAnna Peavey, DEQ-State Office