

State of Idaho
Department of Water Resources
Permit to Appropriate Water

NO. 15-07377

Priority: June 27, 2014

Maximum Diversion Rate: 0.84 CFS

This is to certify, that ERIC HARTVIGSEN
PO BOX 53
MALAD ID 83252

has applied for a permit to appropriate water from:

Source: GROUND WATER

and a permit is APPROVED for development of water as follows:

<u>BENEFICIAL USE</u>	<u>PERIOD OF USE</u>	<u>RATE OF DIVERSION</u>	<u>ANNUAL VOLUME</u>
IRRIGATION	04/01 to 10/31	0.84 CFS	147.0 AF

LOCATION OF POINT(S) OF DIVERSION:

GROUND WATER NW¼NE¼ Sec. 29 Twp 14S Rge 36E, B.M. ONEIDA County

PLACE OF USE: IRRIGATION

Twp	Rge	Sec	NE				NW				SW				SE				Totals	
			NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE		
14S	36E	29																		42.0

Total Acres: 42

CONDITIONS OF APPROVAL


1. Proof of application of water to beneficial use shall be submitted on or before **January 01, 2020**.
2. Subject to all prior water rights.
3. After specific notification by the Department, the right holder shall install a suitable measuring device or shall enter into an agreement with the Department to use power records to determine the amount of water diverted and shall annually report the information to the Department.
4. This right when combined with all other rights shall provide no more than 0.02 cfs per acre nor more than 3.5 afa per acre at the field headgate for irrigation of the place of use.
5. Right holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code and applicable Well Construction Rules of the Department.
6. Project construction shall commence within one year from the date of permit issuance and shall proceed diligently to completion unless it can be shown to the satisfaction of the Director of the Department of Water Resources that delays were due to circumstances over which the permit holder had no control.

State of Idaho
Department of Water Resources
Permit to Appropriate Water

NO. 15-07377

7. To prevent injury to prior water rights appropriating water from the underlying shallow aquifer, the well used as a point of diversion for this water right shall be constructed and maintained with unperforated casing and sealed into the first significant confining layer located 120 feet or more below ground surface.

This permit is issued pursuant to the provisions of Section 42-204, Idaho Code. Witness the signature of the Director, affixed at Boise, this 22nd day of December, 20 14.




for GARY SPACKMAN
Director