

Block, Darla

From: Rex Barrie [waterdistrict63@qwestoffice.net]
Sent: Tuesday, November 25, 2014 7:12 AM
To: 'Merges, Doug'
Cc: 'Neil & Stephanie Allison'; Block, Darla; 'Merges, Lori Ann'; dougmerges@gmail.com
Subject: RE: Permit 63-32562 - Doug & Lori Ann Merges

Doug,

If Neil has any questions please have him contact me so we can finish this up for you.
Your Waterman Headgate is sufficient for the "lockable control works" requirement and as soon as the weir is installed you will be good to go.

Let me know when the weir is in and I will pass on the information to IDWR.

Rex R. Barrie
Boise River Watermaster

From: Merges, Doug [<mailto:Doug.Merges@wolterskluwer.com>]
Sent: Monday, November 24, 2014 12:05 PM
To: waterdistrict63@qwestoffice.net
Cc: Neil & Stephanie Allison (allisonfarms@gmail.com); darla.block@idwr.idaho.gov; Merges, Doug; Merges, Lori Ann (Lamerges@yahoo.com); dougmerges@gmail.com
Subject: Permit 63-32562 - Doug & Lori Ann Merges

Hi Rex –

Per our meeting today, I will commit to having a measuring device installed (most likely a weir style) by 4.1.2015. I'm relieved to already have met the lockable control requirement with my current Waterman Gate set up. I'm copying my farmer, Neil Allison on this correspondence as he will be oversee the measuring device installation process for me and also Darla Block with the IDWR office as she is who sent the "proof of deficiency letter," requiring both the measuring and lockable devices.

Let me know if any further information is required on my end. Thanks for your time today.

Doug Merges
27205 Wing Setter Lane
Parma, ID 83660
Phone: 208.722.7440
doug.merges@wolterskluwer.com