

Westra, John

From: Rex Barrie [waterdistrict63@qwestoffice.net]
Sent: Monday, September 22, 2014 8:33 AM
To: Westra, John
Subject: Mag meter

John,

Paradise HOA is requesting to use a McCrometer Mc.Mag3000 for their diversion at Grouse Creek. Since it is not on the list of approved meters what do I tell them? And how can it be added if it looks good?

Let me know.

Rex R. Barrie
Boise River Watermaster

9/29/14 Dale Pippin Paradise HOA JFW 208-733-1240
- Discussed the possible choice above for a flow meter. The 4" pipeline is off the creek with 100 ft of drop to cabins. This ~~meter~~ meter is battery operated - no power at the pipeline location. Mr. Pippin talked with the manufacturer. This is a new model meter. The HOA will remove the meter every fall and be stored in heated area. The probe is short and is started downstream. This meter is much better choice than a weir or flume. Given the lack of power to the location, this is certainly worth a try. \$1500⁰⁰ reasonable price. I suggested they keep us informed on the success of the meter.