

Block, Darla

From: Block, Darla
Sent: Thursday, September 18, 2014 12:47 PM
To: 'Keith C. Wilson'
Subject: RE: Permit No. 35-14139 School District #91

September 18, 2014

Dear Mr. Wilson,

The Department is in receipt of your request to have the measuring device requirement condition removed from permit # 35-14139. Additionally, you must contact the watermaster about his need for the requirement. If he agrees that the measuring device requirement listed under permit condition no. 3 is unnecessary, request that he/she provide the Department with written agreement that the requirement can be waived at this time. Please make sure that the watermaster knows that this permit has a maximum diversion rate of 1.34 CFS for heating and cooling from groundwater. Upon receipt of a written agreement from the watermaster of Water District No. 120, the Department will look at the possibility of issuance of an order waiving the requirement.

Sincerely,

Darla Block
Technical Records Specialist
Water Allocation Bureau
Ph. #(208) 287-4945
Darla.Block@idwr.idaho.gov

From: Keith C. Wilson [<mailto:keith.rmea@gmail.com>]
Sent: Tuesday, September 16, 2014 3:48 PM
To: Block, Darla
Subject: Permit No. 35-14139 School District #91

Darla,

I do not see a reason that School District #91 permit 35-14139 has a condition for a measuring device.

1. The use is **non-consumptive**
2. The system is a **closed system** where water is pumped to the heat exchanger to extract heat and then injected back into the ground through the injection well.
3. On behalf of School District #91 we have applied for an additional four permits for closed loop heat pump systems that do not require a measuring device. They are as Follows:
 - a. 25-14378 Dora Erickson School
 - b. 25-14387 Edgemont School
 - c. 25-14388 Longfellow School
 - d. 35-14283 Ethel Boyes School

On behalf of our client School District #91, I am requesting that the measuring device condition be removed from Permit #35-14139.

I would appreciate your assistance in removing the condition.

Thank you,

Keith C. Wilson

Senior Water Rights Analyst

482 Constitution, Suite 303, Idaho Falls, ID 83402

E-Mail: kwilson@rockymountainenvironmental.com

VOICE: 208-524-2353 ||| FAX: 208-524-1795 ||| CELL: 208-339-1901



CONFIDENTIALITY NOTICE: This message is intended only for the use of the individual or entity to which it is addressed and may contain information that is privileged, confidential and exempt from disclosure under applicable law. If the reader of this message is not the intended recipient, you are hereby notified that any dissemination or distribution of this communication to other than the intended recipient is strictly prohibited. If you have received this communication in error, please notify us immediately by reply email to the sender or collect telephone call to (208) 524-2353. *Thank you.*
