



State of Idaho

DEPARTMENT OF WATER RESOURCES

Southern Region • 650 Addison Ave West, Suite 500 • Twin Falls, Idaho 83301

Phone: (208) 736-3033 • FAX: (208) 736-3037 • Website: www.idwr.idaho.gov

C.L. "BUTCH" OTTER
Governor

GARY SPACKMAN
Director

September 15, 2014

Charles G. Brockway, PE
Brockway Engineering PLLC
2016 North Washington Street, Suite 4
Twin Falls, ID 83301

RE: Request for Waiver of Measuring Device for 37-22841 and 37-22838

Dear Chuck:

Pursuant to your letter dated August 27, 2014, please consider this letter a waiver for installing a measuring device on the inflow to the subject pond.

I have discussed this matter with the watermaster, Kevin Lakey, and it is acceptable to the Department and the watermaster that a measuring device on the inflow be waived as long as a staff gauge is maintained in the pond and that a measuring device is maintained on the outflow from the pond. Kevin also requests that a measuring device be placed on any pump diverting from the pond.

If you have questions please feel free to contact this office.

Respectfully,

Allen Merritt, PE
Southern Region Manager

Cc: Fritz Haemmerle
Kevin Lakey – Watermaster WD37