

State of Idaho
Department of Water Resources

RECOMMENDATION OF WATERMASTER

Transfer Number.: 79403

Applicant's Name: CV Cattle

Watermaster's Recommendation:

- a) ☐ I do not oppose approval of this application.
b) ☒ I do not oppose approval of this application if it is conditioned as follows:

- c) ☒ I oppose approval of this application for the following reasons:

- d) ☒ Additional Comment:

Dated this 10 day of Aug, 20 14

Water District No: 29

Steve Holder
Watermaster's Signature

I have spent alot of time thinking about this. Im sure there are ways to solve it.

This water ~~right~~ has not been used since 2002 that I know of. There has been problems with the syphon Im well aware of the syphon my Great Grand father my Grandfather and my fathers family (the land down the ditch currently owned by Norman Frankson 1999 or over

The pipe below the valve is getting wore out and beyond repair if the ditch is not cleaned and maintained with moss killer early summer there is no way to get water to the end Too much air in water above there is no way to get water to the end. I believe the the system needs to be fixed and maintained and it will work until the water is gone.

The water is 1905 from Tapona 1913 from the river and it ends early

I believe these water rights should never be part of the system below the reservoir out the bottom into the river this is a private agreement between 3 syphon user's and PMUC Council

If IDWR decides it should I believe measure devices to this property at point of entry should be installed and PMUC has to release water to cover it.

Until these rights are no longer deliverable or if determined the syphon is out of water and it's off