

## Newbry, Ashley

---

**From:** jon@aerospun.com  
**Sent:** Wednesday, August 06, 2014 3:02 PM  
**To:** Newbry, Ashley  
**Subject:** Petition!

Hi, I would like to PETITION the requirement to have a measuring device installed on our pump station. If you can remove this requirement I would appreciate it very much. Thanks!

Take Care,

Jon Roadenbaugh

-----Original Message-----

**From:** Newbry, Ashley  
**Date:** 8/6/2014 1:32:08 PM  
**To:** Jon Roadenbaugh  
**Cc:** Nelson, Dan  
**Subject:** Beneficial Use Exam pursuant to WR 2-10350

Hello Jon,

Dan and I are reviewing some of the notes from the beneficial use exam yesterday; we noticed one issue:

*Condition 01J on your permit states, " Prior to diversion of water under this right, the right holder shall install and maintain a measuring device and lockable controlling works of a type acceptable to the Department as part of the diverting works."*

At your pumping station, you have lockable controlling works, but do not have a measuring device. After receiving some additional information, we have learned that you are able to petition to waive the measuring device condition, if you wish. Following the petition, we can issue an order which will waive this requirement.

If desired, please send me a formal letter or email stating your petition. (Please use the word "petition" in your request, in order for the Department to recognize it as a formal petition for waiver of a condition.)

Thanks,

*Ashley Newbry, EIT*

Water Rights Section

Idaho Dept. of Water Resources

State Office

322 E. Front Street

PO Box 83720

Boise, ID 83720-0098

(208) 287-4800 X 4846

\_\_\_\_\_ Information from ESET NOD32 Antivirus, version of virus signature database 10214 (20140806) \_\_\_\_\_

The message was checked by ESET NOD32 Antivirus.

<http://www.eset.com>