

RECEIVED
SEP 19 2013
IDWR / NORTH

September 13, 2013

Keith Franklin
Idaho Dept. of Water Resources
1910 Northwest Blvd., #210
Coeur d'Alene, ID 83814

Re: Syringa Heights Water Right, No. 95-9324

Dear Mr. Franklin:

The Syringa Water and Sewer Company (SWSC) has retained our firm to assist in the application for amendment of the above referenced application that was originally filed on January 4, 2006. The original application was protested by Kootenai Environmental Alliance (KEA) in February, 2006. IDWR scheduled a pre-hearing conference on July 30, 2013. The protestant did not appear to carry out the protest.

The attached amendment to the original permit application confirms SWSC's requests for diversion capacity of 2.0 cfs for Municipal purposes. The amendment adds a volume limitation of 221 acre feet per year. This amendment is consistent with IDWR's recommendations during our meeting on July 30, 2013. The supporting information for the requested diversion rate and volume limitation is presented below.

The water system service area includes the following residential lots:

Silver Beach	11 homes
Syringa Grove	6 homes
Mullan Bluff	3 homes
Syringa Heights 1-7th Addn.	65 homes

Total: 85 Homes

In accordance with IDWR guidelines; the maximum diversion capacity and volume limitations were determined as follows:

Maximum Diversion Capacity:

- 0.010 cfs per home for internal use ($0.010 \times 85 = 0.85$ cfs)
- 0.013 cfs per home for irrigation ($0.013 \times 85 = 1.105$ cfs)

Total: 1.96 cfs


Annual Volume Limitation:

- 0.6 acre-feet per home for internal use ($0.6 \times 85 = 51$ acre-feet)
- 2 acre-feet per year for irrigation use ($2 \times 85 = 170$ acre-feet)

Total: 221 acre-feet per year

If you have any questions or need additional information, please contact me at 664-9382.

Sincerely,



Steven B. Cordes, P.E.

Vice President / Principal Engineer

SBC/ch

Enclosure: maps

cc: Syringa Water & Sewer Co.