



RECEIVED
MAR 14 2014
DEPARTMENT OF
WATER RESOURCES

March 12, 2014

CERTIFIED MAIL 7012 2210 0000 6037 4243

Mr. Jeff Peppersack
Bureau Chief, Water Allocations
Idaho Department of Water Resources
P.O. Box 83720
Boise, Idaho 83720-0098

Reference: Water Right Permit 63-31183 Annual Report – 2013
Micron Technology, Inc. – Boise Site

Dear Mr. Peppersack:

To fulfill the annual report requirements of Condition #9 of Water Right Permit 63-31183, Micron Technology, Inc. (Micron) is submitting (1) a chart that depicts monthly recharge volumes, monthly diversion volumes, and local area water-level hydrographs and (2) a chart that depicts net annual diversion volume (i.e., Micron diversions minus recharge) and local area water-level hydrographs. The period for the charts is 2002 through 2013, which corresponds to the development period for Water Right Permit 63-31183.

The charts indicate continued stabilization and improvement in the deep aquifer water level as a result of Micron's efforts to reduce net diversions. If you have any questions regarding this submittal, please contact Jim Nielsen at (208) 368-3366.


Sincerely,

A handwritten signature in cursive script, reading 'Ricky L. Murray'.


Ricky L. Murray
Water and Chemical Services Manager
Micron Technology, Inc.

Cc: Michael McIntyre, Micron Technology, Inc.

Micron Technology, Inc. Hydrograph (2)
2013 Annual Report (Water Right Permit 63-31183)



Micron Technology, Inc. Hydrograph (1)
2013 Annual Report (Water Right Permit 63-31183)



Micron Technology, Inc. Hydrograph Notes
2012 Annual Report (Water Right Permit 63-31183)

Description	Date
Started recharging	3/01
Started Well 6	11/06
Started Stage 200 Ultrafiltration skid	6/07
Started Fab 1 shutdown activities	11/08
Shutdown Well 3	2/09
Shutdown Well 6	10/09
Halted recharge for repairs to injection well control valve	10/23/09 – 11/24/09
Shutdown Stage 200 Ultrafiltration skid to replace feedwater control valve positioners	2/19/10 – 3/24/10
Shutdown Stage 200 Ultrafiltration skid to replace modules due to fiber breakage	4/23/10 – 10/27/10
Temporarily restarted Well 6	7/23/10 – 10/20/10
Well 3 and 6 off for the entire year.(Well 6 ran for 2.25 hrs on 5/3/2011)	5/3/2011
Well 3 started to meet increased demand	4/24/2012
Well 3 shut down due to declining pump output.	5/21/2012
Started Well 6 5/23/12 to meet increased demand	5/23/2012
Well 4 and Well 6 operated throughout year	2013