

MEMORANDUM

TO: Danielle Favreau

FROM: Daniel Nelson – Staff Hydrologist

DATE: December 4, 2013,

SUBJECT: Licensing Review of Water Right 57-7684

I was asked to run the Department's Pond Spreadsheet on the two ponds associated with this water right. One of the ponds is the White Horse Reservoir #1 and the other pond is the White Horse Reservoir #2. The Bureau of Land Management (BLM) representative informed us that the White Horse Reservoir #1 has an average depth of 3.5 feet and our GIS information shows the pond at 0.1 acres of surface area. With this information the pond capacity is 0.4 acre feet, and the evaporation for this pond is 0.2 acre feet for a total of 0.6 acre feet of total storage requirement needed. This pond appears to be on stream and very close to a spring, so no seepage was calculated.

The Bureau of Land Management (BLM) representative informed us that the White Horse Reservoir #2 has an average depth of 3.5 feet and our GIS information shows the pond at 0.5 acres of surface area. With this information the pond capacity is 1.8 acre feet, and the evaporation for this pond is 1.3 acre feet for a total of 3.1 acre feet of total storage requirement needed. This pond appears to be on stream and very close to a spring, so no seepage was calculated.

Water right permit 57-7684 allows a total storage volume of 1.7 acre feet. The pond capacity and evaporation losses for the White Horse Reservoir #1 is 0.6 acre feet, which is less than half of the amount allowed by the permit. Reservoir #2 has a pond capacity of 1.8 acre feet and total water need with evaporation of 3.1 acre feet, which is more than the permit allows.

This creates an interesting situation. BLM can do one of the following things:

- 1.) Have this license go to White Horse Reservoir #1 and reduce the water right permit to 0.6 acre feet. Then BLM would need to file another water right for White Horse Reservoir #2 for 3.1 acre feet.
- 2.) Have this license go to White Horse Reservoir #2 and file one new water right to bring White Horse Reservoir #2 up to the 3.1 acre feet it needs to be in compliance, and file a second new water right for White Horse Reservoir #1 to cover the 0.6 acre feet needed to bring this water use into compliance.

We cannot make this decision for the BLM, and it is up to the BLM to determine what they want to do before we can license water right permit 57-7684. We will need the transfer or the petition and new applications on file before we can license this permit.

TOTAL STORAGE

FILE NUMBER	57-7687 Res. 1
REVIEWER	Dan Nelson
DATE	11/26/2013

This spreadsheet has been designed by Idaho Department of Water Resources to estimate the total seepage, evaporation and fill capacity required for a pond

Surface Area (In Acres)	0.1	"Surface Area" is automatically carried over from the "Seepage Loss Sheet"
Average Pond Depth (In feet)	3.5	"Average Pond Depth" depicts the actual depth of the pond either measured or estimated. Note: If you know the maximum depth and not the average depth, the field examiner's handbook suggests multiplying the maximum depth by 0.4 to get the average depth, or you can use any method that you know the capacity, divide the capacity by surface area and enter the average pond depth in the space above.
Pond Capacity (in acre feet)	0.35	

Volume Needed Above Initial Fill to Fulfill From Storage Needs- "Multiple Fills" (in acre feet)	0	The "Volume Needed Above Initial Fill" is the acre-feet of water required to meet <i>from storage</i> component if the <i>from storage</i> component exceeds a one time fill. This section should not include the amount of water needed to fill the pond initially or the amount of water needed to maintain the pond level due to evaporation or seepage. For example: if a pond has a capacity of 5 acre feet and 2.5 acre feet of seepage and evaporation, but the pond is used for irrigation that requires 10 acre feet of from storage for the irrigation use, then you would insert 5 acre feet into this location (10 acre feet needed - 5 acre feet from the initial fill = 5 acre feet of additional storage needed). PLEASE NOTE: You must have a "From Storage" component exceeding the initial fill on the permit to include a volume in this space.
Estimated Seepage Loss (in acre feet)	0.00	The "Estimated Seepage Loss" is automatically carried over from the Seepage Loss Sheet
Estimated Evaporation Loss (in acre feet)	0.27	The "Estimated Evaporation Loss" is automatically carried over from the Evaporation Loss Sheet
Total Volume Required (in acre feet)	0.6	"The Total Volume Required" is calculated by adding the Pond Capacity, Multiple Fills, Seepage Loss, and Evaporation Loss amounts to determine the total amount of storage required.

Flow Rate Into Pond (in cfs)	1.00	The "Flow Rate" Into the Pond depicts the actual flow either measured or estimated into the pond.
Highest Daily Evaporation Rate From Evaporation Tab. (In mm/day)	5.05	This number is automatically selected by picking the highest recorded number in the "Precipitation Deficit Table".
Maximum Required Daily Maintenance Volume (in acre feet per day)	0.00	"Maximum Required Daily Maintenance Volume" is the maximum volume of water needed on any given day during the year, and is calculated by adding the highest daily evaporation loss to the average daily seepage loss in acre feet. The average daily seepage loss is calculated by dividing the "Estimated Seepage Loss" by 365 days. This is acceptable, since the seepage rate shouldn't vary throughout the season unless the pond completely freezes over during the winter months. The highest daily evaporation loss is calculated by dividing the Highest Daily Evaporation Rate by the 304.8 conversion factor and multiplying this number by the pond surface area to attain a combined daily acre feet requirement.
Minimum Maintenance Flow (in cfs)	0.00	The "Minimum Maintenance Flow" is the minimum amount of flow required to maintain the level of the pond. This number is determined by dividing the "Maximum Required Daily Maintenance Volume" by 1.9835. This flow can be used to determine if the flow rate into the pond is adequate to maintain the pond level.
Days Required to Fill the Pond	0	The "Days Required to Fill the Pond" is calculated by dividing the "Pond Capacity" by the "Flow Rate" minus "Minimum Maintenance Flow" multiplied by 1.9835. This section will assist you in determining if the flow rate being diverted to the pond is adequate to fill the pond while maintaining the pond level. The length of time to fill the pond will help determine if the flow rate is adequate for the size of pond being proposed. This number should be between 1 and 365 days for a project to be successful.
Days Required to Fill the Pond at 13,000 gallons per day	9	The "Days Required to Fill the Pond at 13,000 gallons per day" is calculated converting the "Pond Capacity" and the "Maximum Daily Maintenance Volume" to gallons. The "Pond Capacity" is then divided by 13,000 gallons minus the "Maximum Daily Maintenance Volume" in gallons to determine the number of days to fill pond. This number should be between 1 and 365 if this pond is to be described as a domestic use.

User Input
Calculated value
Formula Explanations

White Horse #1

Evaporation Loss Calculation

FILE NUMBER	57-7687 Res. 1
REVIEWER	Dan Nelson
DATE	11/26/2013

This spreadsheet has been designed by Idaho Department of Water Resources to estimate the annual evaporation losses from a pond.

The acronyms used on the Kimberly Research Center website are defined below:

P = Precipitation
ET= Evapotranspiration
P _d = Precipitation deficit
P _d =ET-P

User Input

Calculated value

Formula Explanations

USING THIS SPREADSHEET

To ascertain the evaporation from a pond, you will need to go to the Kimberley Research Center website. The link is found below. This web site provides the Precipitation Deficit for the area where the pond is located. The Precipitation Deficit is the total amount of free pan evaporation minus the precipitation for a given area, which gives the total amount of evaporative losses incurred by the pond. There are several weather sites that are used, and the entire state is pretty much covered. IDWR staff can find the nearest site using Arc Map. The shape file containing the sites can be found at X:/Spatial/Climate/ETIdahostations.shp.

Found at: <http://www.kimberly.uidaho.edu/ETIdaho/online.php>

Precipitation Deficit

Station: Twin Falls 2 NNE (NWS -- 109294)

Month	mm/day ¹	Days per month	mm/Month
Jan	0.00	31	0.00
Feb	0.59	28	16.52
March	1.62	31	50.22
April	2.87	30	86.10
May	3.50	31	108.50
June	4.28	30	128.40
July	5.05	31	156.55
August	4.18	31	129.58
September	2.82	30	84.60
October	1.81	31	56.11
November	0.48	30	14.40
December	0.00	31	0.00

PLEASE NOTE: We cannot use the season average, because there are several areas in Northern Idaho with a negative Precipitation Deficit. Therefore, we must enter each monthly deficit, and enter in a zero (0) for each negative month. The reason for this is that precipitation can only offset evaporation to the extent of the evaporation.

Please enter the daily average Precipitation Deficit as shown in the example below.

Although it has sometimes been useful to consider wintertime evaporation to be zero, Allen and Robison (2007, p. 169) noted, "Evaporation during nongrowing (wintertime) periods varies widely"

¹Negative monthly mean values should be entered in the above table as "0".

Total mm/year = **830.98**

$[(\text{mm/yr}) \div (\text{convert to feet})] \times (\text{Surface area of pond, in acres}) = \text{Evaporation Loss in Acre Feet}$

(**830.98**) $\div$ (**304.8**) $\times$ (**0.10**) = (**0.3 AFA**)

Surface Area of Pond is automatically Carried over from the Seepage Loss Sheet.

SEEPAGE CALCULATIONS

This spreadsheet has been designed by Idaho Department of Water Resources to estimate the total annual seepage losses from a pond.

FILE NUMBER	57-7687 Res. 1
REVIEWER	Dan Nelson
DATE	11/26/2013

User Input
Calculated value
Formula Explanations

INPUTS

SQ. FT. Calculator
Pond Surface area in acres
0.1

POND SURFACE AREA (SQ. FT.)	4356
-----------------------------	------

SUGGESTED SEEPAGE RATE (FT/DAY)	0.0000
---------------------------------	--------

Use the table below to find the "SUGGESTED SEEPAGE RATES".

FORMULA:
(Surface Area X Seepage Rate) / 7.48 = Gallons Per Day loss

CONVERT TO GPD	0	GPD
----------------	---	-----

TOTAL SEEPAGE LOSS (AFA)	0.0	AFA
--------------------------	-----	-----

SUGGESTED SEEPAGE RATES FOR DIFFERENT SOIL TYPES:
GW, GP, GM, GC, SW, SP and SM (silty sand, sand silt mixtures and gravel mixtures) = 0.20 ft per day
OL and ML (inorganic silts - very fine sands, silty, or clayey fine sands) = 0.016 ft per day
SC (clayey sands, sand clay mixtures) = 0.007 ft per day
CL (Low to medium plasticity clays) = 0.003 ft per day
MH, OH, PT and CH (high plasticity clays) = 0.0003 ft per day
LINED PONDS (liners can be chemical, fabric, or bentonite) = 0 ft per day
Ponds Intercepting Groundwater (excavated ponds filled with shallow Ground Water) = 0 ft per day

PLEASE NOTE: The initial basis for the Suggested Seepage Rates in the table above is found on Page 16 of Seepage from Fish Ponds, Bulletin 599, August 1989 Alabama Agricultural experiment Station, Auburn University, Auburn University Alabama. If you don't know the soil type, please refer to the map provided at X:\Spatial\Soils\USCS\PondSoils.lyr. Use "0" if the ponds intersect the water table.

ET_{Idaho} 2012 -- Evapotranspiration and Consumptive Irrigation Water Requirements for Idaho

Please send suggestions for improving this site to robison@kimberly.uidaho.edu Copyright 2012, University of Idaho.

Grand View (NWS -- 103760)

Statistics based on thirty year normal spans 1940 to 2008 years

For a different land cover or crop click on the above link.

You can highlight this table and copy via the clipboard to a Microsoft Excel or OpenOffice spreadsheet to plot or otherwise work with this data.

Open water - shallow systems (ponds, streams)															
Precipitation Deficit (Click here for a graph)															
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Growing Season ^a	Non Growing Season ^b	Annual
Mean ^j	mm/day												mm		
Monthly ^c	0.08	0.59	1.62	2.87	3.50	4.28	5.05	4.18	2.82	1.81	0.48	0.02	819	0	819
15-Day Moving Average ^d	0.09	0.52	1.63	2.91	3.54	4.28	5.09	4.16	2.73	1.88	0.44	0.05			
7-Day Moving Average ^e	0.10	0.58	1.61	2.86	3.51	4.28	5.07	4.17	2.79	1.83	0.44	0.05			
3-Day Moving Average ^f	0.09	0.60	1.63	2.87	3.49	4.29	5.06	4.18	2.81	1.81	0.47	0.03			
Standard Deviation ^k	mm/day												mm		
Monthly ^c	0.56	0.53	1.07	0.69	1.35	0.80	0.78	0.75	0.73	0.83	0.50	0.73	95	0	95
15-Day Moving Average ^d	0.56	0.71	1.02	0.83	1.21	1.03	0.68	0.69	1.02	0.74	0.66	0.64			
7-Day Moving Average ^e	0.80	0.91	1.20	1.22	1.64	1.36	0.88	0.89	1.25	1.04	0.87	0.82			
3-Day Moving Average ^f	1.15	1.22	1.57	1.68	2.17	1.79	1.21	1.19	1.60	1.34	1.18	1.13			
20% Exceedance ^l	mm/day												mm		
Monthly ^c	0.15	0.95	2.18	3.54	4.34	4.96	5.61	4.61	3.32	2.29	0.88	0.40	860	0	860
15-Day Moving Average ^d	0.54	1.34	2.73	4.04	4.85	5.38	5.87	4.95	3.77	2.80	1.17	0.60			
7-Day Moving Average ^e	0.78	1.84	3.29	4.71	5.61	5.95	6.16	5.22	4.19	3.05	1.67	0.88			
3-Day Moving Average ^f	0.98	2.17	3.95	5.24	6.18	6.56	6.61	5.66	4.70	3.57	1.95	1.09			

TOTAL STORAGE

FILE NUMBER	57-7687 Res. 2
REVIEWER	Dan Nelson
DATE	11/26/2013

This spreadsheet has been designed by Idaho Department of Water Resources to estimate the total seepage, evaporation and fill capacity required for a pond

Surface Area (in Acres)	0.5	"Surface Area" is automatically carried over from the "Seepage Loss Sheet"
Average Pond Depth (in feet)	3.5	"Average Pond Depth" depicts the actual depth of the pond either measured or estimated. Note: If you know the maximum depth and not the average depth, the field examiner's handbook suggests multiplying the maximum depth by 0.4 to get the average depth, or you can use any method that you know the capacity, divide the capacity by surface area and enter the average pond depth in the space above.
Pond Capacity (in acre feet)	1.75	

Volume Needed Above Initial Fill to Fulfill From Storage Needs- "Multiple Fills" (in acre feet)	0	The "Volume Needed Above Initial Fill" is the acre-feet of water required to meet <i>from storage</i> component if the <i>from storage</i> component exceeds a one time fill. This section should not include the amount of water needed to fill the pond initially or the amount of water needed to maintain the pond level due to evaporation or seepage. For example: if a pond has a capacity of 5 acre feet and 2.5 acre feet of seepage and evaporation, but the pond is used for irrigation that requires 10 acre feet of from storage for the irrigation use, then you would insert 5 acre feet into this location (10 acre feet needed - 5 acre feet from the initial fill = 5 acre feet of additional storage needed). PLEASE NOTE: You must have a "From Storage" component exceeding the initial fill on the permit to include a volume in this space.
Estimated Seepage Loss (in acre feet)	0.00	The "Estimated Seepage Loss" is automatically carried over from the Seepage Loss Sheet
Estimated Evaporation Loss (in acre feet)	1.36	The "Estimated Evaporation Loss" is automatically carried over from the Evaporation Loss Sheet
Total Volume Required (in acre feet)	3.1	"The Total Volume Required" is calculated by adding the Pond Capacity, Multiple Fills, Seepage Loss, and Evaporation Loss amounts to determine the total amount of storage required.

Flow Rate Into Pond (in cfs)	1.00	The "Flow Rate" Into the Pond depicts the actual flow either measured or estimated into the pond
Highest Daily Evaporation Rate From Evaporation Tab. (in mm/day)	5.05	This number is automatically selected by picking the highest recorded number in the "Precipitation Deficit Table".
Maximum Required Daily Maintenance Volume (in acre feet per day)	0.01	"Maximum Required Daily Maintenance Volume" is the maximum volume of water needed on any given day during the year, and is calculated by adding the highest daily evaporation loss to the average daily seepage loss in acre feet. The average daily seepage loss is calculated by dividing the "Estimated Seepage Loss" by 365 days. This is acceptable, since the seepage rate shouldn't vary throughout the season unless the pond completely freezes over during the winter months. The highest daily evaporation loss is calculated by dividing the Highest Daily Evaporation Rate by the 304.8 conversion factor and multiplying this number by the pond surface area to attain a combined daily acre feet requirement.
Minimum Maintenance Flow (in cfs)	0.00	The "Minimum Maintenance Flow" is the minimum amount of flow required to maintain the level of the pond. This number is determine by dividing the "Maximum Required Daily Maintenance Volume" by 1.9835. This flow can be used to determine if the flow rate into the pond is adequate to maintain the pond level.
Days Required to Fill the Pond	1	The "Days Required to Fill the Pond" is calculated by dividing the "Pond Capacity" by the "Flow Rate" minus "Minimum Maintenance Flow" multiplied by 1.9835. This section will assist you in determining if the flow rate being diverted to the pond is adequate to fill the pond while maintaining the pond level. The length of time to fill the pond will help determine if the flow rate is adequate for the size of pond being proposed. This number should be between 1 and 365 days for a project to be successful.
Days Required to Fill the Pond at 13,000 gallons per day	55	The "Days Required to Fill the Pond at 13,000 gallons per day" is calculated converting the "Pond Capacity" and the "Maximum Daily Maintenance Volume" to gallons. The "Pond Capacity" is then divided by 13,000 gallons minus the "Maximum Daily Maintenance Volume" in gallons to determine the number of days to fill pond. This number should be between 1 and 365 if this pond is to be described as a domestic use.

User Input
Calculated value
Formula Explanations

White Horse
#2

Evaporation Loss Calculation

FILE NUMBER	57-7687 Res. 2
REVIEWER	Dan Nelson
DATE	11/26/2013

This spreadsheet has been designed by Idaho Department of Water Resources to estimate the annual evaporation losses from a pond.

The acronyms used on the Kimberly Research Center website are defined below:

P = Precipitation
ET= Evapotranspiration
P _d = Precipitation deficit
P _d =ET-P

User Input

Calculated value

Formula Explanations

USING THIS SPREADSHEET

To ascertain the evaporation from a pond, you will need to go to the Kimberley Research Center website. The link is found below. This web site provides the Precipitation Deficit for the area where the pond is located. The Precipitation Deficit is the total amount of free pan evaporation minus the precipitation for a given area, which gives the total amount of evaporative losses incurred by the pond. There are several weather sites that are used, and the entire state is pretty much covered. IDWR staff can find the nearest site using Arc Map. The shape file containing the sites can be found at X:/Spatial/Climate/ETIdahostations.shp.

Found at: <http://www.kimberly.uidaho.edu/ETIdaho/online.php>

Precipitation Deficit

Station: Twin Falls 2 NNE (NWS -- 109294)

Month	mm/day ¹	Days per month	mm/Month
Jan	0.00	31	0.00
Feb	0.59	28	16.52
March	1.62	31	50.22
April	2.87	30	86.10
May	3.50	31	108.50
June	4.28	30	128.40
July	5.05	31	156.55
August	4.18	31	129.58
September	2.82	30	84.60
October	1.81	31	56.11
November	0.48	30	14.40
December	0.00	31	0.00

PLEASE NOTE: We cannot use the season average, because there are several areas in Northern Idaho with a negative Precipitation Deficit. Therefore, we must enter each monthly deficit, and enter in a zero (0) for each negative month. The reason for this is that precipitation can only offset evaporation to the extent of the evaporation.

Please enter the daily average Precipitation Deficit as shown in the example below.

Although it has sometimes been useful to consider wintertime evaporation to be zero, Allen and Robison (2007, p. 169) noted, "Evaporation during nongrowing (wintertime) periods varies widely"

¹Negative monthly mean values should be entered in the above table as "0".

Total mm/year = 830.98

$[(\text{mm/yr}) \div (\text{convert to feet})] \times (\text{Surface area of pond, in acres}) = \text{Evaporation Loss in Acre Feet}$

(830.98) $\div$ (304.8) $\times$ 0.50 = 1.4 AFA

Surface Area of Pond is automatically Carried over from the Seepage Loss Sheet.

SEEPAGE CALCULATIONS

This spreadsheet has been designed by Idaho Department of Water Resources to estimate the total annual seepage losses from a pond.

FILE NUMBER	57-7687 Res. 2
REVIEWER	Dan Nelson
DATE	11/26/2013

User Input
Calculated value
Formula Explanations

INPUTS

SQ. FT. Calculator Pond Surface area in acres
0.5

POND SURFACE AREA (SQ. FT.)	21780
-----------------------------	-------

SUGGESTED SEEPAGE RATE (FT/DAY)	0.0000
---------------------------------	--------

Use the table below to find the "SUGGESTED SEEPAGE RATES".

FORMULA: (Surface Area X Seepage Rate) / 7.48 = Gallons Per Day loss

CONVERT TO GPD	0	GPD
----------------	---	-----

TOTAL SEEPAGE LOSS (AFA)	0.0	AFA
--------------------------	-----	-----

SUGGESTED SEEPAGE RATES FOR DIFFERENT SOIL TYPES:
GW, GP, GM, GC, SW, SP and SM (silty sand, sand silt mixtures and gravel mixtures) = 0.20 ft per day
OL and ML (inorganic silts - very fine sands, silty, or clayey fine sands) = 0.016 ft per day
SC (clayey sands, sand clay mixtures) = 0.007 ft per day
CL (Low to medium plasticity clays) = 0.003 ft per day
MH, OH, PT and CH (high plasticity clays) = 0.0003 ft per day
LINED PONDS (liners can be chemical, fabric, or bentonite) = 0 ft per day
Ponds Intercepting Groundwater (excavated ponds filled with shallow Ground Water) = 0 ft per day

PLEASE NOTE: The initial basis for the Suggested Seepage Rates in the table above is found on Page 16 of Seepage from Fish Ponds, Bulletin 599, August 1989 Alabama Agricultural experiment Station, Auburn University, Auburn University Alabama. If you don't know the soil type, please refer to the map provided at <X:\Spatial\Soils\USCS\PondSoils.lyr>. Use "0" if the ponds intersect the water table.

ET_{Idaho} 2012 -- Evapotranspiration and Consumptive Irrigation Water Requirements for Idaho

Please send suggestions for improving this site to robison@kimberly.uidaho.edu Copyright 2012, University of Idaho.

Grand View (NWS -- 103760)

Statistics based on thirty year normal spans 1940 to 2008 years


For a different land cover or crop click on the above link.

You can highlight this table and copy via the clipboard to a Microsoft Excel or OpenOffice spreadsheet to plot or otherwise work with this data.

Open water - shallow systems (ponds, streams)															
Precipitation Deficit (Click here for a graph)															
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Growing Season ^a	Non Growing Season ^b	Annual
Mean ^j	mm/day												mm		
Monthly ^c	0.08	0.59	1.62	2.87	3.50	4.28	5.05	4.18	2.82	1.81	0.48	0.02	819	0	819
15-Day Moving Average ^d	0.09	0.52	1.63	2.91	3.54	4.28	5.09	4.16	2.73	1.88	0.44	0.05			
7-Day Moving Average ^e	0.10	0.58	1.61	2.86	3.51	4.28	5.07	4.17	2.79	1.83	0.44	0.05			
3-Day Moving Average ^f	0.09	0.60	1.63	2.87	3.49	4.29	5.06	4.18	2.81	1.81	0.47	0.03			
Standard Deviation ^k	mm/day												mm		
Monthly ^c	0.56	0.53	1.07	0.69	1.35	0.80	0.78	0.75	0.73	0.83	0.50	0.73	95	0	95
15-Day Moving Average ^d	0.56	0.71	1.02	0.83	1.21	1.03	0.68	0.69	1.02	0.74	0.66	0.64			
7-Day Moving Average ^e	0.80	0.91	1.20	1.22	1.64	1.36	0.88	0.89	1.25	1.04	0.87	0.82			
3-Day Moving Average ^f	1.15	1.22	1.57	1.68	2.17	1.79	1.21	1.19	1.60	1.34	1.18	1.13			
20% Exceedance ^l	mm/day												mm		
Monthly ^c	0.15	0.95	2.18	3.54	4.34	4.96	5.61	4.61	3.32	2.29	0.88	0.40	860	0	860
15-Day Moving Average ^d	0.54	1.34	2.73	4.04	4.85	5.38	5.87	4.95	3.77	2.80	1.17	0.60			
7-Day Moving Average ^e	0.78	1.84	3.29	4.71	5.61	5.95	6.16	5.22	4.19	3.05	1.67	0.88			
3-Day Moving Average ^f	0.98	2.17	3.95	5.24	6.18	6.56	6.61	5.66	4.70	3.57	1.95	1.09			


White Horse #2 And

57-7684




D. Favreau

02/07/14



White Horse #2 And

57-7684



D. Favreau

02/07/14

SWNE

POD White Horse #1

White Horse #1

Troughs

07S02W
13

POD Troughs (Headbox)


White Horse Creek

White Horse #2

POD White Horse #2

NWSE

White Horse #2 and
57-7684



D. Favreau

02/07/14

SWNE

POD White Horse #1

White Horse #1

Troughs

07S02W
13

POD Troughs (Headbox)

White Horse Creek

White Horse #2

POD White Horse #2

NWSE