



STATE OF IDAHO
WATER DISTRICT 130
C/O IDAHO DEPARTMENT OF WATER RESOURCES
1341 FILLMORE ST, STE 200
TWIN FALLS, ID 83301-3380
TELEPHONE NUMBER (208) 736-3033
FACSIMILE NUMBER (208) 736-3037

IDWR DIRECTOR
GARY SPACKMAN

WATERMASTER
CINDY YENTER
Cindy.Yenter@idwr.idaho.gov

June 13, 2013

CLIFF JENSEN
PO BOX 201
HAGERMAN ID 83332

CHRISTY LOU AWALT
PO BOX 392
SAN MIGUEL CA 93451

RE: Measuring Device Approval, Water Right Permit Nos. 37-21456, 37-21486, 37-21827 and 37-21828, Malad State Park Reservoir

By letter dated March 21, 2013, I had directed you to construct or install suitable measurement and control devices pursuant to the above water right permits. The devices were to be installed above the reservoir, and at the diversion from the W-Drain.

On April 16, 2013, I conducted a field inspection and found a controllable screw-type headgate installed at the diversion from the W-Drain, and a four-foot rectangular contracted weir situated near the park office and above the reservoir, which is capable of measuring inflows up to approximately 12 cfs. The weir construction included a staff gage and stilling well as requested. These devices satisfy the measurement requirements of the permits and the minimum requirements of IDWR, and have been inspected and approved by the Watermaster of Water District 130.

Regards,

Cindy Yenter
Watermaster, Water District 130

cc: Bob Jones
Frank Erwin